

**Summary**

**Title I (ECIA) Administration  
TfS IAQ Walkthrough  
4-29-2008**

Temp 71.7 RH 46.1 CO2 598

FISH	Question	Answer	Recommendation	RP
002 Near 136	Temp	RH	CO2	
<p>Signs of water intrusion. Stained ceiling tiles.</p>		<p>Physical Plant Operations to evaluate for leaks and repair as appropriate and replace ceiling tiles as appropriate.</p>	<p>PPO</p>	
101	Temp 72.7	RH 43.2	CO2 610	
<p>Room is free of smell of mold or mildew?</p>		<p>No microbial growth identified. No odor identified at the time of assessment.</p>		
<p>Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?</p>		<p>Signs of water intrusion. Stained ceiling tiles.</p>	<p>Physical Plant Operations to evaluate for leaks and repair as appropriate and replace ceiling tiles as appropriate.</p>	<p>PPO</p>
<p>Temperature in my classroom is generally comfortable (72F-78F)?</p>		<p>Temperature was acceptable at the time of assessment.</p>		
<p>Classroom is free of significant temperature shifts?</p>		<p>Temperature was acceptable at the time of assessment.</p>		
<p>Room is free of the introduction of outdoor air? (Gaps in window/door frames.)</p>		<p>Gaps in windows identified at the time of assessment.</p>	<p>Physical Plant Operations to evaluate and repair as appropriate.</p>	<p>PPO</p>
<p>Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)</p>		<p>Humidity was acceptable at the time of assessment.</p>		
<p>Room is usually comfortable? (If no, please explain in the notes below.)</p>		<p>Environmental parameters were within acceptable range at the time of assessment..</p>		
<p>Room is free of the use of scented cleaners and air fresheners?</p>		<p>No scented cleaners air fresheners or non-approved chemicals found at the time of assessment.</p>		

**Summary**

**Title I (ECIA) Administration  
TfS IAQ Walkthrough  
4-29-2008**

Temp 71.7 RH 46.1 CO2 598

FISH	Question	Answer	Recommendation	RP
	Other exhaust fans that may exist in the classroom are functioning properly?	No exhaust fans in room. Identified in error.		
	Room is free of smell of chemicals? Room is free of smell of mold or mildew?	No odor detected at the time of assessment. No microbial growth identified. No odor identified at the time of assessment.		
	Water poured down floor drains once per week (approx. 1 quart of water).	No floor drain in room.		
	Windows, windowsills and window frames free of continuous condensation?	Condensation on windows at the time of assessment. Temperature was within acceptable range and no leaks were identified.		
	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	No dust observed on supply/return registers at the time of assessment.		
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?	No exhaust system/ventilation in room. Identified in error.		
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)	No exhaust system/ventilation in room. Identified in error.		
	Bathroom exhaust fan is functioning properly?	No bathroom. Identified in error.		
	Windows/doors are operable and are kept closed?	Windows and doors are operable and are kept closed.		

**Summary**

**Title I (ECIA) Administration  
TfS IAQ Walkthrough  
4-29-2008**

Temp 71.7 RH 46.1 CO2 598

<b>FISH</b>	<b>Question</b>	<b>Answer</b>	<b>Recommendation</b>	<b>RP</b>
	Classroom lavatories/water fountains free of leaks?	No lavatories/water fountains in room.		

102	Temp 0	RH 0	CO2 0	
-----	-----------	---------	----------	--

<b>Question</b>	<b>Answer</b>
Air flowing from air supply?	Restroom
Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.
Indoor surfaces of exterior walls free of continuous condensation?	No visible condensation or signs of water intrusion identified at the time of assessment.
Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.
My classroom has sufficient exhaust systems based on the activities/functionality of the room?	It appears that the ventilation system is adequate based on room activities.
Bathroom exhaust fan is functioning properly?	Bathroom exhaust fan is functioning properly.
Other exhaust fans that may exist in the classroom are functioning properly?	Exhaust fan is functioning properly.

105	Temp 75	RH 41.7	CO2 637	
-----	------------	------------	------------	--

Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.
Indoor surfaces of exterior walls free of continuous condensation?	No visible condensation or signs of water intrusion identified at the time of assessment.
Classroom lavatories/water fountains free of leaks?	No lavatories/water fountains in room.

**Summary**

**Title I (ECIA) Administration  
TfS IAQ Walkthrough  
4-29-2008**

Temp 71.7 RH 46.1 CO2 598

<b>FISH</b>	<b>Question</b>	<b>Answer</b>	<b>Recommendation</b>	<b>RP</b>
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks or signs of water intrusion identified.		
	Classroom is dusted/vacuumed thoroughly and regularly?	Excessive dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.		
	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was acceptable at the time of assessment.		
	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.		
	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..		

108	Temp 73.4	RH 44.6	CO2 748	
-----	--------------	------------	------------	--

	Floor is cleaned on a regular basis?	Missing broken or damaged floor tiles.	Physical Plant Operations to evaluate and repair/replace as appropriate.	PPO
	Other exhaust fans that may exist in the classroom are functioning properly?	No exhaust fans in room. Identified in error.		

109	Temp 76.5	RH 41.7	CO2 777	
-----	--------------	------------	------------	--

**Summary**

**Title I (ECIA) Administration  
TfS IAQ Walkthrough  
4-29-2008**

Temp 71.7 RH 46.1 CO2 598

FISH	Question	Answer	Recommendation	RP
	Other exhaust fans that may exist in the classroom are functioning properly?	No exhaust fans in room. Identified in error.		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.		
	Room is usually comfortable? (If no, please explain in the notes below.)	Supply vents closed/blocked at the time of assessment.	Facilities serviceperson to open supply vents.	Site
110	Temp 76.1	RH 40.2	CO2 706	
	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		
	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	Site
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	No dust observed on supply/return registers at the time of assessment.		
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?	No issues identified relating to spill clean up practices at the time of assessment..		
	Floor is cleaned on a regular basis?	Carpet was stained torn rippled or buckled.	Physical Plant Operations to evaluate and repair/replace as appropriate.	PPO
	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was acceptable at the time of assessment.		

**Summary**

**Title I (ECIA) Administration  
TfS IAQ Walkthrough  
4-29-2008**

Temp 71.7 RH 46.1 CO2 598

FISH	Question	Answer	Recommendation	RP
	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	Room is self contained with no access to outdoor untreated air.		
	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..		
111	Temp 77	RH 41.1	CO2 735	
	Air flowing from air supply?	Air supply/return ventilation is functioning.		
	Room is free of smell of vehicle exhaust?	No odor detected at the time of assessment.		
	Room is free of smell of kitchen/food?	No odor detected at the time of assessment.		
	Room is free of smell of chemicals?	No odor detected at the time of assessment.		
	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		
	Windows, windowsills and window frames free of continuous condensation?	No condensation on windows at the time of assessment.		
	Cold water pipes free of continuous condensation?	No pipes in room.		
	Indoor surfaces of exterior walls free of continuous condensation?	No visible condensation or signs of water intrusion identified at the time of assessment.		
	Area around and under classroom sinks free of leaks?	No sinks in room.		
	Classroom lavatories/water fountains free of leaks?	No lavatories/water fountains in room.		

**Summary**

**Title I (ECIA) Administration  
TfS IAQ Walkthrough  
4-29-2008**

Temp 71.7 RH 46.1 CO2 598

FISH	Question	Answer	Recommendation	RP
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks or signs of water intrusion identified.		
	Classrooms general appearance is clean and acceptable?	General cleanliness of the room at the time of assessment was acceptable.		
	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	No dust observed on supply/return registers at the time of assessment.		
	Room is free of pests?	No pests observed at the time of assessment.		
	Bathroom exhaust fan is functioning properly?	No bathroom. Identified in error.		
	Other exhaust fans that may exist in the classroom are functioning properly?	No exhaust fans in room. Identified in error.		
	Locker room and showers cleaned regularly and properly?	Issues not applicable. Room is not a locker room.		
	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was acceptable at the time of assessment.		
	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	No gaps in windows or doors identified at the time of assessment.		
	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..		

112

Temp

RH

CO2

RH - Relative Humidity  
RP - Responsible Party

**Summary**

**Title I (ECIA) Administration  
TfS IAQ Walkthrough  
4-29-2008**

Temp 71.7 RH 46.1 CO2 598

<b>FISH</b>	<b>Question</b>	<b>Answer</b>	<b>Recommendation</b>	<b>RP</b>
	76.5	41.7	746	
	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		
	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	Site
	Other exhaust fans that may exist in the classroom are functioning properly?	No exhaust fans in room. Identified in error.		

<b>120</b>	<b>Temp</b>	<b>RH</b>	<b>CO2</b>	
	75.3	49.5	912	
	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		
	Windows, windowsills and window frames free of continuous condensation?	No windows in room.		
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	Ceiling tiles broken damaged or missing.	Facilities serviceperson to replace ceiling tiles.	Site
	Classrooms general appearance is clean and acceptable?	General cleanliness of the room at the time of assessment was acceptable.		
	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	Site



**Summary**

**Title I (ECIA) Administration  
TfS IAQ Walkthrough  
4-29-2008**

Temp 71.7 RH 46.1 CO2 598

<b>FISH</b>	<b>Question</b>	<b>Answer</b>	<b>Recommendation</b>	<b>RP</b>
	Room is free of pests?	No pests observed at the time of assessment.		
	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was acceptable at the time of assessment.		
	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
	Room is free of smell of kitchen/food?	No odor detected at the time of assessment.		
	Room is free of smell of chemicals?	No odor detected at the time of assessment.		
	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	Ceiling tiles broken damaged or missing.	Facilities serviceperson to replace ceiling tiles.	Site
	Other exhaust fans that may exist in the classroom are functioning properly?	No exhaust fans in room. Identified in error.		

126	Temp 72	RH 61	CO2 713	
-----	------------	----------	------------	--

Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate and replace ceiling tiles as appropriate.	PPO
Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	Site
Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	PPO

**Summary**

**Title I (ECIA) Administration  
TfS IAQ Walkthrough  
4-29-2008**

Temp 71.7 RH 46.1 CO2 598

<b>FISH</b>	<b>Question</b>	<b>Answer</b>	<b>Recommendation</b>	<b>RP</b>
	Room is free of smell of kitchen/food?	No odor detected at the time of assessment.		
127	Temp 74	RH 58.2	CO2 749	
	Classroom is free of animals and pets?	Stuffed animals in the room.	Site based administration to advise occupant to thoroughly clean stuffed animals or remove from the room. Stuffed animals are a source of allergens.	Site
	Air flowing from air supply? Air is flowing without obstruction?	Air supply/return ventilation is functioning. Air flowing without obstruction at the time of assessments.		
	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		
	Area around and under classroom sinks free of leaks?	No sinks in room.		
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks or signs of water intrusion identified.		
	Classrooms general appearance is clean and acceptable?	General cleanliness of the room at the time of assessment was acceptable.		
	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	Site
	Trash is removed daily and trash bags are changed as appropriate?	No issues identified regarding trash removal practices.		
	Food, if any, is stored in tightly sealed containers?	No unsealed food items were observed at the time of assessment.		

**Summary**

**Title I (ECIA) Administration  
TfS IAQ Walkthrough  
4-29-2008**

Temp 71.7 RH 46.1 CO2 598

FISH	Question	Answer	Recommendation	RP
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	No dust observed on supply/return registers at the time of assessment.		
	Room is free of the use of scented cleaners and air fresheners?	No scented cleaners air fresheners or non-approved chemicals found at the time of assessment.		
	Floor is cleaned on a regular basis? My classroom has sufficient exhaust systems based on the activities/functionality of the room?	Floor was clean at the time of assessment. No exhaust system/ventilation in room. Identified in error.		
	Bathroom exhaust fan is functioning properly?	No bathroom. Identified in error.		
	Other exhaust fans that may exist in the classroom are functioning properly?	No exhaust fans in room. Identified in error.		
	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was acceptable at the time of assessment.		
	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	Room is self contained with no access to outdoor untreated air.		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.		
	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..		

128

Temp

RH

CO2

RH - Relative Humidity  
RP - Responsible Party

**Summary**

**Title I (ECIA) Administration  
TfS IAQ Walkthrough  
4-29-2008**

Temp 71.7 RH 46.1 CO2 598

<b>FISH</b>	<b>Question</b>	<b>Answer</b>	<b>Recommendation</b>	<b>RP</b>
	71	62.4	775	
	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks or signs of water intrusion identified.		
	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
	Room is free of pests?	No pests observed at the time of assessment.		
	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
		Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	PPO
	Classroom is free of significant temperature shifts?	Temperature was low at the time of assessment.	See previous recommendation.	
130	Temp 71	RH 62.4	CO2 775	
	Area around and under classroom sinks free of leaks?	No sinks in room.		

**Summary**

**Title I (ECIA) Administration  
TfS IAQ Walkthrough  
4-29-2008**

Temp 71.7 RH 46.1 CO2 598

FISH	Question	Answer	Recommendation	RP
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks or signs of water intrusion identified.		
	Room is free of the use of scented cleaners and air fresheners?	No scented cleaners air fresheners or non-approved chemicals found at the time of assessment.		
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?	No issues identified relating to spill clean up practices at the time of assessment..		
	Floor is cleaned on a regular basis? Other exhaust fans that may exist in the classroom are functioning properly?	Floor was clean at the time of assessment. No exhaust fans in room. Identified in error.		
	Locker room and showers cleaned regularly and properly?	Issues not applicable. Room is not a locker room.		
	Exposure minimized for art supplies?	No art supplies in room. Room not being used as an art room.		
	Exposure minimized for science supplies?	No science supplies in room. Room not being used as a science room.		
	Exposure minimized for industrial supplies?	No industrial supplies in room. Room not being used as an industrial room. Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site

**Summary**

**Title I (ECIA) Administration  
TfS IAQ Walkthrough  
4-29-2008**

Temp 71.7 RH 46.1 CO2 598

FISH	Question	Answer	Recommendation	RP
		Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	PPO
132	Temp 75	RH 57	CO2 787	
	Room is free of smell of mold or mildew?  Indoor surfaces of exterior walls free of continuous condensation?  Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	No microbial growth identified. No odor identified at the time of assessment.  No visible condensation or signs of water intrusion identified at the time of assessment.  Humidity was acceptable at the time of assessment.		
134	Temp 74.1	RH 58	CO2 805	
	Room is free of smell of mold or mildew?  Other exhaust fans that may exist in the classroom are functioning properly?  Classroom is free of significant temperature shifts?	No microbial growth identified. No odor identified at the time of assessment.  No exhaust fans in room. Identified in error.  Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate and replace ceiling tiles as appropriate.	PPO
137	Temp 74.5	RH 56.7	CO2 692	
	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		

**Summary**

**Title I (ECIA) Administration  
TfS IAQ Walkthrough  
4-29-2008**

Temp 71.7 RH 46.1 CO2 598

<b>FISH</b>	<b>Question</b>	<b>Answer</b>	<b>Recommendation</b>	<b>RP</b>
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)? Room is free of pests? Temperature in my classroom is generally comfortable (72F-78F)? Room is usually comfortable? (If no, please explain in the notes below.)	Signs of water intrusion. Stained ceiling tiles.  No pests observed at the time of assessment. Temperature was acceptable at the time of assessment.  Environmental parameters were within acceptable range at the time of assessment..	Physical Plant Operations to evaluate for leaks and repair as appropriate and replace ceiling tiles as appropriate.	PPO
138	Temp 74.6	RH 55.7	CO2 644	
	Room is free of smell of kitchen/food? Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)? Classroom is dusted/vacuumed thoroughly and regularly? Room is free of pests? Floor is cleaned on a regular basis? Room is usually comfortable? (If no, please explain in the notes below.)	No odor detected at the time of assessment. Signs of water intrusion. Stained ceiling tiles.  There does not appear to be a dusting issue within this room. No pests observed at the time of assessment. Floor was clean at the time of assessment. Environmental parameters were within acceptable range at the time of assessment..	Physical Plant Operations to evaluate for leaks and repair as appropriate and replace ceiling tiles as appropriate.	PPO
139	Temp 75	RH 54.5	CO2 661	
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)? Classroom is dusted/vacuumed thoroughly and regularly?	Signs of water intrusion. Stained ceiling tiles.  There does not appear to be a dusting issue within this room.	Physical Plant Operations to evaluate for leaks and repair as appropriate and replace ceiling tiles as appropriate.	PPO

**Summary**

**Title I (ECIA) Administration  
TfS IAQ Walkthrough  
4-29-2008**

Temp 71.7 RH 46.1 CO2 598

FISH	Question	Answer	Recommendation	RP
	<p>Air supply/return registers are cleaned regularly and free of dust and debris accumulation?</p> <p>Room is free of pests?</p> <p>Floor is cleaned on a regular basis?</p> <p>My classroom has sufficient exhaust systems based on the activities/functionality of the room?</p> <p>Temperature in my classroom is generally comfortable (72F-78F)?</p> <p>Classroom is free of significant temperature shifts?</p> <p>Room is usually comfortable? (If no, please explain in the notes below.)</p>	<p>No dust observed on supply/return registers at the time of assessment.</p> <p>No pests observed at the time of assessment.</p> <p>Floor was clean at the time of assessment.</p> <p>No exhaust system/ventilation in room. Identified in error.</p> <p>Temperature was acceptable at the time of assessment.</p> <p>Temperature was acceptable at the time of assessment.</p> <p>Environmental parameters were within acceptable range at the time of assessment..</p> <p>Hole in wall and gap in light fixture.</p>	<p>Physical Plant Operations to evaluate and repair as appropriate.</p>	<p>PPO</p>
143	Temp	RH	CO2	
		<p>Dust impaction on ceiling tiles at supply grills.</p>	<p>Facilities serviceperson to thoroughly clean or remove and replace ceiling tiles.</p>	<p>Site</p>
149	Temp 74.8	RH 46.6	CO2 708	
	<p>Activities and/or room conditions are modified to address student allergies?</p>	<p>This is a general issue requiring approved communication among all stakeholders.</p>	<p>Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.</p>	<p>Site</p>



**Summary**

**Title I (ECIA) Administration  
TfS IAQ Walkthrough  
4-29-2008**

Temp 71.7 RH 46.1 CO2 598

FISH	Question	Answer	Recommendation	RP
	Room is free of smell of mold or mildew? Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No microbial growth identified. No odor identified at the time of assessment. No leaks or signs of water intrusion identified.		
149A	Temp 76.5	RH 45.4	CO2 718	
	Room is free of smell of mold or mildew? Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)? Other exhaust fans that may exist in the classroom are functioning properly?	Stained ceiling tile with minor microbial growth. Signs of water intrusion. Stained ceiling tiles. No exhaust fans in room. Identified in error.	Physical Plant Operations to evaluate for leaks and repair as appropriate and replace ceiling tiles as appropriate.	PPO
150	Temp 79.4	RH 37.3	CO2 697	
	Room is free of smell of kitchen/food?	No odors detected. Central A/C unit migrates food smells.		
152	Temp 78.4	RH 40.1	CO2 685	
	Room is free of the use of scented cleaners and air fresheners?	No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment. Live plants in room. Plant soil is a source of microbial growth. Ceiling tiles broken, damaged or missing.	Site based administration to advise staff to remove live plants. Facilities serviceperson to replace ceiling tiles.	Site Site

**Summary**

**Title I (ECIA) Administration  
TfS IAQ Walkthrough  
4-29-2008**

Temp 71.7 RH 46.1 CO2 598

FISH	Question	Answer	Recommendation	RP
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?	No exhaust fans in room. Identified in error.		
	Other exhaust fans that may exist in the classroom are functioning properly?	No exhaust fans in room. Identified in error.		
	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
	Classroom is free of significant temperature shifts?	Temperature was elevated at the time of assessment.	See previous recommendation.	
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.	See previous recommendation.	
	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..	See previous recommendation.	