

Report: *Walk Through Summary***CROSS CREEK SCHOOL**

Walkthrough Date: 04/25/2006 Temp RH CO2

Outdoor Parameters: 84 60.6 519

Room	Section	Question	Answer	Recommendation	Responsible
101	Inside Parameters:	Temp	RH	CO2	
		72.3	55	717	

EXCESS MOISTURE IN CLASSROOMS Windows, windowsills and window frames free of continuous condensation?

No condensation on windows at the time of assessment.

EXCESS MOISTURE IN CLASSROOMS Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?

Roof leak identified. Carpet is damaged. Interior window is damaged.

Physical Plant Operations to evaluate and repair/replace as appropriate.

PPO

THERMAL COMFORT

Temperature in my classroom is generally comfortable (72F-78F)?

Temperature was acceptable at the time of assessment.

THERMAL COMFORT

Classroom is free of significant temperature shifts?

Temperature was acceptable at the time of assessment.

THERMAL COMFORT

Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)

Humidity was acceptable at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
105	Inside Parameters:	Temp	RH	CO2	
		72.1	55.1	765	

GENERAL CLEANLINESS

Classroom is dusted/vacuumed thoroughly and regularly?

Slight dust accumulation was observed on environmental surfaces at the time of assessment.

Site based administration should address general cleanliness with facility serviceperson staff.

Site

GENERAL CLEANLINESS

Floor is cleaned on a regular basis?

Dust and dirt accumulation on floor.

Facilities serviceperson to thoroughly clean and sanitize.

Site

EXCESS MOISTURE IN CLASSROOMS Windows, windowsills and window frames free of continuous condensation?

No condensation on windows at the time of assessment.

THERMAL COMFORT Temperature in my classroom is generally comfortable (72F-78F)? Temperature was acceptable at the time of assessment.
 THERMAL COMFORT Room is usually comfortable? (If no, please explain in the notes below.) Environmental parameters were within acceptable range at the time of assessment..
 AIR CONDITIONING Room is free of smell of mold or mildew? No microbial growth identified. No odor identified at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
111	Inside Parameters:	Temp	RH	CO2	
		73	53.5	809	

GENERAL CLEANLINESS Floor is cleaned on a regular basis? Carpet was stained, torn, rippled or buckled. Physical Plant Operations to evaluate and repair/replace as appropriate. PPO

Room	Section	Question	Answer	Recommendation	Responsible
120	Inside Parameters:	Temp	RH	CO2	
		72.5	53.5	685	

GENERAL CLEANLINESS Classroom is dusted/vacuumed thoroughly and regularly? There does not appear to be a dusting issue within this room.

GENERAL CLEANLINESS Floor is cleaned on a regular basis? Floor was clean at the time of assessment.

ANIMALS IN THE CLASSROOM Activities and/or room conditions are modified to address student allergies? This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. Site

EXCESS MOISTURE IN CLASSROOMS Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)? No leaks or signs of water intrusion identified.

THERMAL COMFORT Temperature in my classroom is generally comfortable (72F-78F)? Temperature was acceptable at the time of assessment.

THERMAL COMFORT Classroom is free of significant temperature shifts? Temperature was acceptable at the time of assessment.

THERMAL COMFORT Room is usually comfortable? (If no, please explain in the notes below.) Environmental parameters were within acceptable range at the time of assessment..

AIR Room is free of smell of mold or No microbial growth identified. No odor

CONDITIONING mildew? identified at the time of assessment.
 GENERAL Miscellaneous Diffuser needed in main area. Door frame
 CLEANLINESS rusted. Baseboard missing. Physical Plant Operations to evaluate and
 PPO repair/replace as appropriate.

Room	Section	Question	Answer	Recommendation	Responsible
121A	Inside Parameters:	Temp	RH	CO2	
		0	0	0	

GENERAL Miscellaneous Noticeable leaks - East wall. Physical Plant Operations to evaluate and
 CLEANLINESS PPO repair/replace as appropriate.

Room	Section	Question	Answer	Recommendation	Responsible
122A	Inside Parameters:	Temp	RH	CO2	
		0	0	0	

GENERAL Classroom is dusted/vacuumed Storage closet. There does not appear to be a
 CLEANLINESS thoroughly and regularly? dusting issue within this room.
 GENERAL Trash is removed daily and trash bags No issues identified regarding trash removal
 CLEANLINESS are changed as appropriate? practices.
 GENERAL Floor is cleaned on a regular basis? Dust and dirt accumulation on floor. Facilities serviceperson to thoroughly clean and
 CLEANLINESS Site
 DRAIN TRAPS IN Water run in sinks at least once per It appears as though sink is not utilized Site
 THE CLASSROOM week (about 2 cups of water). regularly. Sewer gas odor detected. By running maintenance of sinks toilets and drains with facility
 serviceperson staff.
 THERMAL Temperature in my classroom is Room is a storage closet.
 COMFORT generally comfortable (72F-78F)?
 THERMAL Classroom is free of significant Temperature was acceptable at the time of
 COMFORT temperature shifts? assessment.
 THERMAL Room is usually comfortable? (If no, Environmental parameters were within
 COMFORT please explain in the notes below.) acceptable range at the time of assessment..
 AIR Room is free of smell of mold or No microbial growth identified. No odor
 CONDITIONING mildew? identified at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
127	Inside Parameters:	Temp	RH	CO2	

		78.6	58.8	576	
GENERAL CLEANLINESS	Miscellaneous		Wall damaged around window above main entrance.	Physical Plant Operatoins to evaluate and repair/replace as appropriate.	PPO
GENERAL CLEANLINESS	Miscellaneous		Dust observed on supply/return registers at the time of assessment. Dust impaction on ceiling tiles.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. Remove and replace ceiling tiles with dust impaction.	Site

Room	Section	Question	Answer	Recommendation	Responsible
128D	Inside Parameters:	Temp 0	RH 0	CO2 0	
GENERAL CLEANLINESS	Miscellaneous		Visible microbial growth on musical instruments and cases.	Wipe down instruments and cases.	Site

Room	Section	Question	Answer	Recommendation	Responsible
130	Inside Parameters:	Temp 74.6	RH 51.5	CO2 721	
GENERAL CLEANLINESS	Miscellaneous		A/C diffuser concealed in ceiling. Dust build up on ceiling, vents and fabric walls. Ceiling is at least 25 fee high. Stone front window frame is damaged. Exhaust fans in restrooms not working.	Physical Plant Operations to assist with cleaning of ceiling, vents and walls and evaluate and repair/replace exhaust fans in restrooms.	PPO
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?		Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.	Site

Room	Section	Question	Answer	Recommendation	Responsible
216	Inside Parameters:	Temp 78.6	RH 58.8	CO2 576	
GENERAL CLEANLINESS	Miscellaneous		Carpet throughout 200 building is stained, torn and rippled and temperature in building is elevated.	Physical Plant Operations to remove carpet and replace with tile and evaluate HVAC system for proper operation and repair as appropriate.	PPO

Room	Section	Question	Answer	Recommendation	Responsible
218	Inside Parameters:	Temp	RH	CO2	

		78.6	58.8	576	
GENERAL CLEANLINESS	Miscellaneous		Visible microbial growth on book case and books. Love seat and stuff animals in room. Non-approved chemicals in room.	Remove books and wipe down book case. Remove love seat and stuffed animals. Remove non-approved chemicals.	Site
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		Dust observed on supply/return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site

Room	Section	Question	Answer	Recommendation	Responsible
402	Inside Parameters:	Temp	RH	CO2	
		75.6	53.2	706	
GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?		Excessive dust accumulation was observed on environmental surfaces due to clutter at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	Site
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?		Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.	Site
THERMAL COMFORT	Classroom is free of significant temperature shifts?		Temperature was acceptable at the time of assessment.		
AIR CONDITIONING	Room is free of smell of mold or mildew?		No microbial growth identified. No odor identified at the time of assessment.		

Room	Section	Question	Answer	Recommendation	Responsible
404	Inside Parameters:	Temp	RH	CO2	
		74.2	54.6	752	
GENERAL CLEANLINESS	Classrooms general appearance is clean and acceptable?		General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?		Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		Dust observed on return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
GENERAL	Room is free of pests?		Pests observed at the time of assessment.	Physical Plant Operation to initiate work order to	PPO

CLEANLINESS

evaluate pest issue within location and take appropriate action.

GENERAL CLEANLINESS

Floor is cleaned on a regular basis?

Floor was clean at the time of assessment.

THERMAL COMFORT

Temperature in my classroom is generally comfortable (72F-78F)?

Temperature was acceptable at the time of assessment.

THERMAL COMFORT

Classroom is free of significant temperature shifts?

Temperature was acceptable at the time of assessment.

THERMAL COMFORT

Room is free of the introduction of outdoor air? (Gaps in window/door frames.)

Wall where oven was removed is damaged.

Physical Plant Operations to evaluate and repair/replace as appropriate.

PPO

THERMAL COMFORT

Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)

Humidity was acceptable at the time of assessment.

THERMAL COMFORT

Room is usually comfortable? (If no, please explain in the notes below.)

Environmental parameters were within acceptable range at the time of assessment..

AIR CONDITIONING

Air is flowing without obstruction?

South vent around outlet is damaged.

Physical Plant Operations to evaluate and repair/replace as appropriate.

PPO

AIR CONDITIONING

Room is free of smell of mold or mildew?

Visible microbial growth on surfaces.

Site based custodial staff to wipe down surfaces with approved germicidal cleaner.

Site

LOCAL EXHAUST FANS

Other exhaust fans that may exist in the classroom are functioning properly?

Exhaust fan is functioning properly.

Room	Section	Question	Answer	Recommendation	Responsible
405	Inside Parameters:	Temp	RH	CO2	
		72.8	59.8	741	

GENERAL CLEANLINESS

Classrooms general appearance is clean and acceptable?

Spider web around main entrance.

Site based administration should address general cleanliness with facility serviceperson staff.

Site

GENERAL CLEANLINESS

Classroom is dusted/vacuumed thoroughly and regularly?

There does not appear to be a dusting issue within this room.

GENERAL CLEANLINESS

Floor is cleaned on a regular basis?

Floor was clean at the time of assessment.

ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
GENERAL CLEANLINESS	Miscellaneous	Stuffed animals in room.	Remove stuffed animals from room.	Site
GENERAL CLEANLINESS	Miscellaneous	Air ducts leaking.	Physical Plant Operations to repair leaks around air ducts.	PPO

Room	Section	Question	Answer	Recommendation	Responsible
406	Inside Parameters:	Temp 76.1	RH 53.2	CO2 905	

GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces and spider web by window at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
GENERAL CLEANLINESS	Miscellaneous	Dust build up on diffuser. West wall blistering by cove base.	Physical Plant Operations to clean diffuser and evaluate West wall and repair/replace as appropriate.	PPO

Room	Section	Question	Answer	Recommendation	Responsible
408	Inside Parameters:	Temp 77.6	RH 52.2	CO2 911	

EXCESS MOISTURE IN CLASSROOMS	Miscellaneous	Evidence of roof leak identified. Stained ceiling tiles.	Physical Plant Operations to evaluate for roof leak and repair as appropriate and replace ceiling tiles.	PPO
GENERAL CLEANLINESS	Miscellaneous	Stuffed animals in room and excessive amounts of books and paper.	Remove stuffed animals and encourage occupant to reduce clutter - books and paper.	Site

Room	Section	Question	Answer	Recommendation	Responsible
409	Inside Parameters:	Temp 75.1	RH 54.2	CO2 979	

GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
GENERAL CLEANLINESS	Room is free of pests?	Pests observed at the time of assessment.	Physical Plant Operation to initiate work order to evaluate pest issue within location and take appropriate action.	PPO
GENERAL CLEANLINESS	Room is free of the use of scented cleaners and air fresheners?	No scented cleaners air fresheners or non-approved chemicals found at the time of assessment.		
ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was acceptable at the time of assessment.		
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		
LOCAL EXHAUST FANS	Other exhaust fans that may exist in the classroom are functioning properly?	Exhaust fan is functioning properly.		
EXCESS MOISTURE IN CLASSROOMS	Miscellaneous	Evidence of roof leak - stem wall.	Physical Plant Operations to evaluate for roof leak and repair as appropriate.	PPO

Room	Section	Question	Answer	Recommendation	Responsible
509	Inside Parameters:	Temp	RH	CO2	
		0	0	0	
GENERAL	Miscellaneous		Carpet is stained, torn and rippled in FISH 509-	Physical Plant Operations to remove carpet and	PPO

CLEANLINESS		513.		replace with tile in FISH 509-513.	
Room	Section	Question	Answer	Recommendation	Responsible
510	Inside Parameters:	Temp	RH	CO2	
		0	0	0	
	GENERAL CLEANLINESS	Miscellaneous	Couch and loveseat in room. Excessive items in room - stuffed animals, paper, etc. Food items in room not stored in open containers.	Remove couch and loveseat and stuffed animals from room. Encourage occupant to reduce clutter. Store food items in sealed containers.	Site
	GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
Room	Section	Question	Answer	Recommendation	Responsible
560	Inside Parameters:	Temp	RH	CO2	
		76.4	44.5	629	
	GENERAL CLEANLINESS	Miscellaneous	Visible microbial growth under white board. Roof leak identified on ceiling tile by East closet.	Physical Plant Operations to evaluate cause of microbial growth under white board and repair as appropriate. Evaluate for roof leak and repair as appropriate and replace ceiling tiles as appropriate.	PPO
	GENERAL CLEANLINESS	Miscellaneous	Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	Site
	GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.	Site
Room	Section	Question	Answer	Recommendation	Responsible
602	Inside Parameters:	Temp	RH	CO2	
		76	51.4	731	
	GENERAL CLEANLINESS	Miscellaneous	Several leaks during the hurricane, but none noticed during the assessment.		
Room	Section	Question	Answer	Recommendation	Responsible
605	Inside Parameters:	Temp	RH	CO2	

Room	Section	Question	Answer	Recommendation	Responsible
	72.6		54.7	781	
GENERAL CLEANLINESS		Classrooms general appearance is clean and acceptable?	General cleanliness of the room at the time of assessment was acceptable.		
GENERAL CLEANLINESS		Food, if any, is stored in tightly sealed containers?	No unsealed food items were observed at the time of assessment.		
GENERAL CLEANLINESS		Room is free of pests?	Pests observed at the time of assessment.	Physical Plant Operation to initiate work order to evaluate pest issue within location and take appropriate action.	PPO
GENERAL CLEANLINESS		Room is free of the use of scented cleaners and air fresheners?	Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment. Stuffed animals in room.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room. Advise occupant to remove stuffed animals.	Site
GENERAL CLEANLINESS		Floor is cleaned on a regular basis?	Carpet was stained torn rippled or buckled.	Physical Plant Operations to evaluate and repair/replace as appropriate.	PPO
ANIMALS IN THE CLASSROOM		Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
DRAIN TRAPS IN THE CLASSROOM		Water poured down floor drains once per week (approx. 1 quart of water).	Water is not poured down floor drain at least once a week.	Site based administration should address maintenance of sinks toilets and drains with facility serviceperson staff.	Site
EXCESS MOISTURE IN CLASSROOMS		Windows, windowsills and window frames free of continuous condensation?	No condensation on windows at the time of assessment.		
EXCESS MOISTURE IN CLASSROOMS		Area around and under classroom sinks free of leaks?	Signs of water intrusion. Leak identified. Replace faucet.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	PPO
AIR CONDITIONING		Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		
LOCAL EXHAUST FANS		Other exhaust fans that may exist in the classroom are functioning properly?	Exhaust fan is functioning properly.		
GENERAL CLEANLINESS		Miscellaneous	Chalkboard in room.	Remove chalkboard and replace with whiteboard.	Site

606	Inside Parameters:	Temp 71.3	RH 53.8	CO2 830	
-----	--------------------	--------------	------------	------------	--

EXCESS MOISTURE IN CLASSROOMS	Miscellaneous	No leaks identified. Signs of previous water intrusion as evidenced by staining. Stained ceiling tile above teacher's desk.	Remove and replace stained ceiling tile above teacher's desk.	Site
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply/return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
GENERAL CLEANLINESS	Room is free of the use of scented cleaners and air fresheners?	Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment. Clothing in storage area.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room. Advise occupant to remove clothing from storage area.	Site

Room	Section	Question	Answer	Recommendation	Responsible
608	Inside Parameters:	Temp 71.7	RH 53.1	CO2 830	

GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Chalkboard in room.	Remove chalkboard and replace with whiteboard.	Site
EXCESS MOISTURE IN CLASSROOMS	Miscellaneous	Signs of water intrusion. Window frame and adjacent East wall.	Physical Plant Operations to evaluate and repair/replace as appropriate.	PPO
GENERAL CLEANLINESS	Miscellaneous	Occupants reported rats in room.	Physical Plant Operation to initiate work order to evaluate pest issue within location and take appropriate action.	PPO

Room	Section	Question	Answer	Recommendation	Responsible
609	Inside Parameters:	Temp 71.7	RH 53.1	CO2 830	

GENERAL CLEANLINESS	Miscellaneous	Occupants reported rats in room.	Physical Plant Operation to initiate work order to evaluate pest issue within location and take appropriate action.	PPO
GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Chalkboard in room.	Remove chalkboard and replace with whiteboard.	Site
EXCESS MOISTURE IN CLASSROOMS	Miscellaneous	Signs of water intrusion. Window frame and adjacent East wall.	Physical Plant Operations to evaluate and repair/replace as appropriate.	PPO

Room	Section	Question	Answer	Recommendation	Responsible
706	Inside Parameters:	Temp	RH	CO2	
		75.7	52.2	761	

GENERAL
CLEANLINESS

Classroom is dusted/vacuumed
thoroughly and regularly?

There does not appear to be a dusting issue
within this room.

GENERAL
CLEANLINESS

Floor is cleaned on a regular basis?

Carpet was stained torn rippled or buckled.

Physical Plant Operations to evaluate and
repair/replace as appropriate.

PPO

ANIMALS IN THE
CLASSROOM

Activities and/or room conditions are
modified to address student allergies?

This is a general issue requiring approved
communication among all stakeholders.

Site based administration is encouraged to
communicate all known student allergies to the
appropriate personnel in order to modify classroom
activities/conditions when necessary.

Site

THERMAL
COMFORT

Classroom is free of significant
temperature shifts?

Temperature was acceptable at the time of
assessment.

GENERAL
CLEANLINESS

Air supply/return registers are cleaned
regularly and free of dust and debris
accumulation?

Dust observed on supply/return registers at the
time of assessment.

Facilities serviceperson to thoroughly clean and
sanitize with District approved germicidal cleaner.

Site

GENERAL
CLEANLINESS

Miscellaneous

Pests observed at the time of the assessment.

Physical Plant Operation to initiate work order to
evaluate pest issue within location and take
appropriate action.

PPO

AIR
CONDITIONING

Room is free of smell of mold or
mildew?

No microbial growth identified. No odor
identified at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
707	Inside Parameters:	Temp	RH	CO2	
		77.5	52.9	640	

GENERAL
CLEANLINESS

Classroom is dusted/vacuumed
thoroughly and regularly?

Upholstered furniture in room.

Remove upholstered furniture.

Site

GENERAL
CLEANLINESS

Air supply/return registers are cleaned
regularly and free of dust and debris
accumulation?

No dust observed on supply/return registers at
the time of assessment.

GENERAL
CLEANLINESS

Floor is cleaned on a regular basis?

Carpet was stained torn rippled or buckled.

Physical Plant Operations to evaluate and
repair/replace as appropriate.

PPO

ANIMALS IN THE

Activities and/or room conditions are

This is a general issue requiring approved

Site based administration is encouraged to

Site

CLASSROOM modified to address student allergies? communication among all stakeholders. communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

EXCESS MOISTURE IN CLASSROOMS Windows, windowsills and window frames free of continuous condensation? No condensation on windows at the time of assessment.

EXCESS MOISTURE IN CLASSROOMS Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)? No leaks or signs of water intrusion identified.

THERMAL COMFORT Temperature in my classroom is generally comfortable (72F-78F)? Temperature was acceptable at the time of assessment.

THERMAL COMFORT Classroom is free of significant temperature shifts? Temperature was acceptable at the time of assessment.

THERMAL COMFORT Room is usually comfortable? (If no, please explain in the notes below.) Environmental parameters were within acceptable range at the time of assessment..

AIR CONDITIONING Room is free of smell of mold or mildew? No microbial growth identified. No odor identified at the time of assessment.

LOCAL EXHAUST FANS Other exhaust fans that may exist in the classroom are functioning properly? Exhaust fan is functioning properly.

Room	Section	Question	Answer	Recommendation	Responsible
710	Inside Parameters:	Temp	RH	CO2	
		0	0	0	

GENERAL CLEANLINESS Floor is cleaned on a regular basis? Carpet is stained, torn and rippled in FISH 706-710. Physical Plant Operations to remove carpet and replace with tile in FISH 706-710. PPO

Room	Section	Question	Answer	Recommendation	Responsible
713	Inside Parameters:	Temp	RH	CO2	
		75.3	53.3	607	

GENERAL CLEANLINESS Air supply/return registers are cleaned regularly and free of dust and debris accumulation? Dust observed on supply/return registers at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. Site

EXCESS MOISTURE Miscellaneous Signs of water intrusion. Stained ceiling tile Physical Plant Operations to evaluate and PPO

IN CLASSROOMS

and damaged wall around window.

repair/replace as appropriate.