

Telephone: 754-321-3200

Facsimile: 754-321-3290

January 14, 2009

Signature on File

TO: Mr. Mark Thomas, Principal
McFatter Technical Center

FROM: Edward See, Project Manager
Risk Management Department

SUBJECT: Indoor Air Quality (IAQ) Assessment
FISH 145

<u>For Custodial Supervisor Use Only</u>	
<input type="checkbox"/>	Custodial Issues Addressed
<input type="checkbox"/>	Custodial Issues Not Addressed

On October 17, 2008 I conducted an assessment of FISH 145 at **McFatter Technical Center**. This evaluation included observations of the flooring system, ceiling tiles, false ceiling plenum, environmental surfaces, interior and exterior walls, and the accessible ventilation equipment. Additionally, environmental parameter measurements were taken to include temperature, relative humidity, and carbon dioxide. The detailed findings, along with the recommended corrective action can be found on the attached IAQ Assessment Worksheets.

Generally, the IAQ Assessment did not identify any existing conditions significantly impacting IAQ and thereby presenting immediate health and safety concerns to building occupants. However, due to individual sensitivities and predisposing health factors, it is possible that some building occupants may elicit a health response to agents and / or conditions identified during the evaluation. Therefore, to further improve IAQ, prevent development of future IAQ-related problems, and to reduce the potential for IAQ-related complaints by building occupants, the IAQ Assessment Team recommends appropriate follow up of each item identified and listed in the attached evaluation.

Please ensure that your Head Facilities Serviceperson receives a copy of this correspondence so that the recommendations requiring their attention can be addressed. Within two weeks a representative from the Custodial/Grounds Department will conduct a follow-up visit to ensure that all issues have been appropriately addressed.

Should any questions arise, or if the current concerns continue after the attached recommendations have been addressed, please feel free to contact me at 754-321-3200.

cc: Dr. Leontine Butler, Area Superintendent
Dr. Desmond Blackburn, Area Director
Jeffrey S. Moquin, Executive Director, Support Operations
Greg Boardman, Project Manager, Facilities and Construction Management
Dane Ramson, Broward Teachers Union
Roy Jarrett, Federation of Public Employees
Mark Dorsett, Manager 1, Physical Plant Operations Division, Zone 1
Roy Norton, Manager Custodial/Grounds, Physical Plant Operations Division
Robert Krickovich, Coordinator, LEA, Facilities and Construction Management

ES/tc
Enc.

IAQ Assessment

McFatter Technical Center

Location Number

Evaluation Requested

Time of Day

Evaluation Date

Outdoor Conditions Temperature Relative Humidity Ambient CO2

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
<input type="text" value="145"/>	<input type="text" value="71.3"/>	<input type="text" value="72 - 78"/>	<input type="text" value="53.3"/>	<input type="text" value="30% - 60%"/>	<input type="text" value="584"/>	<input type="text" value="Max 700 > Ambient"/>	<input type="text" value="2"/>
Noticeable Odor		Visible water damage / staining?		Visible microbial growth?		Amount of material affected	
<input type="text" value="No"/>		<input type="text" value="No"/>		<input type="text" value="No"/>		<input type="text" value="None"/>	
Ceiling Type	<input type="text" value="2 x 4"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		
Wall Type	<input type="text" value="Drywall/Plaster"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		
Flooring	<input type="text" value="Carpet"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Walls	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Flooring	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Return Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Ceiling at Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Surfaces in Room	<input type="text" value="No"/>	<input type="text" value="Yes"/>	<input type="text" value="Yes"/>	<input type="text" value="Clean as appropriate"/>

Observations

Findings:

- Chalkboard in use
- 2 set of dry erase markers - 1 low odor and 1 regular
- Dust build up on South wall blinds

Recommendations:

Site Based Maintenance:

- Encourage occupant to replace regular dry erase markers with low odor markers
- Clean South wall blinds thoroughly to remove dust build up
- Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate