

Jeffrey S. Moquin, Director
Risk Management Department

Telephone: 754-321-3200
Facsimile: 754-321-3290

August 12, 2005

Signature on File

TO: Mr. Bonnie Clemon, Principal
Seagull School

FROM: Robert J. Krickovich, Coordinator, LEA
Facilities and Construction Management, Environmental Division

SUBJECT: Indoor Air Quality (IAQ) Assessment
FISH R29F

On August 5, 2005 the IAQ Assessment Team conducted an assessment of FISH R29F at **Seagull School**. The evaluation consisted of a walkthrough of the identified areas to assess the current condition of the location with regard to indoor air quality. This assessment included observations of the carpet, floor tile, ceiling tile, interior walls, false ceiling plenum, and accessible ventilation equipment.

Attached are the findings of this assessment along with recommendations for further assessment, remediation, or corrective actions, if needed.

Generally, the IAQ Assessment did not identify any existing conditions significantly impacting IAQ and thereby presenting immediate health and safety concerns to building occupants. However, due to individual sensitivities and predisposing health factors, it is possible that some building occupants may elicit a health response to agents and / or conditions identified during the evaluation. Therefore, to further improve IAQ, prevent development of future IAQ-related problems, and to reduce the potential for IAQ-related complaints by building occupants, the IAQ Assessment Team recommends appropriate follow up of each item identified and listed in the attached evaluation.

Should any questions arise, or if the current concerns continue after the attached recommendations have been addressed, please feel free to contact me at 754-321-1638.

cc: Dr. Harry LaCava, Area Superintendent
Willie Dudley, Area Director
Jeffrey S. Moquin, Director, Risk Management
Steve Dowling, Project Manager II, Facilities and Construction Management
Jerrod Neal, Broward Teachers Union
Mark Dorsett, Manager 1, Physical Plant Operations Division, Zone 1
Roy Norton, Manager Custodial/Grounds, Physical Plant Operations Division

RK/tc
Enc.

IAQ Assessment

Seagull School

Evaluation Requested

Time of Day

Evaluation Date

Outdoor Conditions Temperature Relative Humidity Ambient CO2

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
<input type="text" value="R29F"/>	<input type="text" value="75.1"/>	<input type="text" value="72 - 78"/>	<input type="text" value="63.4"/>	<input type="text" value="30% - 60%"/>	<input type="text" value="453"/>	<input type="text" value="Max 700 > Ambient"/>	<input type="text" value="2"/>
Noticeable Odor		Visible water damage / staining?		Visible microbial growth?		Amount of material affected	
<input type="text" value="No"/>		<input type="text" value="Yes"/>		<input type="text" value="No"/>		<input type="text" value="6 ceiling tiles"/>	
Ceiling Type	<input type="text" value="2 x 4 Lay In"/>		<input type="text" value="Yes"/>	<input type="text" value="No"/>		<input type="text" value="6 ceiling tiles"/>	
Wall Type	<input type="text" value="Drywall/Wood Panel"/>		<input type="text" value="No"/>	<input type="text" value="No"/>		<input type="text" value="None"/>	
Flooring	<input type="text" value="12 x 12 Vinyl"/>		<input type="text" value="No"/>	<input type="text" value="No"/>		<input type="text" value="None"/>	

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	<input type="text" value="No"/>	<input type="text" value="Yes"/>	<input type="text" value="Yes"/>	<input type="text" value="Replace stained ceiling tiles"/>
Walls	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value=""/>
Flooring	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value=""/>
HVAC Supply Grills	<input type="text" value="No"/>	<input type="text" value="Yes"/>	<input type="text" value="Yes"/>	<input type="text" value="Clean with Wexcide disinfectant"/>
HVAC Return Grills	<input type="text" value="No"/>	<input type="text" value="Yes"/>	<input type="text" value="Yes"/>	<input type="text" value="Clean with Wexcide disinfectant"/>
Ceiling at Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value=""/>
Surfaces in Room	<input type="text" value="No"/>	<input type="text" value="Yes"/>	<input type="text" value="Yes"/>	<input type="text" value="Clean as appropriate"/>

Observations

Findings: (Large area with sitting/reception area in front of 5 small offices with a restroom and storage/sink area in rear)

- 4 stained ceiling tiles in large area
- F6 was the only office unlocked at the time of assessment and had 2 stained ceiling tiles
- All other offices locked
- Dust and debris on environmental surfaces

Recommendations:

Site Based Maintenance:

- Replace stained ceiling tiles
- Clean environmental surfaces as appropriate
- Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate

Physical Plant Operations Division:

- Evaluate roofing and repair as necessary