

Seagull School

0601

IAQ Walkthrough 5/19/2005

Outside Temp RH% CO2

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
101A	Temp <input type="text" value="71.1"/> RH% <input type="text" value="55.6"/> CO2 <input type="text" value="640"/>	Occupants: <input type="text"/>			
	EXCESS MOISTURE IN CLASSROOMS Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Physical Plant Operations	2
	GENERAL CLEANLINESS Room is free of pests?	The "pests" that I referred to in (f) are sweet ants from time to time. Also, I answered all the questions above, however, this is an office as opposed to a classroom.	No pests observed at the time of assessment.	None	
	LOCAL EXHAUST FANS Bathroom exhaust fan is functioning properly?	There are no bathroom or exhaust fans in this office space, ergo I answered "no" for (c) and (d). I answered (a) and (b) with a "Y" as fumes have never been a problem for me in here.	Bathroom exhaust fan is functioning properly.	None	
	Other exhaust fans that may exist in the classroom are functioning properly?	There are no bathroom or exhaust fans in this office space, ergo I answered "no" for (c) and (d). I answered (a) and (b) with a "Y" as fumes have never been a problem for me in here.	Exhaust fan is functioning properly.	None	
101D	Temp <input type="text" value="70.7"/> RH% <input type="text" value="56.8"/> CO2 <input type="text" value="635"/>	Occupants: <input type="text"/>			
	GENERAL CLEANLINESS Classroom is dusted/vacuumed thoroughly and regularly?		Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site Based	2
	Floor is cleaned on a regular basis?		Floor was clean at the time of assessment.	None	2
	THERMAL COMFORT				

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
101D	Temp	<input type="text" value="70.7"/>	RH% <input type="text" value="56.8"/>	CO2 <input type="text" value="635"/>	Occupants: <input type="text"/>		
	Classroom is free of significant temperature shifts?			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Room is usually comfortable? (If no, please explain in the notes below.)			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Temperature in my classroom is generally comfortable (72F-76F)?			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
101F	Temp	<input type="text" value="68.2"/>	RH% <input type="text" value="60.1"/>	CO2 <input type="text" value="648"/>	Occupants: <input type="text"/>		
	LOCAL EXHAUST FANS						
	Bathroom exhaust fan is functioning properly?			No bathroom. Identified in error.	None	None	
101P	Temp	<input type="text" value="70.1"/>	RH% <input type="text" value="59.7"/>	CO2 <input type="text" value="613"/>	Occupants: <input type="text"/>		
	EXCESS MOISTURE IN CLASSROOMS						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?		Extremely old ceiling which needs to be replaced.	Minor staining on ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
	LOCAL EXHAUST FANS						
	Bathroom exhaust fan is functioning properly?		No bathroom in this office.	Bathroom exhaust fan is functioning properly.	None	None	
102B	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
	EXCESS MOISTURE IN CLASSROOMS						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks or signs of water intrusion identified.	None	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
104	Temp	<input type="text" value="72.0"/>	RH% <input type="text" value="53.1"/>	CO2 <input type="text" value="528"/>	Occupants: <input type="text"/>		
ANIMALS IN THE CLASSROOM							
You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Signs of water intrusion. Leak identified. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None	None	
104B	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks or signs of water intrusion identified.	None	None	
105	Temp	<input type="text" value="72.9"/>	RH% <input type="text" value="56.6"/>	CO2 <input type="text" value="565"/>	Occupants: <input type="text"/>		
ANIMALS IN THE CLASSROOM							
You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Classroom ceiling is to be replaced because of the hazard to the babies of tiles falling out.			Physical Plant Operations	2
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None	None	
105A	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks or signs of water intrusion identified.	None	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
105A	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
107	Temp	<input type="text" value="74.4"/>	RH% <input type="text" value="49.9"/>	CO2 <input type="text" value="453"/>	Occupants: <input type="text"/>		
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks or signs of water intrusion identified.	None		
108	Temp	<input type="text" value="69.5"/>	RH% <input type="text" value="63.4"/>	CO2 <input type="text" value="511"/>	Occupants: <input type="text"/>		
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Dust and debris on ceiling tiles.	Facilities serviceperson to replace soiled ceiling tiles.	Site Based	2
109	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
AIR CONDITIONING							
Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None		
ANIMALS IN THE CLASSROOM							
You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks or signs of water intrusion identified.	None		
GENERAL CLEANLINESS							
Room is free of the use of scented cleaners and air fresheners?				No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.	None		
THERMAL COMFORT							
Room is usually comfortable? (If no, please explain in the notes below.)		When air is off, a "moldy" odor surfaces.		Temperature was acceptable at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
110	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?			Temperature was acceptable at the time of assessment.	None		
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)			No gaps in windows or doors identified at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?			Temperature was acceptable at the time of assessment.	None		
114	Temp	<input type="text" value="81.7"/>	RH% <input type="text" value="53.9"/>	CO2 <input type="text" value="677"/>	Occupants: <input type="text"/>		
	AIR CONDITIONING						
	Room is free of smell of kitchen/food?			Kitchen	None		
116	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
	LOCAL EXHAUST FANS						
	Bathroom exhaust fan is functioning properly?			Bathroom exhaust fan is functioning properly.	None		
	THERMAL COMFORT						
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)			No gaps in windows or doors identified at the time of assessment.	None		
119	Temp	<input type="text" value="75.8"/>	RH% <input type="text" value="48.4"/>	CO2 <input type="text" value="573"/>	Occupants: <input type="text"/>		
	LOCAL EXHAUST FANS						
	Bathroom exhaust fan is functioning properly?			No bathroom. Identified in error.	None		
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)			It appears that the ventilation system is adequate based on room activities.	None		
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?			No bathroom. Identified in error.	None		
	Other exhaust fans that may exist in the classroom are functioning properly?			Exhaust fan is functioning properly.	None		
120	Temp	<input type="text" value="75"/>	RH% <input type="text" value="52.5"/>	CO2 <input type="text" value="558"/>	Occupants: <input type="text"/>		
	AIR CONDITIONING						
	Air flowing from air supply?			Air supply/return ventilation is not functioning qualitatively.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
120	Temp	<input type="text" value="75"/>	RH% <input type="text" value="52.5"/>	CO2 <input type="text" value="558"/>	Occupants: <input type="text"/>			
	Air is flowing without obstruction?				Air flowing without obstruction at the time of assessments.	None		
	GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		
120A	Temp	<input type="text" value="75.3"/>	RH% <input type="text" value="57.8"/>	CO2 <input type="text" value="591"/>	Occupants: <input type="text"/>			
	AIR CONDITIONING							
	Air flowing from air supply?				Air flowing without obstruction at the time of assessments.	None		
	Air is flowing without obstruction?				Air flowing without obstruction at the time of assessments.	N		
	Room is free of smell of kitchen/food?				No odor detected at the time of assessment.	None		
	Windows/doors are operable and are kept closed?				Windows and doors are operable and are kept closed.	None		
	THERMAL COMFORT							
	Classroom is free of significant temperature shifts?		It is to cold		Temperature was acceptable at the time of assessment.	None		
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)		It is to cold		No gaps in windows or doors identified at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)		It is to cold		Temperature was acceptable at the time of assessment.	None		
Temperature in my classroom is generally comfortable (72F-76F)?		It is to cold		Temperature was acceptable at the time of assessment.	None			
121	Temp	<input type="text" value="70.3"/>	RH% <input type="text" value="54.1"/>	CO2 <input type="text" value="471"/>	Occupants: <input type="text"/>			
	AIR CONDITIONING							
	Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None		
	ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
121	Temp	<input type="text" value="70.3"/>	RH%	<input type="text" value="54.1"/>	CO2	<input type="text" value="471"/>	Occupants:	<input type="text"/>			
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based					3
	GENERAL CLEANLINESS										
	Room is free of pests?			No pests observed at the time of assessment.	None						
	LOCAL EXHAUST FANS										
	Bathroom exhaust fan is functioning properly?			Bathroom exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations					3
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)			It appears that the ventilation system is adequate based on room activities.	None						
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?			No exhaust system/ventilation in room. Identified in error.	None						
	Other exhaust fans that may exist in the classroom are functioning properly?			No exhaust fans in room. Identified in error.	None						
121A	Temp	<input type="text" value="69.0"/>	RH%	<input type="text" value="55.3"/>	CO2	<input type="text" value="468"/>	Occupants:	<input type="text"/>			
	GENERAL CLEANLINESS										
	Room is free of pests?			ants	No pests observed at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based				3
	LOCAL EXHAUST FANS										
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)			It appears that the ventilation system is adequate based on room activities.	None						
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?			No exhaust system/ventilation in room. Identified in error.	None						
121B	Temp	<input type="text" value="70.1"/>	RH%	<input type="text" value="55.5"/>	CO2	<input type="text" value="482"/>	Occupants:	<input type="text"/>			
	GENERAL CLEANLINESS										
	Room is free of pests?				No pests observed at the time of assessment.	None					
127	Temp	<input type="text" value="69.1"/>	RH%	<input type="text" value="58.5"/>	CO2	<input type="text" value="491"/>	Occupants:	<input type="text"/>			
	LOCAL EXHAUST FANS										
	Bathroom exhaust fan is functioning properly?			this is a mechanical room	No bathroom. Identified in error.	None					

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
127	Temp	69.1	RH% 58.5	CO2 491	Occupants:			
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)	this is a mechanical room			It appears that the ventilation system is adequate based on room activities.	None		
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?	this is a mechanical room			No exhaust system/ventilation in room. Identified in error.			
	Other exhaust fans that may exist in the classroom are functioning properly?	this is a mechanical room			No exhaust system/ventilation in room. Identified in error.	None		
129	Temp	69.3	RH% 57.2	CO2 491	Occupants:			
THERMAL COMFORT								
	Classroom is free of significant temperature shifts?	Teleclass room is sometimes very cold (about 60 degrees).			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Room is usually comfortable? (If no, please explain in the notes below.)	Teleclass room is sometimes very cold (about 60 degrees).			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	3
	Temperature in my classroom is generally comfortable (72F-76F)?	Teleclass room is sometimes very cold (about 60 degrees).			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Physical Plant Operations	2
131	Temp	69.0	RH% 58.5	CO2 486	Occupants:			
THERMAL COMFORT								
	Room is usually comfortable? (If no, please explain in the notes below.)	Room is usually too cold for comfort. Thermostat is not in classroom.			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
131A	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?	This room is a closet.			Storage closet	None	
	Floor is cleaned on a regular basis?	This room is a closet.			Storage closet	None	
	Food, if any, is stored in tightly sealed containers?	This room is a closet.			Storage closet	None	
	Trash is removed daily and trash bags are changed as appropriate?	This room is a closet.			Storage closet	None	
131B	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?	This room is a closet.			Storage closet	None	
	Floor is cleaned on a regular basis?	This room is a closet.			Storage closet	None	
	Trash is removed daily and trash bags are changed as appropriate?	This room is a closet.			Storage closet	None	
131D	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?	Former kiln room unused for any purpose.			Unused room. Former kiln room.	None	
	Trash is removed daily and trash bags are changed as appropriate?	Former kiln room unused for any purpose.			Unused room. Former kiln room.	None	
132	Temp	<input type="text" value="68.8"/>	RH% <input type="text" value="58.4"/>	CO2 <input type="text" value="500"/>	Occupants: <input type="text"/>		
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
DRAIN TRAPS IN THE CLASSROOM							

FISH/Room	Participant Comments				Response	Recommendation	Responsible	Priority			
<i>132</i>	Temp	68.8	RH%	58.4	CO2	500	Occupants:	<input type="text"/>			
	Water poured down floor drains once per week (approx. 1 quart of water).				No floor drain in room.		None				
	LOCAL EXHAUST FANS										
	Bathroom exhaust fan is functioning properly?				Bathroom exhaust fan is functioning properly.		None				
<i>191PL</i>	Temp	73.7	RH%	45.1	CO2	429	Occupants:	<input type="text"/>			
	GENERAL CLEANLINESS										
	Room is free of pests?				This is a portable , and we have some ants in here.	No pests observed at the time of assessment.		None			
<i>198P</i>	Temp	78.3	RH%	48.5	CO2	693	Occupants:	<input type="text"/>			
	GENERAL CLEANLINESS										
	Classroom is dusted/vacuumed thoroughly and regularly?				Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based				2
<i>199P</i>	Temp	77.9	RH%	46.5	CO2	498	Occupants:	<input type="text"/>			
	ANIMALS IN THE CLASSROOM										
	Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based				3
	You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based				3
	GENERAL CLEANLINESS										
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based				2
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.		None				
	Food, if any, is stored in tightly sealed containers?				No food found.		None				
	Room is free of pests?				No pests observed at the time of assessment.		None				

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
199P	Temp	<input type="text" value="77.9"/>	RH% <input type="text" value="46.5"/>	CO2 <input type="text" value="498"/>	Occupants: <input type="text"/>		
LOCAL EXHAUST FANS							
Bathroom exhaust fan is functioning properly?					Bathroom exhaust fan is functioning properly.	None	
THERMAL COMFORT							
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)					No gaps in windows or doors identified at the time of assessment.	None	
200P	Temp	<input type="text" value="73.2"/>	RH% <input type="text" value="48.4"/>	CO2 <input type="text" value="704"/>	Occupants: <input type="text"/>		
AIR CONDITIONING							
Room is free of smell of mold or mildew?					No odor detected at the time of assessment.	None	
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?					Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based 2
LOCAL EXHAUST FANS							
Bathroom exhaust fan is functioning properly?					Bathroom exhaust fan is functioning properly.	None	
THERMAL COMFORT							
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)					Gaps in windows or doors identified at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations 2
203P	Temp	<input type="text" value="78.2"/>	RH% <input type="text" value="41.7"/>	CO2 <input type="text" value="699"/>	Occupants: <input type="text"/>		
ANIMALS IN THE CLASSROOM							
You are informed about the potential allergies of your students?					This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
235C	Temp	<input type="text" value="77.0"/>	RH% <input type="text" value="51.6"/>	CO2 <input type="text" value="529"/>	Occupants: <input type="text"/>		
ANIMALS IN THE CLASSROOM							
You are informed about the potential allergies of your students?			My students are all teenagers and as a safety precaution I always ask a new student if she has any known allergies, esp. food allergies. This is essential to know when dealing with food products.		This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
235C	Temp	<input type="text" value="77.0"/>	RH% <input type="text" value="51.6"/>	CO2 <input type="text" value="529"/>	Occupants: <input type="text"/>		
EXCESS MOISTURE IN CLASSROOMS							
Area around and under classroom sinks free of leaks?		Due to age of kitchens, seals between counter tops and backsplashes are no longer sealed, etting water in. Faucets are loose on top of sink.		Signs of water intrusion. Leak identified. Caulk needed.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		Even with scheduled cleaning, the small sugar ants find their way into the portable and onto every surface possible. This is a constant battle I fight since this is the Foods Lab.		No dust observed on supply/return registers at the time of assessment.	None		
Room is free of pests?		Even with scheduled cleaning, the small sugar ants find their way into the portable and onto every surface possible. This is a constant battle I fight since this is the Foods Lab.		No pests observed at the time of assessment.	None		
344	Temp	<input type="text" value="76.0"/>	RH% <input type="text" value="37.5"/>	CO2 <input type="text" value="418"/>	Occupants: <input type="text"/>		
THERMAL COMFORT							
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)				Temperature was acceptable at the time of assessment.	None		
529C	Temp	<input type="text" value="73"/>	RH% <input type="text" value="41.4"/>	CO2 <input type="text" value="394"/>	Occupants: <input type="text"/>		
THERMAL COMFORT							
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)				Humidity was acceptable at the time of assessment.	None		
922VE	Temp	<input type="text" value="78.7"/>	RH% <input type="text" value="38.3"/>	CO2 <input type="text" value="529"/>	Occupants: <input type="text"/>		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
Classroom is free of animals and pets?				No animals identified at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
922VE	Temp	<input type="text" value="78.7"/>	RH% <input type="text" value="38.3"/>	CO2 <input type="text" value="529"/>	Occupants: <input type="text"/>		
You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
923VE	Temp	<input type="text" value="77.3"/>	RH% <input type="text" value="39.3"/>	CO2 <input type="text" value="613"/>	Occupants: <input type="text"/>		
GENERAL CLEANLINESS							
Room is free of pests?			Room has ants	No pests observed at the time of assessment.	None		
924P	Temp	<input type="text" value="79.0"/>	RH% <input type="text" value="52.4"/>	CO2 <input type="text" value="523"/>	Occupants: <input type="text"/>		
AIR CONDITIONING							
Windows/doors are operable and are kept closed?			Windows cannot be opened and sometimes door is left open for fresh air..It is not a classroom just staff.	Windows and doors are operable and are kept closed.	None		
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks or signs of water intrusion identified.	None		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?			ANTS	No dust observed on supply/return registers at the time of assessment.	None		
Room is free of pests?			ANTS	No pests observed at the time of assessment.	None		
THERMAL COMFORT							
Classroom is free of significant temperature shifts?			Room has wall a/c that can be turned on & off by anyone. One person is hot its on. One person is cold its off. Windows cannot be opened and sometimes door is left open for fresh air	Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)			Room has wall a/c that can be turned on & off by anyone. One person is hot its on. One person is cold its off. Windows cannot be opened and sometimes door is left open for fresh air	Humidity was acceptable at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
924P	Temp	79.0	RH% 52.4	CO2 523	Occupants:		
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	Room has wall a/c that can be turned on & off by anyone. One person is hot its on. One person is cold its off. Windows cannot be opened and sometimes door is left open for fresh air			Gaps in windows or doors identified at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
Room is usually comfortable? (If no, please explain in the notes below.)	Room has wall a/c that can be turned on & off by anyone. One person is hot its on. One person is cold its off. Windows cannot be opened and sometimes door is left open for fresh air			Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
Temperature in my classroom is generally comfortable (72F-76F)?	Room has wall a/c that can be turned on & off by anyone. One person is hot its on. One person is cold its off. Windows cannot be opened and sometimes door is left open for fresh air			Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
958PHC	Temp	73.3	RH% 49.3	CO2 570	Occupants:		
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks or signs of water intrusion identified.	None		
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None		
Classroom is dusted/vacuumed thoroughly and regularly?				General cleanliness of the room at the time of assessment was acceptable.	None		
Room is free of pests?				No pests observed at the time of assessment.	None		
THERMAL COMFORT							
Classroom is free of significant temperature shifts?	portable has room a/c that are turned on and off whenever anyone chooses too.			Temperature was acceptable at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)	portable has room a/c that are turned on and off whenever anyone chooses too.			Temperature was acceptable at the time of assessment.	None		
Temperature in my classroom is generally comfortable (72F-76F)?	portable has room a/c that are turned on and off whenever anyone chooses too.			Temperature was acceptable at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
959PHC	Temp	<input type="text" value="73.6"/>	RH%	<input type="text" value="46.9"/>	CO2	<input type="text" value="574"/>	Occupants:	<input type="text"/>
GENERAL CLEANLINESS								
Classroom is dusted/vacuumed thoroughly and regularly?			ants	General cleanliness of the room at the time of assessment was acceptable.	None			
Room is free of pests?			ants	No pests observed at the time of assessment.	None			
THERMAL COMFORT								
Classroom is free of significant temperature shifts?			Room a/c are turned on and off by individual teachers	Temperature was acceptable at the time of assessment.	None			
Room is usually comfortable? (If no, please explain in the notes below.)			Room a/c are turned on and off by individual teachers	Temperature was acceptable at the time of assessment.	None			
Temperature in my classroom is generally comfortable (72F-76F)?			Room a/c are turned on and off by individual teachers	Temperature was acceptable at the time of assessment.	None			
961VE	Temp	<input type="text" value="76.6"/>	RH%	<input type="text" value="43.2"/>	CO2	<input type="text" value="1080"/>	Occupants:	<input type="text"/>
GENERAL CLEANLINESS								
Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2	
980VE	Temp	<input type="text" value="75.0"/>	RH%	<input type="text" value="44.0"/>	CO2	<input type="text" value="1096"/>	Occupants:	<input type="text"/>
AIR CONDITIONING								
Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None			
ANIMALS IN THE CLASSROOM								
You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
GENERAL CLEANLINESS								
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None			
Classroom is dusted/vacuumed thoroughly and regularly?				General cleanliness of the room at the time of assessment was acceptable.	None			
Room is free of pests?				No pests observed at the time of assessment.	None			
THERMAL COMFORT								

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
980VE	Temp	<input type="text" value="75.0"/>	RH% <input type="text" value="44.0"/>	CO2 <input type="text" value="1096"/>	Occupants: <input type="text"/>		
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)			Gaps in windows or doors identified at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
983P	Temp	<input type="text" value="78.2"/>	RH% <input type="text" value="53.3"/>	CO2 <input type="text" value="690"/>	Occupants: <input type="text"/>		
	ANIMALS IN THE CLASSROOM						
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None		
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None		
R29A	Temp	<input type="text" value="74.8"/>	RH% <input type="text" value="61.3"/>	CO2 <input type="text" value="422"/>	Occupants: <input type="text"/>		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None		
	ANIMALS IN THE CLASSROOM						
	Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	EXCESS MOISTURE IN CLASSROOMS						
	Indoor surfaces of exterior walls free of continuous condensation?			No condensation the time of assessment.	None		
	Windows, windowsills and window frames free of continuous condensation?			No condensation on windows at the time of assessment.	None		
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Some of the above answers are neither 100% Yes nor 100% No.	Dust observed on supply/return registers at the time of assessment.	None	
	Classroom is dusted/vacuumed thoroughly and regularly?			Some of the above answers are neither 100% Yes nor 100% No.	General cleanliness of the room at the time of assessment was acceptable.	None	
	Classrooms general appearance is clean and acceptable?			Some of the above answers are neither 100% Yes nor 100% No.	General cleanliness of the room at the time of assessment was acceptable.	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
R29A	Temp	<input type="text" value="74.8"/>	RH%	<input type="text" value="61.3"/>	CO2	<input type="text" value="422"/>	Occupants:	<input type="text"/>
Floor is cleaned on a regular basis?	Some of the above answers are neither 100% Yes nor 100% No.			Floor was clean at the time of assessment.	None			
Room is free of pests?	Some of the above answers are neither 100% Yes nor 100% No.			No pests observed at the time of assessment.	None			
LOCAL EXHAUST FANS								
Bathroom exhaust fan is functioning properly?				Bathroom exhaust fan is functioning properly.	None			
Other exhaust fans that may exist in the classroom are functioning properly?				Exhaust fan is functioning properly.	None			
THERMAL COMFORT								
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	Room is freezing at the beginning of everyday, particularly when the temperature drops. It is often takes the entire day to warm up the room.			No gaps in windows or doors identified at the time of assessment.	None			
R29F	Temp	<input type="text" value="75.6"/>	RH%	<input type="text" value="59.2"/>	CO2	<input type="text" value="422"/>	Occupants:	<input type="text"/>
AIR CONDITIONING								
Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None			
EXCESS MOISTURE IN CLASSROOMS								
Windows, windowsills and window frames free of continuous condensation?				No condensation on windows at the time of assessment.	None			
Walkthrough				Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations		1