

**SHERIDAN TECHNICAL CENTER**

Walkthrough Date: 05/30/2007 Temp RH CO2

Outdoor Parameters: 80.7 64.9 530

Room	Section	Question	Answer	Recommendation	Responsible
102	Inside Parameters:	Temp 69.9	RH 48.7	CO2 719	
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
	DRAIN TRAPS IN THE CLASSROOM	Water run in sinks at least once per week (about 2 cups of water).	It appears as though sink is not utilized regularly. Sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	Site based administration should address maintenance of sinks toilets and drains with facility serviceperson staff.	Site
	EXCESS MOISTURE IN CLASSROOMS	Area around and under classroom sinks free of leaks?	No leaks or signs of water intrusion identified.		
	EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks or signs of water intrusion identified.		
	THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
	THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..		
	LOCAL EXHAUST FANS	Other exhaust fans that may exist in the classroom are functioning properly?	No exhaust fans in room. Identified in error.		
Room	Section	Question	Answer	Recommendation	Responsible
103	Inside Parameters:	Temp 69.9	RH 51.6	CO2 905	

GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
DRAIN TRAPS IN THE CLASSROOM	Water run in sinks at least once per week (about 2 cups of water).	It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was low at the time of assessment.	
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..	

Room	Section	Question	Answer	Recommendation	Responsible
110	Inside Parameters:	Temp 71.4	RH 54.9	CO2 632	

GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time	Site based administration should address Site general cleanliness with facility
---------------------	--	---	---

GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	of assessment. Dust observed on supply and return registers at the time of assessment.	serviceperson staff. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..		
GENERAL CLEANLINESS	Classrooms general appearance is clean and acceptable?	General cleanliness of the room at the time of assessment was acceptable.		
GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.		
ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in	Site

ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	order to modify classroom activities/conditions when necessary. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks or signs of water intrusion identified.		
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..		
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		
LOCAL EXHAUST FANS	Bathroom exhaust fan is functioning properly?	No bathroom. Identified in error.		
AIR CONDITIONING	Room is free of smell of vehicle exhaust?	No odor detected at the time of assessment.		
AIR CONDITIONING	Room is free of smell of kitchen/food?	No odor detected at the time of assessment.		
AIR CONDITIONING	Room is free of smell of chemicals?	No odor detected at the time of assessment.		
LOCAL EXHAUST FANS	My classroom has sufficient exhaust systems based on the activities/functionality of the room?	It appears that the ventilation system is adequate based on room activities.		
LOCAL EXHAUST FANS	Bathroom exhaust fan is functioning properly?	No bathroom. Identified in error.		

Room	Section	Question	Answer	Recommendation	Responsible
111	Inside Parameters:	Temp 74.4	RH 50.7	CO2 1075	
	GENERAL CLEANLINESS	Classrooms general appearance is clean and acceptable?	General cleanliness of the room at the time of assessment was acceptable.		
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
	GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
	GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.		
	ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	EXCESS MOISTURE IN CLASSROOMS	Windows, windowsills and window frames free of continuous condensation?	No condensation on windows at the time of assessment.		
	EXCESS MOISTURE IN CLASSROOMS	Cold water pipes free of continuous condensation?	No condensation on pipes at the time of assessment.		
	EXCESS MOISTURE IN CLASSROOMS	Indoor surfaces of exterior walls free of continuous condensation?	No visible condensation or signs of water intrusion identified at the time of assessment.		
	EXCESS MOISTURE IN CLASSROOMS	Area around and under classroom sinks free of leaks?	No leaks or signs of water intrusion identified.		
	EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	Dust and debris on ceiling tiles.	Facilities serviceperson to replace ceiling tiles.	Site
	THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was acceptable at the time of assessment.		
	THERMAL	Classroom is free of significant	Temperature was acceptable at the time		

COMFORT	temperature shifts?	of assessment.
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..
AIR CONDITIONING	Room is free of smell of vehicle exhaust?	No odor detected at the time of assessment.
AIR CONDITIONING	Room is free of smell of chemicals?	No odor detected at the time of assessment.
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.
LOCAL EXHAUST FANS	My classroom has sufficient exhaust systems based on the activities/functionality of the room?	It appears that the ventilation system is adequate based on room activities.
LOCAL EXHAUST FANS	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)	It appears that the ventilation system is adequate based on room activities.
LOCAL EXHAUST FANS	Other exhaust fans that may exist in the classroom are functioning properly?	No exhaust fans in room. Identified in error.
ART SUPPLIES	Exposure minimized for industrial supplies?	No industrial supplies in room. Room not being used as an industrial room.

Room	Section	Question	Answer	Recommendation	Responsible
113	Inside Parameters:	Temp 65.8	RH 64.2	CO2 610	

GENERAL CLEANLINESS	Classrooms general appearance is clean and acceptable?	General cleanliness of the room at the time of assessment was acceptable.	
GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address Site general cleanliness with facility serviceperson staff.
GENERAL	Air supply/return registers are	Dust observed on supply and return	Facilities serviceperson to thoroughly Site

CLEANLINESS	cleaned regularly and free of dust and debris accumulation?	registers at the time of assessment.	clean and sanitize with District approved germicidal cleaner.	
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.		
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
EXCESS MOISTURE IN CLASSROOMS	Cold water pipes free of continuous condensation?	No condensation on pipes at the time of assessment.		
EXCESS MOISTURE IN CLASSROOMS	Indoor surfaces of exterior walls free of continuous condensation?	No visible condensation or signs of water intrusion identified at the time of assessment.		
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was low at the time of assessment.		
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	PPO
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate and repair as appropriate.	PPO
AIR CONDITIONING	Air flowing from air supply?	Air supply/return ventilation is functioning.		
AIR CONDITIONING	Air is flowing without obstruction?	Air flowing without obstruction at the time of assessments.		
AIR CONDITIONING	Room is free of smell of vehicle exhaust?	No odor detected at the time of assessment.		
AIR	Room is free of smell of	No odor detected at the time of		

CONDITIONING	chemicals?	assessment.		
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		
LOCAL EXHAUST FANS	My classroom has sufficient exhaust systems based on the activities/functionality of the room?	No exhaust system/ventilation in room. Identified in error.		
LOCAL EXHAUST FANS	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)	It appears that the ventilation system is adequate based on room activities.		
LOCAL EXHAUST FANS	Other exhaust fans that may exist in the classroom are functioning properly?	No exhaust fans in room. Identified in error.		
ART SUPPLIES	Science supplies okay?	Science supplies in room.	Curriculum supervisor meet with appropriate staff to address issues of concern and ensure that all supplies are approved for use and handled/stored in a manner consistent with District procedures.	Site
ART SUPPLIES	Following good handling and storage practices for science supplies?	Science supplies in room.	Curriculum supervisor meet with appropriate staff to address issues of concern and ensure that all supplies are approved for use and handled/stored in a manner consistent with District procedures.	Site
ART SUPPLIES	Exposure minimized for science supplies?	Science supplies in room.	Curriculum supervisor meet with appropriate staff to address issues of concern and ensure that all supplies are approved for use and handled/stored in a manner consistent with District procedures.	Site

Room	Section	Question	Answer	Recommendation	Responsible
120	Inside Parameters:	Temp 69.8	RH 54.4	CO2 881	
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site



GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.	Site
EXCESS MOISTURE IN CLASSROOMS	Indoor surfaces of exterior walls free of continuous condensation?	No visible condensation or signs of water intrusion identified at the time of assessment.		
EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks or signs of water intrusion identified.		

Room	Section	Question	Answer	Recommendation	Responsible
122	Inside Parameters:	Temp 70.6	RH 54.6	CO2 865	

GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
GENERAL CLEANLINESS	Room is free of the use of scented cleaners and air fresheners?	No scented cleaners air fresheners or non-approved chemicals found at the time of assessment.		
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.	Site
ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
EXCESS MOISTURE IN CLASSROOMS	Windows, windowsills and window frames free of continuous condensation?	No condensation on windows at the time of assessment.		
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
THERMAL	Room is free of the introduction	No gaps in windows or doors identified		

COMFORT	of outdoor air? (Gaps in window/door frames.)	at the time of assessment.		
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.		
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate and repair as appropriate.	PPO
AIR CONDITIONING	Room is free of smell of chemicals?	No odor detected at the time of assessment.		
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		
LOCAL EXHAUST FANS	My classroom has sufficient exhaust systems based on the activities/functionality of the room?	It appears that the ventilation system is adequate based on room activities.		
LOCAL EXHAUST FANS	Other exhaust fans that may exist in the classroom are functioning properly?	No exhaust fans in room. Identified in error.		

Room	Section	Question	Answer	Recommendation	Responsible
124	Inside Parameters:	Temp 71.3	RH 52.0	CO2 904	
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
	THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
	THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
	THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the	Environmental parameters were not within acceptable range at the time of		

notes below.)

assessment..

Room	Section	Question	Answer	Recommendation	Responsible
131	Inside Parameters:	Temp 72.2	RH 49.9	CO2 823	
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site

Room	Section	Question	Answer	Recommendation	Responsible
132A	Inside Parameters:	Temp 71.4	RH 52.9	CO2 841	
	ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		

Room	Section	Question	Answer	Recommendation	Responsible
133	Inside Parameters:	Temp 72.1	RH 48.5	CO2 825	
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
	GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
	GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.	Site
	ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in	Site

order to modify classroom activities/conditions when necessary.

**EXCESS MOISTURE IN CLASSROOMS** Windows, windowsills and window frames free of continuous condensation? No condensation on windows at the time of assessment.

**EXCESS MOISTURE IN CLASSROOMS** Classroom lavatories/water fountains free of leaks? No lavatories/water fountains in room.

**THERMAL COMFORT** Temperature in my classroom is generally comfortable (72F-76F)? Temperature was acceptable at the time of assessment.

**THERMAL COMFORT** Classroom is free of significant temperature shifts? Temperature was acceptable at the time of assessment.

**THERMAL COMFORT** Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.) Humidity was acceptable at the time of assessment.

**THERMAL COMFORT** Room is usually comfortable? (If no, please explain in the notes below.) Environmental parameters were within acceptable range at the time of assessment..

**LOCAL EXHAUST FANS** Bathroom exhaust fan is functioning properly? No bathroom. Identified in error.

Room	Section	Question	Answer	Recommendation	Responsible
134A	Inside Parameters:	Temp 73.7	RH 47.3	CO2 813	

**ANIMALS IN THE CLASSROOM** You are informed about the potential allergies of your students? This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Section	Question	Answer	Recommendation	Responsible
137	Inside Parameters:	Temp 70.3	RH 52.8	CO2 788	

**EXCESS MOISTURE IN CLASSROOMS** Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)? No leaks or signs of water intrusion identified.

THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.		
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..		
LOCAL EXHAUST FANS	Bathroom exhaust fan is functioning properly?	No bathroom. Identified in error.		

Room	Section	Question	Answer	Recommendation	Responsible
139A	Inside Parameters:	Temp 72.0	RH 56.9	CO2 678	

GENERAL CLEANLINESS Room is free of pests? No pests observed at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
204	Inside Parameters:	Temp 71.7	RH 54.0	CO2 686	

GENERAL CLEANLINESS Classrooms general appearance is clean and acceptable? General cleanliness of the room at the time of assessment was acceptable.

GENERAL CLEANLINESS Classroom is dusted/vacuumed thoroughly and regularly? Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff. Site

GENERAL Air supply/return registers are Dust observed on supply and return Facilities serviceperson to thoroughly Site

CLEANLINESS	cleaned regularly and free of dust and debris accumulation?	registers at the time of assessment.	clean and sanitize with District approved germicidal cleaner.
GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.	
GENERAL CLEANLINESS	Room is free of the use of scented cleaners and air fresheners?	No scented cleaners air fresheners or non-approved chemicals found at the time of assessment.	
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.	
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged Site to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
EXCESS MOISTURE IN CLASSROOMS	Windows, windowsills and window frames free of continuous condensation?	No condensation on windows at the time of assessment.	
EXCESS MOISTURE IN CLASSROOMS	Cold water pipes free of continuous condensation?	No condensation on pipes at the time of assessment.	
EXCESS MOISTURE IN CLASSROOMS	Area around and under classroom sinks free of leaks?	No leaks or signs of water intrusion identified.	
EXCESS MOISTURE IN CLASSROOMS	Classroom lavatories/water fountains free of leaks?	No leaks or signs of water intrusion identified.	
EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks or signs of water intrusion identified.	
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was low at the time of assessment.	Site based administration to encourage Site facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.	
THERMAL	Humidity is generally	Humidity was acceptable at the time of	

COMFORT acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.) assessment.

THERMAL COMFORT Room is usually comfortable? (If no, please explain in the notes below.) Environmental parameters were not within acceptable range at the time of assessment..

AIR CONDITIONING Room is free of smell of chemicals? Temperature was low at the time of assessment.

AIR CONDITIONING Room is free of smell of mold or mildew? No microbial growth identified. No odor identified at the time of assessment.

LOCAL EXHAUST FANS My classroom has sufficient exhaust systems based on the activities/functionality of the room? It appears that the ventilation system is adequate based on room activities.

LOCAL EXHAUST FANS Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section) It appears that the ventilation system is adequate based on room activities.

LOCAL EXHAUST FANS Other exhaust fans that may exist in the classroom are functioning properly? Exhaust fan is functioning properly.

Room	Section	Question	Answer	Recommendation	Responsible
204B	Inside Parameters:	Temp	RH	CO2	
		71.7	53.2	743	

GENERAL CLEANLINESS Room is free of pests? No pests observed at the time of assessment.

ANIMALS IN THE CLASSROOM You are informed about the potential allergies of your students? This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. Site

ANIMALS IN THE CLASSROOM Activities and/or room conditions are modified to address student allergies? This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. Site

THERMAL Temperature in my classroom is Temperature was low at the time of Site based administration to encourage Site

COMFORT	generally comfortable (72F-76F)?	assessment.	facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.	
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.	
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..	
AIR CONDITIONING	Room is free of smell of chemicals?	No odor detected at the time of assessment.	
LOCAL EXHAUST FANS	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)	No exhaust system/ventilation in room. Identified in error.	

Room	Section	Question	Answer	Recommendation	Responsible
208	Inside Parameters:	Temp 71.7	RH 55.3	CO2 776	
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
	GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
	GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
	GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.	Site
	EXCESS MOISTURE IN CLASSROOMS	Windows, windowsills and window frames free of continuous condensation?	No windows in room.		



EXCESS MOISTURE IN CLASSROOMS	Indoor surfaces of exterior walls free of continuous condensation?	No visible condensation or signs of water intrusion identified at the time of assessment.		
EXCESS MOISTURE IN CLASSROOMS	Area around and under classroom sinks free of leaks?	No leaks or signs of water intrusion identified.		
EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	Signs of water intrusion. Stained ceiling tiles.		Physical Plant Operations to evaluate for PPO leaks and repair as appropriate and replace ceiling tiles as appropriate.
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was low at the time of assessment.		Site based administration to encourage Site facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.		
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..		
AIR CONDITIONING	Room is free of smell of chemicals?	No odor detected at the time of assessment.		

Room	Section	Question	Answer	Recommendation	Responsible
210	Inside Parameters:	Temp 69.5	RH 57.8	CO2 727	

GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.		Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
---------------------	---	---	--	--	------

Room	Section	Question	Answer	Recommendation	Responsible
211	Inside Parameters:	Temp 73.3	RH 46.3	CO2 779	

GENERAL CLEANLINESS	Classrooms general appearance is clean and acceptable?	General cleanliness of the room at the time of assessment was acceptable.	
ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
EXCESS MOISTURE IN CLASSROOMS	Windows, windowsills and window frames free of continuous condensation?	No condensation on windows at the time of assessment.	
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was acceptable at the time of assessment.	
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.	
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..	
AIR CONDITIONING	Room is free of smell of chemicals?	No odor detected at the time of assessment.	
LOCAL EXHAUST FANS	My classroom has sufficient exhaust systems based on the activities/functionality of the room?	It appears that the ventilation system is adequate based on room activities.	
LOCAL EXHAUST FANS	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)	It appears that the ventilation system is adequate based on room activities.	
LOCAL EXHAUST FANS	Bathroom exhaust fan is functioning properly?	No bathroom. Identified in error.	
LOCAL EXHAUST FANS	Other exhaust fans that may exist in the classroom are functioning properly?	Exhaust fan is functioning properly.	
LOCKER ROOM	Locker room and showers cleaned regularly and properly?	Issues not applicable. Room is not a locker room.	

Room	Section	Question	Answer	Recommendation	Responsible
212	Inside Parameters:	Temp 74.0	RH 51.4	CO2 861	
	GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
	ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was acceptable at the time of assessment.		
	THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
	THERMAL COMFORT	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	No gaps in windows or doors identified at the time of assessment.		
	THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..		
	AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		
	LOCAL EXHAUST FANS	Bathroom exhaust fan is functioning properly?	No bathroom. Identified in error.		
	LOCAL EXHAUST FANS	Other exhaust fans that may exist in the classroom are functioning properly?	No exhaust fans in room. Identified in error.		
Room	Section	Question	Answer	Recommendation	Responsible
213	Inside Parameters:	Temp 70.5	RH 52.3	CO2 758	

GENERAL CLEANLINESS	Classrooms general appearance is clean and acceptable?	General cleanliness of the room at the time of assessment was acceptable.		
GENERAL CLEANLINESS	Trash is removed daily and trash bags are changed as appropriate?	No issues identified regarding trash removal practices.		
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
LOCAL EXHAUST FANS	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)	It appears that the ventilation system is adequate based on room activities.		
LOCAL EXHAUST FANS	Bathroom exhaust fan is functioning properly?	No bathroom. Identified in error.		
LOCKER ROOM	Soiled clothes and towels are removed regularly?	Appears that clothes and towels are removed regularly.		
GENERAL CLEANLINESS	Classrooms general appearance is clean and acceptable?	General cleanliness of the room at the time of assessment was acceptable.		
GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
GENERAL CLEANLINESS	Trash is removed daily and trash bags are changed as	No issues identified regarding trash removal practices.		

	appropriate?			
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
GENERAL CLEANLINESS	Room is free of the use of scented cleaners and air fresheners?	No scented cleaners air fresheners or non-approved chemicals found at the time of assessment.		
GENERAL CLEANLINESS	Spills and other such issues requiring custodial assistance are addressed in a timely manner?	No issues identified relating to spill clean up practices at the time of assessment..		
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.	Site
ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
EXCESS MOISTURE IN CLASSROOMS	Windows, windowsills and window frames free of continuous condensation?	No condensation on windows at the time of assessment.		
EXCESS MOISTURE IN CLASSROOMS	Cold water pipes free of continuous condensation?	No pipes in room.		
EXCESS MOISTURE IN CLASSROOMS	Indoor surfaces of exterior walls free of continuous condensation?	No visible condensation or signs of water intrusion identified at the time of assessment.		
EXCESS MOISTURE IN CLASSROOMS	Area around and under classroom sinks free of leaks?	No sinks in room.		
EXCESS MOISTURE IN CLASSROOMS	Classroom lavatories/water fountains free of leaks?	No lavatories/water fountains in room.		

EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	Dust and debris on ceiling tiles.	Facilities serviceperson to replace ceiling tiles.	Site
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was low at the time of assessment.		
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
THERMAL COMFORT	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	No gaps in windows or doors identified at the time of assessment.		
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.		
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..		
AIR CONDITIONING	Air flowing from air supply?	Air supply/return ventilation is functioning.		
AIR CONDITIONING	Room is free of smell of kitchen/food?	No odor detected at the time of assessment.		
AIR CONDITIONING	Room is free of smell of chemicals?	No odor detected at the time of assessment.		
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		
LOCAL EXHAUST FANS	My classroom has sufficient exhaust systems based on the activities/functionality of the room?	It appears that the ventilation system is adequate based on room activities.		
LOCAL EXHAUST FANS	Indoor classroom activities do not cause problems with	It appears that the ventilation system is adequate based on room activities.		

excessive fumes? (If no, please explain in notes section)

LOCAL EXHAUST FANS Other exhaust fans that may exist in the classroom are functioning properly? Exhaust fan is functioning properly.

ART SUPPLIES Industrial supplies okay? Industrial supplies in room. Curriculum supervisor meet with appropriate staff to address issues of concern and ensure that all supplies are approved for use and handled/stored in a manner consistent with District procedures. Site

ART SUPPLIES Following good handling and storage practices for industrial supplies? Industrial supplies in room. Curriculum supervisor meet with appropriate staff to address issues of concern and ensure that all supplies are approved for use and handled/stored in a manner consistent with District procedures. Site

ART SUPPLIES Exposure minimized for industrial supplies? Industrial supplies in room. Curriculum supervisor meet with appropriate staff to address issues of concern and ensure that all supplies are approved for use and handled/stored in a manner consistent with District procedures. Site

LOCKER ROOM Soiled clothes and towels are removed regularly? Appears that clothes and towels are removed regularly.

Room	Section	Question	Answer	Recommendation	Responsible
220	Inside Parameters:	Temp 70.1	RH 52.9	CO2 682	

LOCAL EXHAUST FANS Other exhaust fans that may exist in the classroom are functioning properly? No exhaust fans in room. Identified in error.

Room	Section	Question	Answer	Recommendation	Responsible
308	Inside Parameters:	Temp 71.1	RH 49.4	CO2 749	

GENERAL CLEANLINESS Classroom is dusted/vacuumed thoroughly and regularly? Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff. Site

GENERAL Air supply/return registers are Dust observed on supply and return Facilities serviceperson to thoroughly Site

CLEANLINESS cleaned regularly and free of dust and debris accumulation? registers at the time of assessment. clean and sanitize with District approved germicidal cleaner.

DRAIN TRAPS IN THE CLASSROOM Water poured down floor drains once per week (approx. 1 quart of water). No floor drain in room.

THERMAL COMFORT Temperature in my classroom is generally comfortable (72F-76F)? Temperature was low at the time of assessment. Site based administration to encourage Site facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

THERMAL COMFORT Room is usually comfortable? (If no, please explain in the notes below.) Environmental parameters were not within acceptable range at the time of assessment..

Room	Section	Question	Answer	Recommendation	Responsible
401	Inside Parameters:	Temp 74.4	RH 49.1	CO2 546	

GENERAL CLEANLINESS Air supply/return registers are cleaned regularly and free of dust and debris accumulation? Dust observed on supply and return registers at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. Site

Room	Section	Question	Answer	Recommendation	Responsible
403	Inside Parameters:	Temp 72.3	RH 54.4	CO2 531	

THERMAL COMFORT Temperature in my classroom is generally comfortable (72F-76F)? Temperature was acceptable at the time of assessment.

THERMAL COMFORT Room is usually comfortable? (If no, please explain in the notes below.) Environmental parameters were within acceptable range at the time of assessment..

Room	Section	Question	Answer	Recommendation	Responsible
406	Inside Parameters:	Temp 72.4	RH 58.7	CO2 538	

GENERAL CLEANLINESS Classrooms general appearance is clean and acceptable? General cleanliness of the room at the time of assessment was acceptable.

GENERAL Classroom is dusted/vacuumed There does not appear to be a dusting



CLEANLINESS GENERAL CLEANLINESS	thoroughly and regularly? Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	issue within this room. No dust observed on supply/return registers at the time of assessment.		
GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks or signs of water intrusion identified.		
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..		
AIR CONDITIONING	Room is free of smell of kitchen/food?	No odor detected at the time of assessment.		
LOCAL EXHAUST FANS	Bathroom exhaust fan is functioning properly?	Bathroom exhaust fan is functioning properly.		
LOCAL EXHAUST FANS	Other exhaust fans that may exist in the classroom are functioning properly?	Exhaust fan is functioning properly.		

Room	Section	Question	Answer	Recommendation	Responsible
422	Inside Parameters:	Temp	RH	CO2	
		72.1	56.1	537	

THERMAL COMFORT Temperature in my classroom is generally comfortable (72F-76F)? Temperature was acceptable at the time of assessment.

THERMAL COMFORT Room is usually comfortable? (If no, please explain in the notes below.) Environmental parameters were within acceptable range at the time of assessment..

Room	Section	Question	Answer	Recommendation	Responsible
431	Inside Parameters:	Temp 73.5	RH 53.2	CO2 743	

THERMAL COMFORT Temperature in my classroom is generally comfortable (72F-76F)? Temperature was acceptable at the time of assessment.

THERMAL COMFORT Classroom is free of significant temperature shifts? Temperature was acceptable at the time of assessment.

THERMAL COMFORT Room is free of the introduction of outdoor air? (Gaps in window/door frames.) No gaps in windows or doors identified at the time of assessment.

GENERAL CLEANLINESS Room is free of pests? No pests observed at the time of assessment.

THERMAL COMFORT Temperature in my classroom is generally comfortable (72F-76F)? Temperature was acceptable at the time of assessment.

THERMAL COMFORT Classroom is free of significant temperature shifts? Temperature was acceptable at the time of assessment.

THERMAL COMFORT Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.) Humidity was acceptable at the time of assessment.

THERMAL COMFORT Temperature in my classroom is generally comfortable (72F-76F)? Temperature was acceptable at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
431A	Inside Parameters:	Temp 73.5	RH 54.1	CO2 717	

GENERAL CLEANLINESS Classroom is dusted/vacuumed thoroughly and regularly? Slight dust accumulation was observed on environmental surfaces at the time Site based administration should address Site general cleanliness with facility

GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	of assessment. Dust observed on supply and return registers at the time of assessment.	serviceperson staff. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.		
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..		

Room	Section	Question	Answer	Recommendation	Responsible
431B	Inside Parameters:	Temp 72.5	RH 57.2	CO2 738	

GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	No dust observed on supply/return registers at the time of assessment.		
GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room.		
EXCESS MOISTURE IN CLASSROOMS	Indoor surfaces of exterior walls free of continuous condensation?	Condensation on walls or surfaces at the time of assessment. No leak identified.	Physical Plant Operations to evaluate and repair as appropriate.	PPO
THERMAL COMFORT	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	No gaps in windows or doors identified at the time of assessment.		
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.		
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		

Room	Section	Question	Answer	Recommendation	Responsible
431C	Inside Parameters:	Temp 73.7	RH 54	CO2 752	
	GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
	EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for PPO leaks and repair as appropriate and replace ceiling tiles as appropriate.	

Room	Section	Question	Answer	Recommendation	Responsible
434	Inside Parameters:	Temp 75.2	RH 51	CO2 634	
	GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
	GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
	ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was acceptable at the time of assessment.		
	THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		

Room	Section	Question	Answer	Recommendation	Responsible
435	Inside Parameters:	Temp 72.6	RH 53.4	CO2 587	
	GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	No dust observed on supply/return registers at the time of assessment.		
	EXCESS MOISTURE IN	Windows, windowsills and window frames free of	No condensation on windows at the time of assessment.		

CLASSROOMS	continuous condensation?	
EXCESS MOISTURE IN CLASSROOMS	Indoor surfaces of exterior walls free of continuous condensation?	No visible condensation or signs of water intrusion identified at the time of assessment.
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was acceptable at the time of assessment.
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..
AIR CONDITIONING	Air flowing from air supply?	Air supply/return ventilation is functioning.
AIR CONDITIONING	Air is flowing without obstruction?	Air flowing without obstruction at the time of assessments.
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
439	Inside Parameters:	Temp 73.4	RH 56.6	CO2 540	

ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		

Room	Section	Question	Answer	Recommendation	Responsible
440	Inside Parameters:	Temp	RH	CO2	

	67	71.2	429	
GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.		
ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
EXCESS MOISTURE IN CLASSROOMS	Windows, windowsills and window frames free of continuous condensation?	No condensation on windows at the time of assessment.		
EXCESS MOISTURE IN CLASSROOMS	Cold water pipes free of continuous condensation?	No condensation on pipes at the time of assessment.		
EXCESS MOISTURE IN CLASSROOMS	Indoor surfaces of exterior walls free of continuous condensation?	No visible condensation or signs of water intrusion identified at the time of assessment.		
EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks or signs of water intrusion identified.		
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was low at the time of assessment.		
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the	Site

thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

THERMAL COMFORT

Room is free of the introduction of outdoor air? (Gaps in window/door frames.)

No gaps in windows or doors identified at the time of assessment.

THERMAL COMFORT

Room is usually comfortable? (If no, please explain in the notes below.)

Environmental parameters were not within acceptable range at the time of assessment..

Physical Plant Operations to evaluate and repair as appropriate.

PPO

AIR CONDITIONING

Room is free of smell of mold or mildew?

Odor detected and no microbial growth identified.

Physical Plant operations to evaluate cause odor.

PPO

Room	Section	Question	Answer	Recommendation	Responsible
445	Inside Parameters:	Temp 72.1	RH 61.2	CO2 472	

ANIMALS IN THE CLASSROOM

You are informed about the potential allergies of your students?

This is a general issue requiring approved communication among all stakeholders.

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site

ANIMALS IN THE CLASSROOM

Activities and/or room conditions are modified to address student allergies?

This is a general issue requiring approved communication among all stakeholders.

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site

EXCESS MOISTURE IN CLASSROOMS

Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?

No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.

Facilities serviceperson to replace ceiling tiles.

Site

GENERAL CLEANLINESS

Classroom is dusted/vacuumed thoroughly and regularly?

There does not appear to be a dusting issue within this room.

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

Dust observed on supply and return registers at the time of assessment.

Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Site

GENERAL CLEANLINESS

Room is free of pests?

No pests observed at the time of assessment.

GENERAL CLEANLINESS

Classroom is dusted/vacuumed thoroughly and regularly?

There does not appear to be a dusting issue within this room.

GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.		
ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
DRAIN TRAPS IN THE CLASSROOM	Water poured down floor drains once per week (approx. 1 quart of water).	It appears as though water is poured down the floor drain at least once a week.		
EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace ceiling tiles.	Site
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Temperature was acceptable at the time of assessment.		
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		
ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site



ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
EXCESS MOISTURE IN CLASSROOMS	Windows, windowsills and window frames free of continuous condensation?	No condensation on windows at the time of assessment.		
EXCESS MOISTURE IN CLASSROOMS	Indoor surfaces of exterior walls free of continuous condensation?	No visible condensation or signs of water intrusion identified at the time of assessment.		
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	Gaps in doors identified at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.	PPO
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was slightly elevated at the time of assessment. Windows and/or doors were open at the time of assessment. Open doors and windows allow humid untreated air into occupied environment.	Site based administration to encourage staff to keep doors and windows closed.	Site
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Temperature was acceptable at the time of assessment.		
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		

Room	Section	Question	Answer	Recommendation	Responsible
445A	Inside Parameters:	Temp 70.3	RH 64.5	CO2 452	
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
	GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved	Site

		dust and debris accumulation?		germicidal cleaner.	
GENERAL CLEANLINESS		Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.		
ANIMALS IN THE CLASSROOM		You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
ANIMALS IN THE CLASSROOM		Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
THERMAL COMFORT		Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was low at the time of assessment.		
THERMAL COMFORT		Classroom is free of significant temperature shifts?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
THERMAL COMFORT		Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was slightly elevated at the time of assessment. Humidity slightly exceeded target range however indoor humidity was more than 10% lower than the outside reading which is evidence that the ventilation system is dehumidifying fresh air.	Site based facilities serviceperson should monitor this room.	Site
THERMAL COMFORT		Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..		
AIR CONDITIONING		Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		

Room	Section	Question	Answer	Recommendation	Responsible
445C	Inside Parameters:	Temp 68.8	RH 67.7	CO2 453	

THERMAL  
COMFORTClassroom is free of significant  
temperature shifts?Temperature was low at the time of  
assessment.Site based administration to encourage  
facility serviceperson staff to adjust the  
thermostat. Continue to monitor  
condition and initiate a work order for  
Physical Plant Operations to evaluate  
the HVAC system if temperature does  
not improve.

Site

Room	Section	Question	Answer	Recommendation	Responsible
450A	Inside Parameters:	Temp 68.8	RH 67.7	CO2 453	

GENERAL  
CLEANLINESSClassroom is dusted/vacuumed  
thoroughly and regularly?Environmental parameters were not  
within acceptable range at the time of  
assessment..GENERAL  
CLEANLINESSFloor is cleaned on a regular  
basis?Floor was clean at the time of  
assessment.THERMAL  
COMFORTRoom is usually comfortable?  
(If no, please explain in the  
notes below.)Environmental parameters were within  
acceptable range at the time of  
assessment..

Room	Section	Question	Answer	Recommendation	Responsible
455	Inside Parameters:	Temp 71.8	RH 54.1	CO2 588	

GENERAL  
CLEANLINESSClassroom is dusted/vacuumed  
thoroughly and regularly?There does not appear to be a dusting  
issue within this room.GENERAL  
CLEANLINESSAir supply/return registers are  
cleaned regularly and free of  
dust and debris accumulation?Dust observed on supply and return  
registers at the time of assessment.Facilities serviceperson to thoroughly  
clean and sanitize with District approved  
germicidal cleaner.

Site

THERMAL  
COMFORTTemperature in my classroom is  
generally comfortable (72F-  
76F)?Temperature was low at the time of  
assessment.Site based administration to encourage  
facility serviceperson staff to adjust the  
thermostat. Continue to monitor  
condition and initiate a work order for  
Physical Plant Operations to evaluate  
the HVAC system if temperature does  
not improve.

Site

THERMAL  
COMFORTClassroom is free of significant  
temperature shifts?Temperature was acceptable at the time  
of assessment.THERMAL  
COMFORTHumidity is generally  
acceptable? (Typically too high  
if higher than 60% relativeHumidity was acceptable at the time of  
assessment.

	humidity [RH] or too low if lower than 30% RH.)		
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..	
GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room.	
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. Site
DRAIN TRAPS IN THE CLASSROOM	Water poured down floor drains once per week (approx. 1 quart of water).	It appears as though water is poured down the floor drain at least once a week.	
EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. Site
LOCAL EXHAUST FANS	Bathroom exhaust fan is functioning properly?	Bathroom exhaust fan is functioning properly.	

Room	Section	Question	Answer	Recommendation	Responsible
455A	Inside Parameters:	Temp 73.3	RH 54	CO2 676	

GENERAL CLEANLINESS	Classrooms general appearance is clean and acceptable?	General cleanliness of the room at the time of assessment was acceptable.	
GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff. Site
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize. Site

Room	Section	Question	Answer	Recommendation	Responsible
455B	Inside Parameters:	Temp 71.4	RH 54	CO2 630	

ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. Site
--------------------------	--	--	---

**ANIMALS IN THE CLASSROOM** Activities and/or room conditions are modified to address student allergies? This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

**AIR CONDITIONING** Room is free of smell of chemicals? No odor detected at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
462	Inside Parameters:	Temp	RH	CO2	
		69.2	48.2	938	

**GENERAL CLEANLINESS** Classroom is dusted/vacuumed thoroughly and regularly? There does not appear to be a dusting issue within this room.

**EXCESS MOISTURE IN CLASSROOMS** Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)? Signs of water intrusion. Stained ceiling tiles. Physical Plant Operations to evaluate for PPO leaks and repair as appropriate and replace ceiling tiles as appropriate.

**AIR CONDITIONING** Room is free of smell of kitchen/food? No odor detected at the time of assessment.

**AIR CONDITIONING** Room is free of smell of mold or mildew? No microbial growth identified. No odor identified at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
463	Inside Parameters:	Temp	RH	CO2	
		73.4	54.7	631	

**GENERAL CLEANLINESS** Air supply/return registers are cleaned regularly and free of dust and debris accumulation? No dust observed on supply/return registers at the time of assessment.

**ANIMALS IN THE CLASSROOM** You are informed about the potential allergies of your students? This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

**ANIMALS IN THE CLASSROOM** Activities and/or room conditions are modified to address student allergies? This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

**EXCESS** Indoor surfaces of exterior walls No visible condensation or signs of

MOISTURE IN CLASSROOMS	free of continuous condensation?	water intrusion identified at the time of assessment.	
EXCESS MOISTURE IN CLASSROOMS	Area around and under classroom sinks free of leaks?	No leaks or signs of water intrusion identified.	
EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for PPO leaks and repair as appropriate and replace ceiling tiles as appropriate.
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.	
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.	
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.	

Room	Section	Question	Answer	Recommendation	Responsible
469	Inside Parameters:	Temp 73.1	RH 62.3	CO2 747	
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
	GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.		
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
	GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
	GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.		
	ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in	Site

order to modify classroom activities/conditions when necessary.

EXCESS MOISTURE IN CLASSROOMS	Area around and under classroom sinks free of leaks?	No leaks or signs of water intrusion identified.		
EXCESS MOISTURE IN CLASSROOMS	Classroom lavatories/water fountains free of leaks?	No leaks or signs of water intrusion identified.		
EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for PPO leaks and repair as appropriate and replace ceiling tiles as appropriate.	
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	Gaps in doors identified at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.	PPO
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was slightly elevated at the time of assessment. Humidity slightly exceeded target range however indoor humidity was more than 10% lower than the outside reading which is evidence that the ventilation system is dehumidifying fresh air.	Site based facilities serviceperson should monitor this room.	Site
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..		
AIR CONDITIONING	Windows/doors are operable and are kept closed?	Windows and doors are operable and are kept closed.		
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		

Room	Section	Question	Answer	Recommendation	Responsible
479	Inside Parameters:	Temp 73.7	RH 52.1	CO2 568	

GENERAL CLEANLINESS Floor is cleaned on a regular basis? Floor was clean at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
479B	Inside Parameters:	Temp 72.5	RH 52.7	CO2 573	

GENERAL CLEANLINESS Air supply/return registers are cleaned regularly and free of dust and debris accumulation? Dust observed on supply and return registers at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. Site

THERMAL COMFORT Classroom is free of significant temperature shifts? Temperature was acceptable at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
480A	Inside Parameters:	Temp 73.1	RH 51.3	CO2 609	

GENERAL CLEANLINESS Classroom is dusted/vacuumed thoroughly and regularly? There does not appear to be a dusting issue within this room.

GENERAL CLEANLINESS Air supply/return registers are cleaned regularly and free of dust and debris accumulation? Dust observed on supply and return registers at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. Site

GENERAL CLEANLINESS Floor is cleaned on a regular basis? Floor was clean at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
480F	Inside Parameters:	Temp 72.5	RH 52.9	CO2 569	

GENERAL CLEANLINESS Classroom is dusted/vacuumed thoroughly and regularly? There does not appear to be a dusting issue within this room.

GENERAL CLEANLINESS Air supply/return registers are cleaned regularly and free of dust and debris accumulation? Dust observed on supply and return registers at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. Site

ANIMALS IN THE CLASSROOM You are informed about the potential allergies of your students? This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. Site

Room	Section	Question	Answer	Recommendation	Responsible
506	Inside Parameters:	Temp	RH	CO2	



	68.3	68.4	437	
GENERAL CLEANLINESS	Classrooms general appearance is clean and acceptable?	General cleanliness of the room at the time of assessment was acceptable.		
GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room.		
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	No dust observed on supply/return registers at the time of assessment.		
GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.	Site
EXCESS MOISTURE IN CLASSROOMS	Windows, windowsills and window frames free of continuous condensation?	No condensation on windows at the time of assessment.		
EXCESS MOISTURE IN CLASSROOMS	Indoor surfaces of exterior walls free of continuous condensation?	No visible condensation or signs of water intrusion identified at the time of assessment.		
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	PPO
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate and repair as appropriate.	PPO
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		
LOCAL EXHAUST FANS	Other exhaust fans that may exist in the classroom are functioning properly?	Exhaust fan is functioning properly.		

Room	Section	Question	Answer	Recommendation	Responsible
511	Inside Parameters:	Temp	RH	CO2	
		73.6	56.6	484	

ANIMALS IN THE CLASSROOM You are informed about the potential allergies of your students?

This is a general issue requiring approved communication among all stakeholders.

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Section	Question	Answer	Recommendation	Responsible
511E	Inside Parameters:	Temp 73.2	RH 49.7	CO2 563	

GENERAL CLEANLINESS

Classroom is dusted/vacuumed thoroughly and regularly?

There does not appear to be a dusting issue within this room.

GENERAL CLEANLINESS

Floor is cleaned on a regular basis?

Floor was clean at the time of assessment.

THERMAL COMFORT

Room is free of the introduction of outdoor air? (Gaps in window/door frames.)

No gaps in windows or doors identified at the time of assessment.

THERMAL COMFORT

Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)

Humidity was acceptable at the time of assessment.

LOCAL EXHAUST FANS

My classroom has sufficient exhaust systems based on the activities/functionality of the room?

It appears that the ventilation system is adequate based on room activities.

Room	Section	Question	Answer	Recommendation	Responsible
518B	Inside Parameters:	Temp 80.3	RH 47.3	CO2 608	

GENERAL CLEANLINESS

Classroom is dusted/vacuumed thoroughly and regularly?

Slight dust accumulation was observed on environmental surfaces at the time of assessment.

Site based administration should address Site general cleanliness with facility serviceperson staff.

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

Dust observed on supply and return registers at the time of assessment.

Facilities serviceperson to thoroughly Site clean and sanitize with District approved germicidal cleaner.

ANIMALS IN THE CLASSROOM

You are informed about the potential allergies of your students?

This is a general issue requiring approved communication among all stakeholders.

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

ANIMALS IN THE CLASSROOM Activities and/or room conditions are modified to address student allergies? This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. Site

AIR CONDITIONING Room is free of smell of mold or mildew? Odor detected and no microbial growth identified. Physical Plant operations to evaluate cause odor. PPO

Room	Section	Question	Answer	Recommendation	Responsible
519	Inside Parameters:	Temp 69.2	RH 59.8	CO2 536	

GENERAL CLEANLINESS Classrooms general appearance is clean and acceptable? General cleanliness of the room at the time of assessment was acceptable.

GENERAL CLEANLINESS Classroom is dusted/vacuumed thoroughly and regularly? There does not appear to be a dusting issue within this room.

GENERAL CLEANLINESS Floor is cleaned on a regular basis? Floor was clean at the time of assessment.

ANIMALS IN THE CLASSROOM You are informed about the potential allergies of your students? This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. Site

THERMAL COMFORT Classroom is free of significant temperature shifts? Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. Site

THERMAL COMFORT Room is usually comfortable? (If no, please explain in the notes below.) Environmental parameters were not within acceptable range at the time of assessment..

AIR CONDITIONING Room is free of smell of vehicle exhaust? No odor detected at the time of assessment.

LOCAL EXHAUST FANS Bathroom exhaust fan is functioning properly? No bathroom. Identified in error.

LOCAL EXHAUST FANS Other exhaust fans that may exist in the classroom are functioning properly? No exhaust fans in room. Identified in error.

Room	Section	Question	Answer	Recommendation	Responsible
519A	Inside Parameters:	Temp 70.3	RH 58.0	CO2 534	
	ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was low at the time of assessment.		
	THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
	THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..		

Room	Section	Question	Answer	Recommendation	Responsible
519B	Inside Parameters:	Temp 71.9	RH 64.5	CO2 533	
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
	GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
	GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
	GENERAL CLEANLINESS	Spills and other such issues requiring custodial assistance are addressed in a timely manner?	No issues identified relating to spill clean up practices at the time of assessment..		
	GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.		

ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	PPO
GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.		
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	PPO

Room	Section	Question	Answer	Recommendation	Responsible
519C	Inside Parameters:	Temp 68.8	RH 57.8	CO2 594	

GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
---------------------	--	--	---	------

ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was low at the time of assessment.		
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..		
GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.		
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..		

Room	Section	Question	Answer	Recommendation	Responsible
522	Inside Parameters:	Temp	RH	CO2	
		72.0	67.2	532	

GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room.		
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site

GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.		
DRAIN TRAPS IN THE CLASSROOM	Water run in sinks at least once per week (about 2 cups of water).	No sink in room.		
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	Gaps in doors identified at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.	PPO
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was slightly elevated at the time of assessment. Gaps in windows or doors identified at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.	PPO
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate and repair as appropriate.	PPO

Room	Section	Question	Answer	Recommendation	Responsible
524	Inside Parameters:	Temp 74.1	RH 54.1	CO2 631	

GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room.		
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	No dust observed on supply/return registers at the time of assessment.		
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.		
ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
EXCESS MOISTURE IN	Indoor surfaces of exterior walls free of continuous	No visible condensation or signs of water intrusion identified at the time of		

CLASSROOMS condensation? assessment.  
 EXCESS Ceiling tiles or walls free of  
 MOISTURE IN leaks and/or discoloration  
 CLASSROOMS (discoloration may indicate  
 periodic leaks)?  
 AIR Air flowing from air supply? Air supply/return ventilation is  
 CONDITIONING functioning.  
 AIR Room is free of smell of mold No microbial growth identified. No  
 CONDITIONING or mildew? odor identified at the time of  
 assessment.

Room	Section	Question	Answer	Recommendation	Responsible
524B	Inside Parameters:	Temp 74.7	RH 49.6	CO2 657	

GENERAL Air supply/return registers are Dust observed on supply register at the Facilities serviceperson to thoroughly Site  
 CLEANLINESS cleaned regularly and free of time of assessment. clean and sanitize with District approved  
 dust and debris accumulation? germicidal cleaner.  
 ANIMALS IN THE You are informed about the This is a general issue requiring Site based administration is encouraged Site  
 CLASSROOM potential allergies of your approved communication among all to communicate all known student  
 students? stakeholders. allergies to the appropriate personnel in  
 order to modify classroom  
 ANIMALS IN THE Activities and/or room This is a general issue requiring Site based administration is encouraged Site  
 CLASSROOM conditions are modified to approved communication among all to communicate all known student  
 address student allergies? stakeholders. allergies to the appropriate personnel in  
 order to modify classroom  
 activities/conditions when necessary.  
 THERMAL Temperature in my classroom is Temperature was acceptable at the time  
 COMFORT generally comfortable (72F- of assessment.  
 76F)?  
 THERMAL Classroom is free of significant Temperature was acceptable at the time  
 COMFORT temperature shifts? of assessment.  
 THERMAL Room is free of the introduction Room is self contained with no access  
 COMFORT of outdoor air? (Gaps in to outdoor untreated air.  
 window/door frames.)  
 THERMAL Humidity is generally Humidity was acceptable at the time of  
 COMFORT acceptable? (Typically too high assessment.  
 if higher than 60% relative  
 humidity [RH] or too low if  
 lower than 30% RH.)



THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..		
AIR CONDITIONING	Windows/doors are operable and are kept closed?	There are no windows or doors with access to outdoor untreated air.		
AIR CONDITIONING	Room is free of smell of vehicle exhaust?	Odor detected at the time of assessment.	Physical Plant operations to evaluate cause of odor.	PPO
AIR CONDITIONING	Room is free of smell of chemicals?	Odor detected at the time of assessment. Cause not found.	Physical Plant operations to evaluate cause of odor.	PPO

Room	Section	Question	Answer	Recommendation	Responsible
528	Inside Parameters:	Temp 73.3	RH 49.6	CO2 607	

GENERAL CLEANLINESS	Room is free of the use of scented cleaners and air fresheners?	No scented cleaners air fresheners or non-approved chemicals found at the time of assessment.		
ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
DRAIN TRAPS IN THE CLASSROOM	Water poured down floor drains once per week (approx. 1 quart of water).	No floor drain in room.		
AIR CONDITIONING	Air flowing from air supply?	Air supply/return ventilation is functioning.		
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	No gaps in windows or doors identified at the time of assessment.		

THERMAL COMFORT Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.) Humidity was acceptable at the time of assessment.

THERMAL COMFORT Room is usually comfortable? (If no, please explain in the notes below.) Environmental parameters were within acceptable range at the time of assessment..

Room	Section	Question	Answer	Recommendation	Responsible
528D	Inside Parameters:	Temp 71.9	RH 57.6	CO2 693	

EXCESS MOISTURE IN CLASSROOMS Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)? No leaks or signs of water intrusion identified.

THERMAL COMFORT Classroom is free of significant temperature shifts? Temperature was acceptable at the time of assessment.

THERMAL COMFORT Room is usually comfortable? (If no, please explain in the notes below.) Environmental parameters were within acceptable range at the time of assessment..

Room	Section	Question	Answer	Recommendation	Responsible
529A	Inside Parameters:	Temp 72.4	RH 59.5	CO2 585	

GENERAL CLEANLINESS Classroom is dusted/vacuumed thoroughly and regularly? Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address Site general cleanliness with facility serviceperson staff.

Room	Section	Question	Answer	Recommendation	Responsible
530	Inside Parameters:	Temp 73.0	RH 63.5	CO2 548	

DRAIN TRAPS IN THE CLASSROOM Water poured down floor drains once per week (approx. 1 quart of water). Water is not poured down floor drain at least once a week. Site based administration should address Site maintenance of sinks toilets and drains with facility serviceperson staff.

EXCESS MOISTURE IN CLASSROOMS Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)? No leaks or signs of water intrusion identified.

THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate and repair as appropriate.	PPO

Room	Section	Question	Answer	Recommendation	Responsible
532	Inside Parameters:	Temp 71.3	RH 65.6	CO2 529	
GENERAL CLEANLINESS		Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
GENERAL CLEANLINESS		Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
ANIMALS IN THE CLASSROOM		You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
ANIMALS IN THE CLASSROOM		Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
EXCESS MOISTURE IN CLASSROOMS		Windows, windowsills and window frames free of continuous condensation?	No condensation on windows at the time of assessment.		
EXCESS MOISTURE IN CLASSROOMS		Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate and replace ceiling tiles as appropriate.	PPO
Room	Section	Question	Answer	Recommendation	Responsible
540B	Inside Parameters:	Temp 72.0	RH 49.8	CO2 579	
EXCESS		Ceiling tiles or walls free of	No leaks or signs of water intrusion		

MOISTURE IN CLASSROOMS leaks and/or discoloration (discoloration may indicate periodic leaks)? identified.

Room	Section	Question	Answer	Recommendation	Responsible
542A	Inside Parameters:	Temp 68.8	RH 55.0	CO2 540	
	ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was low at the time of assessment.		
	THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
	THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.		
	THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..		
Room	Section	Question	Answer	Recommendation	Responsible
544C	Inside Parameters:	Temp 74.9	RH 68.9	CO2 541	
	GENERAL	Classroom is dusted/vacuumed	Slight dust accumulation was observed	Site based administration should address	Site

CLEANLINESS	thoroughly and regularly?	on environmental surfaces at the time of assessment.	general cleanliness with facility serviceperson staff.
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. Site
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.	
ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. Site
THERMAL COMFORT	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	Windows and/or doors were open at the time of assessment. Open doors and windows allow humid untreated air into occupied environment.	Site based administration to encourage staff to keep doors and windows closed. Site

Room	Section	Question	Answer	Recommendation	Responsible
548	Inside Parameters:	Temp 70.9	RH 55.7	CO2 517	

GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. Site
ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. Site
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. Site
EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks or signs of water intrusion identified.	