

Report: *Walk Through Summary***DAVE THOMAS ED CENTER WEST**

Walkthrough Date: 05/03/2006 Temp RH CO2

Outdoor Parameters: 85.4 43 440

Room	Section	Question	Answer	Recommendation	Responsible
207	Inside Parameters:	Temp	RH	CO2	
		74.7	51.4	444	

AIR  
CONDITIONING Windows/doors are operable and are kept closed? Windows and doors are operable and are kept closed.

AIR  
CONDITIONING Room is free of smell of chemicals? No odor detected at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
209	Inside Parameters:	Temp	RH	CO2	
		73.8	43	439	

GENERAL  
CLEANLINESS Air supply/return registers are cleaned regularly and free of dust and debris accumulation? No dust observed on supply/return registers at the time of assessment.

ANIMALS IN THE  
CLASSROOM You are informed about the potential allergies of your students? This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to Site communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

ANIMALS IN THE  
CLASSROOM Activities and/or room conditions are modified to address student allergies? This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to Site communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

AIR  
CONDITIONING Room is free of smell of chemicals? No odor detected at the time of assessment.

AIR Room is free of smell of No microbial growth

CONDITIONING mold or mildew?

identified. No odor  
identified at the time of  
assessment.