

Jeffrey S. Moquin, Director
Risk Management Department

Telephone: 754-321-3200
Facsimile: 754-321-3290

March 28, 2006

Signature on File

TO: Ms. Linda Wilhoit, Principal
Dave Thomas Education Center

FROM: Robert J. Krickovich, Coordinator, LEA
Facilities and Construction Management, Environmental Division

SUBJECT: Indoor Air Quality (IAQ) Assessment
FISH 108, 109, 111 and 131

On March 15, 2006 I conducted an assessment of FISH 108, 109, 111 and 131 at **Dave Thomas Education Center - Main Campus**. This evaluation included observations of the flooring system, ceiling tiles, false ceiling plenum, environmental surfaces, interior and exterior walls, and the accessible ventilation equipment. Additionally, environmental parameter measurements were taken to include temperature, relative humidity, and carbon dioxide. The detailed findings, along with the recommended corrective action can be found on the attached IAQ Assessment Worksheets.

Generally, the IAQ Assessment did not identify any existing conditions significantly impacting IAQ and thereby presenting immediate health and safety concerns to building occupants. However, due to individual sensitivities and predisposing health factors, it is possible that some building occupants may elicit a health response to agents and / or conditions identified during the evaluation. Therefore, to further improve IAQ, prevent development of future IAQ-related problems, and to reduce the potential for IAQ-related complaints by building occupants, the IAQ Assessment Team recommends appropriate follow up of each item identified and listed in the attached evaluation.

Should any questions arise, or if the current concerns continue after the attached recommendations have been addressed, please feel free to contact me at 754-321-1638.

cc: Dr. Harry LaCava, Area Superintendent
Fran Bolden, Area Director
Jeffrey S. Moquin, Director, Risk Management
Philip Kaufold, Project Manager, Facilities and Construction Management
Jamie Daniels, Broward Teachers Union
Mark Dorsett, Manager 1, Physical Plant Operations Division, Zone 1
Roy Norton, Manager Custodial/Grounds, Physical Plant Operations Division

KP/tc
Enc.

IAQ Assessment

Location Number
 Evaluation Requested
 Evaluation Date

Dave Thomas Education Center - Main (Adult)

Time of Day

Outdoor Conditions Temperature Relative Humidity Ambient CO2

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
<input type="text" value="108"/>	<input type="text" value="75.5"/>	<input type="text" value="72 - 78"/>	<input type="text" value="55.1"/>	<input type="text" value="30% - 60%"/>	<input type="text" value="749"/>	<input type="text" value="Max 700 > Ambient"/>	<input type="text" value="1"/>
Noticeable Odor		Visible water damage / staining?		Visible microbial growth?		Amount of material affected	
<input type="text" value="No"/>		<input type="text" value="No"/>		<input type="text" value="No"/>		<input type="text" value="None"/>	
Ceiling Type	<input type="text" value="2 x 4 Lay In"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		
Wall Type	<input type="text" value="Drywall"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		
Flooring	<input type="text" value="12 x 12 Vinyl"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Walls	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Flooring	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Return Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Ceiling at Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Surfaces in Room	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>

Observations

Findings:

- No visible signs of water intrusion or microbial growth
- Environmental parameters were acceptable at the time of the assessment
- FISH 108, 109 and 111 are side by side with connecting doors and share the same HVAC unit

Recommendations:

Site Based Maintenance:

- Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate

IAQ Assessment

Location Number
 Evaluation Requested
 Evaluation Date

Dave Thomas Education Center - Main (Adult)

Time of Day

Outdoor Conditions Temperature Relative Humidity Ambient CO2

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
<input type="text" value="109"/>	<input type="text" value="74.8"/>	<input type="text" value="72 - 78"/>	<input type="text" value="57.8"/>	<input type="text" value="30% - 60%"/>	<input type="text" value="793"/>	<input type="text" value="Max 700 > Ambient"/>	<input type="text" value="1"/>
Noticeable Odor		Visible water damage / staining?		Visible microbial growth?		Amount of material affected	
<input type="text" value="No"/>		<input type="text" value="No"/>		<input type="text" value="No"/>		<input type="text" value="None"/>	
Ceiling Type	<input type="text" value="2 x 4 Lay In"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		
Wall Type	<input type="text" value="Drywall"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		
Flooring	<input type="text" value="12 x 12 Vinyl"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Walls	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Flooring	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Return Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Ceiling at Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Surfaces in Room	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>

Observations

Findings:

- No visible signs of water intrusion or microbial growth
- Environmental parameters were acceptable at the time of the assessment
- FISH 108, 109 and 111 are side by side with connecting doors and share the same HVAC unit

Recommendations:

Site Based Maintenance:

- Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate

IAQ Assessment

Dave Thomas Education Center - Main (Adult)

Location Number
 Evaluation Requested
 Evaluation Date

Time of Day

Outdoor Conditions Temperature Relative Humidity Ambient CO2

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
<input type="text" value="111"/>	<input type="text" value="74.4"/>	<input type="text" value="72 - 78"/>	<input type="text" value="59.1"/>	<input type="text" value="30% - 60%"/>	<input type="text" value="790"/>	<input type="text" value="Max 700 > Ambient"/>	<input type="text" value="2"/>
Noticeable Odor	<input type="text" value="No"/>		Visible water damage / staining?	Visible microbial growth?	Amount of material affected		
Ceiling Type	<input type="text" value="2 x 4 Lay In"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		
Wall Type	<input type="text" value="Drywall"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		
Flooring	<input type="text" value="12 x 12 Vinyl"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Walls	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Flooring	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Return Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Ceiling at Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Surfaces in Room	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>

Observations

Findings:

- No visible signs of water intrusion or microbial growth
- Environmental parameters were acceptable at the time of the assessment
- Teacher indicated that some days the odor is in one room one day and another room the next day. HFSP advised that odor may be from the cleaning supplies.
- FISH 108, 109 and 111 are side by side with connecting doors and share the same HVAC unit

Recommendations:

Site Based Maintenance:

- Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate

IAQ Assessment

Location Number
 Evaluation Requested
 Evaluation Date

Dave Thomas Education Center - Main (Adult)

Time of Day

Outdoor Conditions Temperature Relative Humidity Ambient CO2

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
<input type="text" value="131"/>	<input type="text" value="74.5"/>	<input type="text" value="72 - 78"/>	<input type="text" value="46.3"/>	<input type="text" value="30% - 60%"/>	<input type="text" value="911"/>	<input type="text" value="Max 700 > Ambient"/>	<input type="text" value="10"/>
Noticeable Odor		Visible water damage / staining?		Visible microbial growth?		Amount of material affected	
<input type="text" value="No"/>		<input type="text" value="No"/>		<input type="text" value="No"/>		<input type="text" value="None"/>	
Ceiling Type	<input type="text" value="2 x 4 Lay In"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		
Wall Type	<input type="text" value="Drywall"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		
Flooring	<input type="text" value="12 x 12 Vinyl"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Walls	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Flooring	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Return Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Ceiling at Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Surfaces in Room	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>

Observations

Findings:

- No visible signs of water intrusion or microbial growth
- Teacher indicated that HVAC was not working, but environmental parameters were acceptable at the time of the assessment. HVAC mechanic from zone 1 was on site at the time of the assessment and he indicated that the unit is working and that the equipment has been checked several times and there is no problem.
- HVAC filter not installed properly

Recommendations:

Site Based Maintenance:

- Remove and reinstall HVAC filter properly
- Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate