

Jeffrey S. Moquin, Director  
Risk Management Department

Telephone: 754-321-3200  
Facsimile: 754-321-3290

September 18, 2006

**Signature on File**

TO: Ms. Mary Lou Ridge, Principal  
**Bethune Elementary School**

FROM: Robert J. Krickovich, Coordinator, LEA  
Facilities and Construction Management, Environmental Division

SUBJECT: Indoor Air Quality (IAQ) Assessment  
**Portable 122C and 634C**

On September 15, 2006 I conducted an assessment of Portable 122C and 634C at **Bethune Elementary School**. This evaluation included observations of the flooring system, ceiling tiles, false ceiling plenum, environmental surfaces, interior and exterior walls, and the accessible ventilation equipment. Additionally, environmental parameter measurements were taken to include temperature, relative humidity, and carbon dioxide. The detailed findings, along with the recommended corrective action can be found on the attached IAQ Assessment Worksheets.

The IAQ assessment did identify one or more existing conditions impacting IAQ and has generated appropriate work orders to correct deficiencies in systems and maintenance that could contribute to decreased indoor air quality. At the time of the assessment, these concerns were not an immediate health or safety concern to building occupants. However, due to individual sensitivities and predisposing health factors, it is possible that some building occupants may elicit a health response to agents and / or conditions identified during the evaluation. Therefore, to further improve IAQ, prevent development of future IAQ-related problems, and to reduce the potential for IAQ-related complaints by building occupants, the IAQ Assessment Team recommends appropriate follow up of each item identified and listed in the attached evaluation.

Should any questions arise, or if the current concerns continue after the attached recommendations have been addressed, please feel free to contact me at 754-321-1638.

cc: Sam Gregg, Area Superintendent  
Margaret Underhill, Area Director  
Jeffrey S. Moquin, Director, Risk Management  
Bob Sharps, Project Manager, Facilities and Construction Management  
Jerrod Neal, Broward Teachers Union  
Mark Dorsett, Manager 1, Physical Plant Operations Division, Zone 1  
Roy Norton, Manager Custodial/Grounds, Physical Plant Operations Division

RK/tc  
Enc.

# IAQ Assessment

Location Number 0341

Bethune Elementary School

Evaluation Requested September 14, 2006

Time of Day 11:45 am

Evaluation Date September 15, 2006

Outdoor Conditions      Temperature 89.9      Relative Humidity 61.8      Ambient CO2 505

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
<span style="border: 1px solid black; padding: 2px;">P-122C</span>	<span style="border: 1px solid black; padding: 2px;">73.3</span>	<span style="border: 1px solid black; padding: 2px;">72 - 78</span>	<span style="border: 1px solid black; padding: 2px;">50</span>	<span style="border: 1px solid black; padding: 2px;">30% - 60%</span>	<span style="border: 1px solid black; padding: 2px;">1147</span>	<span style="border: 1px solid black; padding: 2px;">Max 700 &gt; Ambient</span>	<span style="border: 1px solid black; padding: 2px;">2</span>
Noticeable Odor		Visible water damage / staining?		Visible microbial growth?		Amount of material affected	
<span style="border: 1px solid black; padding: 2px;">No</span>		<span style="border: 1px solid black; padding: 2px;">No</span>		<span style="border: 1px solid black; padding: 2px;">No</span>		<span style="border: 1px solid black; padding: 2px;">None</span>	
Ceiling Type	<span style="border: 1px solid black; padding: 2px;">2 x 4 Lay In</span>		<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">None</span>		
Wall Type	<span style="border: 1px solid black; padding: 2px;">Drywall</span>		<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">None</span>		
Flooring	<span style="border: 1px solid black; padding: 2px;">12 X 12 vinyl</span>		<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">None</span>		

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;"></span>
Walls	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;"></span>
Flooring	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;"></span>
HVAC Supply Grills	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;"></span>
HVAC Return Grills	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;"></span>
Ceiling at Supply Grills	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;"></span>
Surfaces in Room	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;"></span>

## Observations

### Findings:

- No signs of water intrusion or microbial growth. Walls were dry.
- Dust and debris in light fixture lenses.

### Recommendations:

#### Site Based Maintenance:

- Clean light fixture lenses
- Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate

# IAQ Assessment

Location Number 0341  
 Evaluation Requested September 14, 2006  
 Evaluation Date September 15, 2006

Bethune Elementary School

Time of Day 11:45 am

Outdoor Conditions      Temperature 89.9      Relative Humidity 61.8      Ambient CO2 505

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
<span style="border: 1px solid black; padding: 2px;">P-634C</span>	<span style="border: 1px solid black; padding: 2px;">70.3</span>	<span style="border: 1px solid black; padding: 2px;">72 - 78</span>	<span style="border: 1px solid black; padding: 2px;">59.7</span>	<span style="border: 1px solid black; padding: 2px;">30% - 60%</span>	<span style="border: 1px solid black; padding: 2px;">486</span>	<span style="border: 1px solid black; padding: 2px;">Max 700 &gt; Ambient</span>	<span style="border: 1px solid black; padding: 2px;">2</span>
Noticeable Odor	<span style="border: 1px solid black; padding: 2px;">Yes</span>		Visible water damage / staining?	Visible microbial growth?	Amount of material affected		
Ceiling Type	<span style="border: 1px solid black; padding: 2px;">2 x 4 Lay In</span>		<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">2 ceiling tiles</span>		
Wall Type	<span style="border: 1px solid black; padding: 2px;">Tackable</span>		<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">None</span>		
Flooring	<span style="border: 1px solid black; padding: 2px;">12 X 12 vinyl</span>		<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">None</span>		

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">Yes</span>	Replace 2 ceiling tiles
Walls	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	
Flooring	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	
HVAC Supply Grills	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	
HVAC Return Grills	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	
Ceiling at Supply Grills	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	
Surfaces in Room	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	

**Observations**

**Findings:**

- Elevated moisture content in walls - Under both HVAC units (20-30%), Under and between North windows (20-30%), Under Southwest window (25%)
- Dust and debris on HVAC coils - West unit
- 2 stained ceiling tiles at West HVAC unit
- Caulking around windows is deteriorated

**Recommendations:**

**Site Based Maintenance:**

- Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate

**Physical Plant Operations:**

- Evaluate cause of moisture in walls and repair. Repair/replace water damaged wall material as appropriate (see above).
- Clean HVAC coils - West unit
- Remove and replace stained ceiling tiles at West HVAC unit
- Caulk/seal around all windows