

Jeffrey S. Moquin, Director  
Risk Management Department

Telephone: 754-321-3200  
Facsimile: 754-321-3290

December 4, 2006

**Signature on File**

TO: Ms. Mary Lou Ridge, Principal  
**Bethune Elementary School**

FROM: Robert J. Krickovich, Coordinator, LEA  
Facilities and Construction Management, Environmental Division

SUBJECT: Indoor Air Quality (IAQ) Assessment  
**FISH 810, Portable 111N and 992CP**

On November 29, 2006 I conducted an assessment of FISH 810, Portable 111N and 992CP at **Bethune Elementary School**. This evaluation included observations of the flooring system, ceiling tiles, false ceiling plenum, environmental surfaces, interior and exterior walls, and the accessible ventilation equipment. Additionally, environmental parameter measurements were taken to include temperature, relative humidity, and carbon dioxide. The detailed findings, along with the recommended corrective action can be found on the attached IAQ Assessment Worksheets.

The IAQ assessment did identify one or more existing conditions impacting IAQ and has generated appropriate work orders to correct deficiencies in systems and maintenance that could contribute to decreased indoor air quality. At the time of the assessment, these concerns were not an immediate health or safety concern to building occupants. However, due to individual sensitivities and predisposing health factors, it is possible that some building occupants may elicit a health response to agents and / or conditions identified during the evaluation. Therefore, to further improve IAQ, prevent development of future IAQ-related problems, and to reduce the potential for IAQ-related complaints by building occupants, the IAQ Assessment Team recommends appropriate follow up of each item identified and listed in the attached evaluation.

Should any questions arise, or if the current concerns continue after the attached recommendations have been addressed, please feel free to contact me at 754-321-1638.

cc: Sam Gregg, Area Superintendent  
Margaret Underhill, Area Director  
Jeffrey S. Moquin, Director, Risk Management  
Bob Sharps, Project Manager, Facilities and Construction Management  
Jerrod Neal, Broward Teachers Union  
Mark Dorsett, Manager 1, Physical Plant Operations Division, Zone 1  
Roy Norton, Manager Custodial/Grounds, Physical Plant Operations Division

RK/tc  
Enc.

# IAQ Assessment

Location Number 0341  
 Evaluation Requested November 27, 2006  
 Evaluation Date November 29, 2006

Bethune Elementary School

Time of Day 1:00 pm

Outdoor Conditions      Temperature 84.6      Relative Humidity 60.2      Ambient CO2 483

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
<span style="border: 1px solid black; padding: 2px;">810</span>	<span style="border: 1px solid black; padding: 2px;">74.6</span>	<span style="border: 1px solid black; padding: 2px;">72 - 78</span>	<span style="border: 1px solid black; padding: 2px;">52.7</span>	<span style="border: 1px solid black; padding: 2px;">30% - 60%</span>	<span style="border: 1px solid black; padding: 2px;">770</span>	<span style="border: 1px solid black; padding: 2px;">Max 700 &gt; Ambient</span>	<span style="border: 1px solid black; padding: 2px;">3</span>
Noticeable Odor		Visible water damage / staining?		Visible microbial growth?		Amount of material affected	
<span style="border: 1px solid black; padding: 2px;">No</span>		<span style="border: 1px solid black; padding: 2px;">No</span>		<span style="border: 1px solid black; padding: 2px;">No</span>		<span style="border: 1px solid black; padding: 2px;">None</span>	
Ceiling Type	<span style="border: 1px solid black; padding: 2px;">2 x 4 Lay In</span>		<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">None</span>		
Wall Type	<span style="border: 1px solid black; padding: 2px;">Drywall</span>		<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">None</span>		
Flooring	<span style="border: 1px solid black; padding: 2px;">Carpet</span>		<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">None</span>		

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; height: 20px; width: 100%;"></span>
Walls	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; height: 20px; width: 100%;"></span>
Flooring	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; height: 20px; width: 100%;"></span>
HVAC Supply Grills	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; height: 20px; width: 100%;"></span>
HVAC Return Grills	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; height: 20px; width: 100%;"></span>
Ceiling at Supply Grills	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; height: 20px; width: 100%;"></span>
Surfaces in Room	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; height: 20px; width: 100%;"></span>

**Observations**

**Findings:**

- No signs of water intrusion or visible microbial growth
- Green staining around interior of four copper kettle drums

**Recommendations:**

**Site Based Maintenance:**

- School to have the four copper kettle drums cleaned/repaired
- Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate

# IAQ Assessment

Location Number 0341  
 Evaluation Requested November 27, 2006  
 Evaluation Date November 29, 2006

Bethune Elementary School

Time of Day 1:00 pm

Outdoor Conditions      Temperature 84.6      Relative Humidity 60.2      Ambient CO2 483

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
<span style="border: 1px solid black; padding: 2px;">P-111N</span>	<span style="border: 1px solid black; padding: 2px;">76.5</span>	<span style="border: 1px solid black; padding: 2px;">72 - 78</span>	<span style="border: 1px solid black; padding: 2px;">42.2</span>	<span style="border: 1px solid black; padding: 2px;">30% - 60%</span>	<span style="border: 1px solid black; padding: 2px;">2193</span>	<span style="border: 1px solid black; padding: 2px;">Max 700 &gt; Ambient</span>	<span style="border: 1px solid black; padding: 2px;">20</span>
Noticeable Odor		Visible water damage / staining?		Visible microbial growth?		Amount of material affected	
<span style="border: 1px solid black; padding: 2px;">No</span>		<span style="border: 1px solid black; padding: 2px;">Yes</span>		<span style="border: 1px solid black; padding: 2px;">No</span>		<span style="border: 1px solid black; padding: 2px;">Over East A/C Unit</span>	
Ceiling Type	<span style="border: 1px solid black; padding: 2px;">4' x 8' Homasote</span>		<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>		<span style="border: 1px solid black; padding: 2px;">Under East A/C Unit</span>	
Wall Type	<span style="border: 1px solid black; padding: 2px;">4' x 8' Homasote</span>		<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>		<span style="border: 1px solid black; padding: 2px;">None</span>	
Flooring	<span style="border: 1px solid black; padding: 2px;">12 x 12 Vinyl</span>		<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>			

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">Repair/replace stained ceiling panel</span>
Walls	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">Repair/replace stained wall material</span>
Flooring	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;"></span>
HVAC Supply Grills	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;"></span>
HVAC Return Grills	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;"></span>
Ceiling at Supply Grills	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;"></span>
Surfaces in Room	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;"></span>

**Observations**

**Findings:**

- Only one East A/C unit was on at the time of the assessment - set for fresh air intake
- CO2 level was elevated
- Elevated moisture content in wall under left side of East A/C unit
- Ceiling material over East A/C unit is stained (dry)

**Recommendations:**

**Site Based Maintenance:**

- Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate

**Physical Plant Operations:**

- Evaluate A/C units for proper operation and repair as appropriate to lower CO2 level
- Evaluate cause of moisture in wall under left side of East A/C unit and repair. Remove and replace wall material as appropriate.
- Evaluate cause of stained ceiling over East A/C unit and repair. Remove and replace ceiling material as appropriate.

# IAQ Assessment

Location Number 0341  
 Evaluation Requested November 27, 2006  
 Evaluation Date November 29, 2006

Bethune Elementary School

Time of Day 1:00 pm

Outdoor Conditions      Temperature 84.6      Relative Humidity 60.2      Ambient CO2 483

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
<span style="border: 1px solid black; padding: 2px;">P-992CP</span>	<span style="border: 1px solid black; padding: 2px;">76.6</span>	<span style="border: 1px solid black; padding: 2px;">72 - 78</span>	<span style="border: 1px solid black; padding: 2px;">47.6</span>	<span style="border: 1px solid black; padding: 2px;">30% - 60%</span>	<span style="border: 1px solid black; padding: 2px;">1156</span>	<span style="border: 1px solid black; padding: 2px;">Max 700 &gt; Ambient</span>	<span style="border: 1px solid black; padding: 2px;">17</span>
Noticeable Odor	<span style="border: 1px solid black; padding: 2px;">No</span>		Visible water damage / staining?	Visible microbial growth?	Amount of material affected		
Ceiling Type	<span style="border: 1px solid black; padding: 2px;">2 x 4 Lay In</span>		<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">Over East A/C Unit - 1 tile</span>		
Wall Type	<span style="border: 1px solid black; padding: 2px;">Tackboard</span>		<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">Under both A/C units</span>		
Flooring	<span style="border: 1px solid black; padding: 2px;">12 x 12 Vinyl</span>		<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">None</span>		

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">Remove and replace stained ceiling tile</span>
Walls	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">Repair/replace wall material</span>
Flooring	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;"></span>
HVAC Supply Grills	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;"></span>
HVAC Return Grills	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;"></span>
Ceiling at Supply Grills	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;"></span>
Surfaces in Room	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;"></span>

**Observations**

**Findings:**

- Only one A/C unit was on at the time of the assessment - not set for fresh air intake
- Elevated moisture content in walls under both A/C units
- 1 stained ceiling tile over East A/C unit

**Recommendations:**

**Site Based Maintenance:**

- Ensure that both A/C units are on and set for fresh air intake
- Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate

**Physical Plant Operations:**

- Evaluate cause of moisture in walls under both A/C units. Remove and replace wall material as appropriate.
- Evaluate cause of stained ceiling over East A/C unit and repair. Remove and replace stained ceiling tile.