

Jeffrey S. Moquin, Director  
Risk Management Department

Telephone: 754-321-3200  
Facsimile: 754-321-3290

January 16, 2008

**Signature on File**

TO: Mr. Donald Cottrell, Principal  
**Broadview Elementary School**

FROM: Aston A. Henry, Supervisor  
Risk Management Department

SUBJECT: Indoor Air Quality (IAQ) Assessment  
**FISH 118**

<u>For Custodial Supervisor Use Only</u>	
<input type="checkbox"/>	Custodial Issues Addressed
<input type="checkbox"/>	Custodial Issues Not Addressed
_____	
_____	

On December 12, 2007 I conducted an assessment of FISH 118 at **Broadview Elementary School**. This evaluation included observations of the flooring system, ceiling tiles, false ceiling plenum, environmental surfaces, interior and exterior walls, and the accessible ventilation equipment. Additionally, environmental parameter measurements were taken to include temperature, relative humidity, and carbon dioxide. The detailed findings, along with the recommended corrective action can be found on the attached IAQ Assessment Worksheets.

The IAQ assessment did identify one or more existing conditions impacting IAQ and has generated appropriate work orders to correct deficiencies in systems and maintenance that could contribute to decreased indoor air quality. At the time of the assessment, these concerns were not an immediate health or safety concern to building occupants. However, due to individual sensitivities and predisposing health factors, it is possible that some building occupants may elicit a health response to agents and / or conditions identified during the evaluation. Therefore, to further improve IAQ, prevent development of future IAQ-related problems, and to reduce the potential for IAQ-related complaints by building occupants, the IAQ Assessment Team recommends appropriate follow up of each item identified and listed in the attached evaluation.

*Please ensure that your Head Facilities Serviceperson receives a copy of this correspondence so that the recommendations requiring their attention can be addressed. Within two weeks a representative from the Custodial/Grounds Department will conduct a follow-up visit to ensure that all issues have been appropriately addressed.*

Should any questions arise, or if the current concerns continue after the attached recommendations have been addressed, please feel free to contact me at 754-321-3200.

cc: Dr. Leontine Butler, Area Superintendent  
Desmond Blackburn, Area Director  
Jeffrey S. Moquin, Director, Risk Management  
Israel Rodriguez-Soto, Project Manager, Facilities and Construction Management  
Gary Itzkowitz, Broward Teachers Union  
Roy Jarrett, Federation of Public Employees  
Mark Dorsett, Manager 1, Physical Plant Operations Division, Zone 1  
Roy Norton, Manager Custodial/Grounds, Physical Plant Operations Division  
Robert Krickovich, Coordinator, LEA, Facilities and Construction Management

AAH/tc  
Enc.

# IAQ Assessment

Location Number 0811  
 Evaluation Requested December 5, 2007  
 Evaluation Date December 12, 2007

Broadview Elementary School

Time of Day 1:05 pm

Outdoor Conditions      Temperature 82      Relative Humidity 62.7      Ambient CO2 450

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
<span style="border: 1px solid black; padding: 2px;">118</span>	<span style="border: 1px solid black; padding: 2px;">73.3</span>	<span style="border: 1px solid black; padding: 2px;">72 - 78</span>	<span style="border: 1px solid black; padding: 2px;">48.4</span>	<span style="border: 1px solid black; padding: 2px;">30% - 60%</span>	<span style="border: 1px solid black; padding: 2px;">1641</span>	<span style="border: 1px solid black; padding: 2px;">Max 700 &gt; Ambient</span>	<span style="border: 1px solid black; padding: 2px;">16</span>
Noticeable Odor		Visible water damage / staining?		Visible microbial growth?		Amount of material affected	
<span style="border: 1px solid black; padding: 2px;">No</span>		<span style="border: 1px solid black; padding: 2px;">No</span>		<span style="border: 1px solid black; padding: 2px;">No</span>		<span style="border: 1px solid black; padding: 2px;">None</span>	
Ceiling Type	<span style="border: 1px solid black; padding: 2px;">2 x 4 Lay In</span>		<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">None</span>		
Wall Type	<span style="border: 1px solid black; padding: 2px;">Tackable</span>		<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">None</span>		
Flooring	<span style="border: 1px solid black; padding: 2px;">Tile</span>		<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">None</span>		

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; height: 20px; width: 100%;"></span>
Walls	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; height: 20px; width: 100%;"></span>
Flooring	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; height: 20px; width: 100%;"></span>
HVAC Supply Grills	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; height: 20px; width: 100%;"></span>
HVAC Return Grills	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; height: 20px; width: 100%;"></span>
Ceiling at Supply Grills	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; height: 20px; width: 100%;"></span>
Surfaces in Room	<span style="border: 1px solid black; padding: 2px;">Yes</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; height: 20px; width: 100%;"></span>

**Observations**

**Findings:**  
 - No visible signs of microbial growth or water intrusion  
 - CO2 level was slightly elevated at the time of the assessment

**Recommendations:**

**Site Based Maintenance:**  
 - Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate

**Physical Plant Operations**  
 - Evaluate HVAC for proper operation and repair as appropriate to lower CO2 level