

managing risk with responsibility

Aston A. Henry, Director Risk Management Department		Telephone: Fax:	754 321-1900 754 321-1917	
February 24,	2015 Signature on File	For Custodial S	upervisor Use Only	
TO:	Donald Lee, Principal	Custodial Iss	ues Addressed	
	Broadview Elementary	Custodial Iss	ues Not Addressed	
FROM:	Daniel Meyer, Project Manager			
	Risk Management Department			
SUBJECT:	Indoor Air Quality (IAQ) Assessment			

On February 20, 2015, I conducted an assessment at **Broadview Elementary School**. Attached are findings and recommendations for further assessment, remediation, or corrective actions needed.

The IAQ assessment did identify one or more existing conditions impacting IAQ and has generated appropriate work orders to correct deficiencies in systems and maintenance that could contribute to decreased indoor air quality. At the time of the assessment, these concerns were not an immediate health or safety concern to building occupants. However, due to individual sensitivities and predisposing health factors, it is possible that some building occupants may elicit a health response to agents and / or conditions identified during the evaluation. Therefore, to further improve IAQ, prevent development of future IAQ-related problems, and to reduce the potential for IAQ-related complaints by building occupants, the IAQ Assessment Team recommends appropriate follow up of each item identified and listed in the attached evaluation.

Please ensure that your Head Facilities Serviceperson receives a copy of this correspondence so that the recommendations requiring their attention can be addressed. In an attempt to separate IAQ issues from general maintenance items, the attached assessment may contain direction for site based staff to generate a work order through COMPASS. Within two weeks a representative from the Custodial/Grounds Department will conduct a follow-up visit to ensure that all site based custodial issues have been appropriately addressed.

Should any questions arise, or if the current concerns continue after the attached recommendations have been addressed, please feel free to contact us at 754-321-1900.

cc: Shelley Meloni, Executive Director, Facilities & Construction
Mark Dorsett, Manager, Zone 1, Physical Plant Operations Division
Roy Norton, Manager, Custodial/Grounds, Physical Plant Operations Division
Aston Henry, Director, Risk Management
Sonja Coley, Senior Project Manager, Facilities & Construction
Broward Teachers Union
Federation of Public Employees

DM/jj Enc.

Remove throw rugs	
Remove and replace A/C filters	
	▼
	▼
	▼
	▼
	▼
	▼

Evaluate wet wall under South window	▼
Evaluate rotten wood around windows	
	▼
	▼
	▼
	▼
	▼
	▼