

# Tools for Schools - Indoor Air Quality

## Follow-up Action Plan for Project Manager



Broadview Elementary

Principal: Mrs. Mary Morgan

Walkthrough Date: 4/14/2004

Temp RH Co2  
Outside Measurements

Assignment Member: Mark Dorsett

Room	Priority	Responsible	Assessment Comments	Recommended Corrective Action
101	3	Project Manager	Appears to be a balancing problem in building 1.	Test and Balance building 1.