

# Broadview Elementary

Outdoor Parameter Measurements:

Temp

RH

Co2

WalkthroughDate: 4/14/2004

--	--	--

	Category	Detail	Assessment Comments	Recommended Corrective Action
<b>101</b>	<input type="text"/> <i>Temp</i>	<input type="text"/> <i>RH</i>	<input type="text"/> <i>Co2</i>	
	Exterior Inspection	Check Building Drainage	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Interior Inspection	Check preventative indoor items.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Interior Inspection	General maintenance items.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Interior Inspection	Restroom fans.	Appears to be a balancing problem in building 1.	Test and Balance building 1.
A/C system balance and calibration of thermostats has not been completed. This was requested from the Salazar and Spaul IAQ report dated May 2001. Work orders were closed out. Facility manager has been contacted about his ongoing				
<b>101L</b>	<input type="text"/> <i>Temp</i>	<input type="text"/> <i>RH</i>	<input type="text"/> <i>Co2</i>	
	Health and Hygiene Education	Provide information about IAQ and health.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Health and Hygiene Education	Obtain Indoor Air Quality: An Introduction for Health professionals	Needs IAQ manual.	Contact EPA website <a href="http://www.epa.gov/iaq">www.epa.gov/iaq</a>
	Health Officer's Office	Ensure that the ventilation system is properly operating.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Maintain Student Health Records	Track health-related complaints by students and staff.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Maintain Student Health Records	Recognize indicators that health problems may be IAQ related.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
<b>104</b>	<input type="text"/> <i>Temp</i>	<input type="text"/> <i>RH</i>	<input type="text"/> <i>Co2</i>	

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
<b>104D</b>	General Classroom Information		Hot in work room.	Maintenance needs to inspect HVAC for proper operation.
	General Cleanliness	Confirm that the classroom is cleaned properly.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
		The hub for the computer system generates heat in the workroom (104a).		
		<input type="text"/>	<input type="text"/>	<input type="text"/>
		<i>Temp</i>	<i>RH</i>	<i>Co2</i>
<b>111</b>	Drain Traps	Fill drain traps in your area each week.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Thermal Comfort	Check comfort factors.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
	Ventilation	Check for unexplained odors.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
		<input type="text"/>	<input type="text"/>	<input type="text"/>
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	Thermal Comfort	Humidity level.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
	Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
	Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.
	Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
	Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
<b>1110PHC</b>	<input type="text"/> <i>Temp</i>	<input type="text"/> <i>RH</i>	<input type="text"/> <i>Co2</i>	
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	Water intrusion around exterior doors.	Maintenance to inspect and repair as appropriate.
	General Cleanliness	Confirm that the classroom is cleaned properly.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	<input type="text" value="My classroom is much better since it has been rebuilt and the new air conditioner put in."/>			
<b>113</b>	<input type="text"/> <i>Temp</i>	<input type="text"/> <i>RH</i>	<input type="text"/> <i>Co2</i>	
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	<input type="text"/>			
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Local Exhaust Fans	Confirm that fume hoods and local exhaust fans are used whenever activities that generate pollutants take place.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Local Exhaust Fans	Confirm that fume hoods and local exhaust fans function properly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Local Exhaust Fans	General items.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
	Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.
	Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
	<input type="text" value="My main concern is of an unusual smell that I am unable to identify."/>			

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
<b>113B</b>	<input type="text"/> <i>Temp</i>	<input type="text"/> <i>RH</i>	<input type="text"/> <i>Co2</i>	
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	Stained ceiling tile.	Maintenance to inspect for roof leak and repair as appropriate and replace ceiling tiles.
	General Cleanliness	Confirm that the classroom is cleaned properly.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	General Cleanliness	Clean spills promptly	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.
	Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.
	Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
	My concerns are that often I have been suffering from severe headaches so I would appreciate it if someone would check this room. Thank you.			
<b>114</b>	<input type="text"/> <i>Temp</i>	<input type="text"/> <i>RH</i>	<input type="text"/> <i>Co2</i>	
	Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
	Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
<b>116</b>	<input type="text"/> <i>Temp</i>	<input type="text"/> <i>RH</i>	<input type="text"/> <i>Co2</i>	
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
		<input type="text" value="Every need in these areas are met. The class is cleaned daily. I have seen a few insects, but not often."/>		
<b>117A</b>	<input type="text"/> <i>Temp</i>	<input type="text"/> <i>RH</i>	<input type="text"/> <i>Co2</i>	
	Health and Hygiene Education	Inform students and staff about the importance of good hygiene in preventing the spread of airborne contagious diseases.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
		<input type="text"/>		
<b>118</b>	<input type="text"/> <i>Temp</i>	<input type="text"/> <i>RH</i>	<input type="text"/> <i>Co2</i>	
	Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
		<input type="text" value="Unpleasant odors are present inside drawers and under sink."/>		
<b>119</b>	<input type="text"/> <i>Temp</i>	<input type="text"/> <i>RH</i>	<input type="text"/> <i>Co2</i>	
	Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
	Drain Traps in the Classroom	Drain traps, if present, can become a problem when the water in the drain trap evaporates due to infrequent use, allowing sewer gases to enter the room.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
	Thermal Comfort	Humidity level.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
<b>120</b>	<input type="text"/> <i>Temp</i>	<input type="text"/> <i>RH</i> <input type="text"/> <i>Co2</i>	<input type="text"/>	
	General Cleanliness	Confirm that the classroom is cleaned properly.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
<b>121</b>	<input type="text"/> <i>Temp</i>	<input type="text"/> <i>RH</i> <input type="text"/> <i>Co2</i>	<input type="text"/>	
	General Classroom Information		Check A/C.	Maintenance needs to inspect HVAC for proper operation.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
<b>125</b>	<input type="text"/> <i>Temp</i>	<input type="text"/> <i>RH</i> <input type="text"/> <i>Co2</i>	<input type="text"/> Temperature throughout building is very inconsistent: freezing in some areas and very warm and humid in other areas.	
	Local Exhaust Fans	Confirm that fume hoods and local exhaust fans function properly.	Odors coming from restroom.	Reset toilet in restroom.
	Ventilation	Check for unexplained odors.	Odor coming from restroom.	See other item to repair.
			<input type="text"/> The bathroom located in my room often has a foul mildew odor. There is a fan in the bathroom, however it is set to a timer to only run when the bathroom light is on. The bathroom door is closed most of the day and fan is of	

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
<b>126</b>	<input type="text"/> <i>Temp</i>	<input type="text"/> <i>RH</i>	<input type="text"/> <i>Co2</i>	
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
	I think we need for help in having our computers cleaned. There is a lot of dust on top of them. Also the bathroom sometimes smells and they need to have some kind of chemical. Also in the middle of the day my classroom is very cold. When it is cold outside my room gets much colder.			
<b>129</b>	<input type="text"/> <i>Temp</i>	<input type="text"/> <i>RH</i>	<input type="text"/> <i>Co2</i>	
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
	Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.
<b>12M</b>	<input type="text"/> <i>Temp</i>	<input type="text"/> <i>RH</i>	<input type="text"/> <i>Co2</i>	
	Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
	Excess Moisture in Classrooms	Check for leaks (or signs of wetness) from plumbing or roof.	Stained ceiling tiles.	Maintenance to inspect for roof leak and repair as appropriate and replace ceiling tiles.
	General Cleanliness	Confirm that the classroom is cleaned properly.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>	
Ventilation	Determine how your classroom is ventilated.	See other item.	No corrective action recommended at this time.	
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.	
Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	There were no problems observed at time of assessment.	No corrective action recommended at this time.	
Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	There is no air movement.	Install exhaust fan.	
<b>130</b>				
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	Health and Hygiene Education	Inform students and staff about the importance of good hygiene in preventing the spread of airborne contagious diseases.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Health and Hygiene Education	Establish an information and counseling program regarding smoking.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Health Officer's Office	Ensure that the ventilation system is properly operating.	Ventilation is working properly.	No corrective action recommended at this time.	
<b>131</b>				
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	Local Exhaust Fans	General items.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Local Exhaust Fans	Confirm that fume hoods and local exhaust fans function properly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Thermal Comfort	General items to watch for.	There were no problems observed at time of assessment.	No corrective action recommended at this time.	

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
<b>133</b>	<input type="text"/> <i>Temp</i>	<input type="text"/> <i>RH</i>	<input type="text"/> <i>Co2</i>	
	General Cleanliness	Confirm that the classroom is cleaned properly.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
<input type="text"/>				
<b>134</b>	<input type="text"/> <i>Temp</i>	<input type="text"/> <i>RH</i>	<input type="text"/> <i>Co2</i>	
	Thermal Comfort	General items to watch for.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
	Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.
<input type="text"/>				
<b>136</b>	<input type="text"/> <i>Temp</i>	<input type="text"/> <i>RH</i>	<input type="text"/> <i>Co2</i>	
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
<input type="text"/>				
	General Cleanliness	Confirm that the classroom is cleaned properly.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
148	Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
		When I first started here I had a series of sinus infections and weird headaches. I found out that I had developed asthma and when I am on a break I feel all right, but as soon as I come back, I start to become extremely congested		
		<input type="text"/>	<input type="text"/>	<input type="text"/>
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
149B	General Cleanliness	Confirm that the classroom is cleaned properly.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
		<input type="text"/>		
		<input type="text"/>	<input type="text"/>	<input type="text"/>
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	General Cleanliness	Confirm that the office area is cleaned properly.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	Local Exhaust Fans	Determine if activities generate air pollutants and whether the room or area is equipped with local exhaust fans.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Local Exhaust Fans	Confirm that local exhaust fans (if any) function properly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Printing/Duplicating Equipment	Minimize staff and student exposure to equipment.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Thermal Comfort	Humidity level.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Thermal Comfort	Check comfort factors.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.
	Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
	Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.
		<input type="text"/>		

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
<b>150</b>	<input type="text"/>	<input type="text"/>	<input type="text"/>	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
	Drain Traps in the Classroom	Drain traps, if present, can become a problem when the water in the drain trap evaporates due to infrequent use, allowing sewer gases to enter the room.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.	
<input type="text"/>				
<b>152</b>	<input type="text"/>	<input type="text"/>	<input type="text"/>	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.	
<input type="text"/>				
<b>153</b>	<input type="text"/>	<input type="text"/>	<input type="text"/>	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
Health and Hygiene Education	Inform students and staff about the importance of good hygiene in preventing the spread of airborne contagious diseases.	There were no problems observed at time of assessment.	No corrective action recommended at this time.	

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
Health Officer's Office	Ensure that the ventilation system is properly operating.	Ventilation is working properly.	No corrective action recommended at this time.
Maintain Student Health Records	Recognize indicators that health problems may be IAQ-related.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Maintain Student Health Records	Track health-related complaints by students and staff.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Maintain Student Health Records	Include information about sensitivities to IAQ problems in student health records.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
The building is far better than it used to be since they removed the carpets and all is tile now. However the bathrooms still smell constantly.			
154	<input type="text"/>	<input type="text"/>	<input type="text"/>
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>
Health and Hygiene Education	Provide information about IAQ and health.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Health and Hygiene Education	Establish an information and counseling program regarding smoking.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Maintain Student Health Records	Track health-related complaints by students and staff.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Maintain Student Health Records	Recognize indicators that health problems may be IAQ-related.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
206	<input type="text"/>	<input type="text"/>	<input type="text"/>
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>
Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
Art Supplies	Learn about supplies.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Art Supplies	Follow good safety, handling and storage practices.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Art Supplies	Minimize exposure to hazardous materials.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	Stained ceiling tile.	Maintenance to inspect for roof leak and repair as appropriate and replace ceiling tiles.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
General Cleanliness	Clean spills promptly	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Industrial and Vocational Education Supplies	Follow good safety, handling and storage practices.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Local Exhaust Fans	Confirm that fume hoods and local exhaust fans are used whenever activities that generate pollutants take place.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Local Exhaust Fans	Confirm that fume hoods and local exhaust fans function properly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Local Exhaust Fans	General items.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Thermal Comfort	General items to watch for.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.

207

<i>Temp</i>	<i>RH</i>	<i>Co2</i>	

General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Thermal Comfort	General items to watch for.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Thermal Comfort	Humidity level.	There were no problems observed at time of assessment.	No corrective action recommended at this time.

At times the room gets extremely warm.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
208	<input type="text"/> <i>Temp</i>	<input type="text"/> <i>RH</i>	<input type="text"/> <i>Co2</i>	
	Thermal Comfort	General items to watch for.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
211	<input type="text"/> <i>Temp</i>	<input type="text"/> <i>RH</i>	<input type="text"/> <i>Co2</i>	
	Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Local Exhaust Fans	Confirm that fume hoods and local exhaust fans are used whenever activities that generate pollutants take place.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Thermal Comfort	Humidity level.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.
212	<input type="text"/> <i>Temp</i>	<input type="text"/> <i>RH</i>	<input type="text"/> <i>Co2</i>	
	Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
		I have experienced what the doctor calls lingering bronchitis for 3 years now. I know it has to be related to the school building because over the summer, winter, and spring breaks I am not sick at all!		

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
Drain Traps in the Classroom	Drain traps, if present, can become a problem when the water in the drain trap evaporates due to infrequent use, allowing sewer gases to enter the room.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Local Exhaust Fans	General items.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Local Exhaust Fans	Confirm that fume hoods and local exhaust fans function properly.	Exhaust fan in restroom is not working.	Repair exhaust fan.
Thermal Comfort	General items to watch for.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.
I have developed asthmatic conditions and am on medication for it. It developed at the end of last year.			
213	<input type="text"/>	<input type="text"/>	<input type="text"/>
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>
Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.
I have developed asthmatic conditions and am on medication for it. It developed at the end of last year.			
215	<input type="text"/>	<input type="text"/>	<input type="text"/>
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>
Dust Control	Use higher efficiency vacuum bags.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
I have developed asthmatic conditions and am on medication for it. It developed at the end of last year.			

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
<b>218</b>	<input type="text"/> <i>Temp</i>	<input type="text"/> <i>RH</i>	<input type="text"/> <i>Co2</i>	
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Thermal Comfort	Humidity level.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.
	Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
	Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.
	Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
	Dusting should be done with a wet rag, instead of a feather duster.			
<b>219</b>	<input type="text"/> <i>Temp</i>	<input type="text"/> <i>RH</i>	<input type="text"/> <i>Co2</i>	
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Ventilation	Check for unexplained odors.	Exhaust fans not working	Repair/replace exhaust fans.
	There is an odor that appears occasionally, but not all the time, and some days more than others. I have had better health this year, possibly because of being in a different classroom.			

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
<b>220</b>	<input type="text"/> <i>Temp</i>	<input type="text"/> <i>RH</i>	<input type="text"/> <i>Co2</i>	
	Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Industrial and Vocational Education Supplies	Learn about your supplies.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Locker Room	Verify that showers and other locker room areas are cleaned regularly and properly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Science Supplies	Learn about your supplies. Read labels and identify precautions regarding fumes ventilation. Request information and Material Safety Data Sheets (MSDS) from suppliers and manufacturers.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.

We have a need for more custodians on a daily basis. It is impossible for the room to be in top shape with so much to do for one person.

<b>301</b>	<input type="text"/> <i>Temp</i>	<input type="text"/> <i>RH</i>	<input type="text"/> <i>Co2</i>	
	Drain Traps in the Classroom	Drain traps, if present, can become a problem when the water in the drain trap evaporates due to infrequent use, allowing sewer gases to enter the room.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
General Cleanliness	Clean spills promptly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Local Exhaust Fans	General items.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Local Exhaust Fans	Confirm that fume hoods and local exhaust fans are used whenever activities that generate pollutants take place.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Local Exhaust Fans	Confirm that fume hoods and local exhaust fans function properly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Thermal Comfort	Humidity level.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Thermal Comfort	General items to watch for.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.
Ventilation	Check for unexplained odors.	Carpeting is stained.	Replace carpeting in entire portable (4 pods).

The classroom needs the old carpet to be removed and better cleaning practices.

303

*Temp*

*RH*

*Co2*

Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Clean spills promptly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
General Cleanliness	Confirm that the classroom is cleaned properly.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
Ventilation	Check for unexplained odors.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
Ventilation	Determine how your classroom is ventilated.	Exhaust fans in restroom not working.	Replace exhaust fan.

304

<i>Temp</i>	<i>RH</i>	<i>Co2</i>	

General Classroom Information

Water leak on ceiling tile on west wall.

Maintenance to inspect for leak and repair as appropriate and replace ceiling tiles.

863VE

<i>Temp</i>	<i>RH</i>	<i>Co2</i>	

Excess Moisture in Classrooms

Check for leaks or signs of moisture from plumbing or roofs.

There were no problems observed at time of assessment.

No corrective action recommended at this time.

General Cleanliness

Confirm that the classroom is cleaned properly.

General cleanliness appeared adequate on date of assessment.

No corrective action recommended at this time.

General Cleanliness

Check for pests.

There were no problems observed at time of assessment.

No corrective action recommended at this time.

Local Exhaust Fans

Confirm that fume hoods and local exhaust fans are used whenever activities that generate pollutants take place.

There were no problems observed at time of assessment.

No corrective action recommended at this time.

Local Exhaust Fans

General items.

Exhaust fan and light are on a separate switch.

Interlock bathroom light and exhaust fan.

Thermal Comfort

Humidity level.

There were no problems observed at time of assessment.

No corrective action recommended at this time.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>	
	Thermal Comfort	General items to watch for.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Ventilation	Check for unexplained odors.	Air freshener in room.	Remove air freshener.
<b>P-128</b>	Many children in my class have congestion, runny noses and headaches.			
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.
<b>PM15</b>				
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
	Drain Traps in the Classroom	Drain traps, if present, can become a problem when the water in the drain trap evaporates due to infrequent use, allowing sewer gases to enter the room.	No water in trap.	Fill trap with water.
	Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Excess Moisture in Classrooms	Check for leaks (or signs of wetness) from plumbing or roof.	Stained ceiling tiles.	Maintenance to inspect for roof leak and repair as appropriate and replace ceiling tiles.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
Local Exhaust Fans	Confirm that fume hoods and local exhaust fans are used whenever activities that generate pollutants take place.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Local Exhaust Fans	Confirm that fume hoods and local exhaust fans function properly.	No air movement.	Install exhaust fan.
Thermal Comfort	General items to watch for.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
In the portables there is a mildew odor as well as a water stain on the ceiling.			