

Report: *Responsible Party***CASTLE HILL ELEMENTARY**

Walkthrough Date: 04/26/2006 Temp RH CO2

Outdoor Parameters: 92.6 53.1 390

Room	Priority	Responsible	Answer	Recommendation
005P	Inside Parameters:	Temp	RH	CO2
		76.7	40.6	1562

2 Site Dust observed on supply register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Room	Priority	Responsible	Answer	Recommendation
104	Inside Parameters:	Temp	RH	CO2
		76.4	60.8	1137

3 Site This is a general issue requiring approved communication among all stakeholders.

3 Site This is a general issue requiring approved communication among all stakeholders.

Room	Priority	Responsible	Answer	Recommendation
117	Inside Parameters:	Temp	RH	CO2
		72.2	69	837

3 Site This is a general issue requiring approved communication among all stakeholders.

Room	Priority	Responsible	Answer	Recommendation
120	Inside Parameters:	Temp 72.3	RH 54.2	CO2 911

3 Site This is a general issue requiring approved communication among all stakeholders.

Room	Priority	Responsible	Answer	Recommendation
132	Inside Parameters:	Temp 71.5	RH 56.4	CO2 803

2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
417	Inside Parameters:	Temp 69.7	RH 60.4	CO2 602

2 Site Dust observed on supply register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

3 Site This is a general issue requiring approved communication among all stakeholders.

Site based administration to encourage facility serviceperson staff to

- 2 Site Temperature was low at the time of assessment. adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
- 2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
554C	Inside Parameters:	Temp	RH	CO2
		81.5	45.2	1792

- 2 Site Temperature was elevated at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.