

Report: Site

CHALLENGER ELEMENTARY

Walkthrough Date: 03/28/2007 Temp RH CO2

Outdoor Parameters: 72.2 69.8 603

Room	Priority	Responsible	Answer	Recommendation
101E	Inside Parameters:	Temp 74.5	RH 43	CO2 1053
2	Site		Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
2	Site		Dust observed on supply register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
103	Inside Parameters:	Temp 72.9	RH 45.2	CO2 1093
3	Site		Room is the media center located directly across from the cafeteria. The smell is most likely a passive migration from the cafeteria.	This is not representative of an environmental issue. Staff should keep doors closed during lunch hours.
109	Inside Parameters:	Temp 72.8	RH 46.8	CO2 1122
3	Site		This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
3	Site		This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
131	Inside Parameters:	Temp 72	RH 50	CO2 732
2	Site		Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.

Room	Priority	Responsible	Answer	Recommendation
135	Inside Parameters:	Temp	RH	CO2
		73.7	49.4	709

3	Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
3	Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Answer	Recommendation
140	Inside Parameters:	Temp	RH	CO2
		73.2	50.4	774

3	Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
3	Site	There appears to be a general condition throughout the school with the window systems. There are not tight seals on all windows. However, it does appear to be problematic at this time.	Site based administration to monitor windows as necessary.

Room	Priority	Responsible	Answer	Recommendation
146	Inside Parameters:	Temp	RH	CO2
		73.2	50.4	774

3	Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
---	------	--	--

Room	Priority	Responsible	Answer	Recommendation
201	Inside Parameters:	Temp	RH	CO2
		73	49.6	1082

2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
---	------	--	---

Room	Priority	Responsible	Answer	Recommendation
	Inside			

202	Parameters:	Temp 73	RH 49.6	CO2 1082
2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.
Room	Priority	Responsible	Answer	Recommendation
203	Inside Parameters:	Temp 73.1	RH 49	CO2 1046
2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.
Room	Priority	Responsible	Answer	Recommendation
204	Inside Parameters:	Temp 73.1	RH 50	CO2 1017
2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.
Room	Priority	Responsible	Answer	Recommendation
214	Inside Parameters:	Temp 73.7	RH 50.8	CO2 775
2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.
2	Site	Dust and dirt accumulation on floor.		Facilities serviceperson to thoroughly clean and sanitize.
Room	Priority	Responsible	Answer	Recommendation
215	Inside Parameters:	Temp 73.1	RH 52.1	CO2 834
2	Site	No condensation observed at the time of assessment. However, two windows were open allowing humid untreated air into the classroom and could be cause of condensation.		Site based administration to encourage staff to keep doors and windows closed.
Room	Priority	Responsible	Answer	Recommendation
223	Inside Parameters:	Temp 72.5	RH 53.7	CO2 931

2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
3	Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Answer	Recommendation
225	Inside Parameters:	Temp	RH	CO2
		72.3	54.9	941

2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
2	Site	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.
2	Site	Supply vents closed/blocked at the time of assessment.	Facilities serviceperson to open supply vents.
2	Site	Windows and doors are operable and are not kept closed. Open doors and windows allow humid untreated air into occupied environment.	Site based administration to encourage staff to keep doors and windows closed.

Room	Priority	Responsible	Answer	Recommendation
226A	Inside Parameters:	Temp	RH	CO2
		73.5	52.3	979

2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
2	Site	Dust and debris on ceiling tiles at supply grills.	Facilities serviceperson to clean ceiling tiles at supply grills.
2	Site	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.
3	Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Answer	Recommendation
230	Inside Parameters:	Temp	RH	CO2
		74.1	48.1	963

1	Site	No exhaust fans in room. However, there was an odor from an air freshener.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.
---	------	--	--

Room	Priority	Responsible	Answer	Recommendation
232	Inside Parameters:	Temp	RH	CO2

		74.3	48.3	954
--	--	------	------	-----

- 2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.
- 2 Site Dust and dirt accumulation on floor. Facilities serviceperson to thoroughly clean and sanitize.

Room	Priority	Responsible	Answer	Recommendation
402	Inside Parameters:	Temp	RH	CO2
		72.3	47.1	1450

- 2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.
- 3 Site This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
- 3 Site This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Answer	Recommendation
402A	Inside Parameters:	Temp	RH	CO2
		0	0	0

- 3 Site This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
- 3 Site This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Answer	Recommendation
403	Inside Parameters:	Temp	RH	CO2
		72.4	47.1	1812

- 2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.
- 2 Site Dead bugs were observed near window systems. Site based administration should address general cleanliness with facility serviceperson staff.

Room	Priority	Responsible	Answer	Recommendation

421	Inside Parameters:	Temp	RH	CO2
		71.3	47.3	1147

- | | | | |
|---|------|--|--|
| 2 | Site | Slight dust accumulation was observed on environmental surfaces at the time of assessment. | Site based administration should address general cleanliness with facility serviceperson staff. |
| 3 | Site | This is a general issue requiring approved communication among all stakeholders. | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. |

Room	Priority	Responsible	Answer	Recommendation
423	Inside Parameters:	Temp	RH	CO2
		71.1	44.9	1297

- | | | | |
|---|------|--|---|
| 2 | Site | Slight dust accumulation was observed on environmental surfaces at the time of assessment. | Site based administration should address general cleanliness with facility serviceperson staff. |
| 2 | Site | Dust and dirt accumulation on floor. | Facilities serviceperson to thoroughly clean and sanitize. |