THE SCHOOL BOARD OF BROWARD COUNTY, FLORIDA ENVIRONMENTAL HEALTH & SAFETY DEPARTMENT

TELEPHONE (754) 321-4200

August 28, 2015	Signature	on	File
-----------------	-----------	----	------

TO: Katherine Good, Principal

Coconut Creek Elementary

FROM: Daniel Meyer, Project Manager

Environmental Health & Safety Department

SUBJECT: Indoor Air Quality (IAQ) Assessment

<u>Fo</u>	r Custodial Supervisor Use Only
	Custodial Issues Addressed
	Custodial Issues Not Addressed
-	

FACSIMILE: (754) 321-4285

On August 27, 2015, I conducted an assessment at **Coconut Creek Elementary School.** Attached are findings and recommendations for further assessment, remediation, or corrective actions needed.

The IAQ assessment did identify one or more existing conditions impacting IAQ and has generated appropriate work orders to correct deficiencies in systems and maintenance that could contribute to decreased indoor air quality. At the time of the assessment, these concerns were not an immediate health or safety concern to building occupants. However, due to individual sensitivities and predisposing health factors, it is possible that some building occupants may elicit a health response to agents and / or conditions identified during the evaluation. Therefore, to further improve IAQ, prevent development of future IAQ-related problems, and to reduce the potential for IAQ-related complaints by building occupants, the IAQ Assessment Team recommends appropriate follow up of each item identified and listed in the attached evaluation.

Please ensure that your Head Facilities Serviceperson receives a copy of this correspondence so that the recommendations requiring their attention can be addressed. In an attempt to separate IAQ issues from general maintenance items, the attached assessment may contain direction for site based staff to generate a work order through COMPASS. Within two weeks a representative from the Custodial/Grounds Department will conduct a follow-up visit to ensure that all site based custodial issues have been appropriately addressed.

Should any questions arise, or if the current concerns continue after the attached recommendations have been addressed, please feel free to contact us at 754-321-4200.

cc: Shelley Meloni, Director, Pre-Construction

Mark Dorsett, Manager, Zone 1, Physical Plant Operations Division

Broward Teachers Union

Federation of Public Employees

Gerald Devio, Supervisor II Custodial

Benjamin Osborne, Supervisor II Custodial

Rich Volipi, Supervisor II Custodial

Mark Murray, Supervisor II Custodial

Sam Bays, Director, Maintenance Operations

Kurt Wirz, Area Manager Trades

Clean HVAC supply and return grills with Wexcide	▼
	▼
	▼
	▼
	▼
	▼
	▼
	▼

Corrective Actions to be completed by 110	
Repair HVAC to Reduce Humidity Levels	▼
Repair Cause of Stained Ceiling Tiles	▼
Ceiling tile cuts needed around supply vents	▼
	▼
	▼
	▼
	▼
	▼