

Jeffrey S. Moquin, Director
Risk Management Department

Telephone: 754-321-3200
Facsimile: 754-321-3290

June 4, 2008

Signature on File

TO: Dr. Amanda Miles, Principal
Coral Park Elementary School

FROM: Edward See, Project Manager
Risk Management Department

SUBJECT: Indoor Air Quality (IAQ) Assessment
FISH 501, 503 and 506

For Custodial Supervisor Use Only	
<input type="checkbox"/>	Custodial Issues Addressed
<input type="checkbox"/>	Custodial Issues Not Addressed
<hr/>	
<hr/>	

On May 20, 2008 I conducted an assessment of FISH 501, 503 and 506 at **Coral Park Elementary School**. This evaluation included observations of the flooring system, ceiling tiles, false ceiling plenum, environmental surfaces, interior and exterior walls, and the accessible ventilation equipment. Additionally, environmental parameter measurements were taken to include temperature, relative humidity, and carbon dioxide. The detailed findings, along with the recommended corrective action can be found on the attached IAQ Assessment Worksheets.

Generally, the IAQ Assessment did not identify any existing conditions significantly impacting IAQ and thereby presenting immediate health and safety concerns to building occupants. However, due to individual sensitivities and predisposing health factors, it is possible that some building occupants may elicit a health response to agents and / or conditions identified during the evaluation. Therefore, to further improve IAQ, prevent development of future IAQ-related problems, and to reduce the potential for IAQ-related complaints by building occupants, the IAQ Assessment Team recommends appropriate follow up of each item identified and listed in the attached evaluation.

Please ensure that your Head Facilities Serviceperson receives a copy of this correspondence so that the recommendations requiring their attention can be addressed. Within two weeks a representative from the Custodial/Grounds Department will conduct a follow-up visit to ensure that all issues have been appropriately addressed.

Should any questions arise, or if the current concerns continue after the attached recommendations have been addressed, please feel free to contact me at 754-321-3200.

cc: Dr. Joanne Harrison, Area Superintendent
Jackie Haywood, Area Director
Jeffrey S. Moquin, Director, Risk Management
Denise Cone, Project Manager, Facilities and Construction Management
Gary Itzkowitz, Broward Teachers Union
Roy Jarrett, Federation of Public Employees
Mark Dorsett, Manager 1, Physical Plant Operations Division, Zone 1
Roy Norton, Manager Custodial/Grounds, Physical Plant Operations Division
Robert Krickovich, Coordinator, LEA, Facilities and Construction Management

ES/tc
Enc.

IAQ Assessment

Location Number 3041

Coral Park Elementary School

Evaluation Requested May 7, 2008

Time of Day 12:40 pm

Evaluation Date May 20, 2008

Outdoor Conditions Temperature 87.3 Relative Humidity 66.8 Ambient CO2 462

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
501	77.2	72 - 78	56.4	30% - 60%	657	Max 700 > Ambient	21
Noticeable Odor		Visible water damage / staining?		Visible microbial growth?		Amount of material affected	
Ceiling Type		No		No		None	
Wall Type		No		No		None	
Flooring		No		No		None	

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> No	
Walls	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> No	
Flooring	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> No	
HVAC Supply Grills	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> No	
HVAC Return Grills	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> No	
Ceiling at Supply Grills	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> No	
Surfaces in Room	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> No	

Observations

Findings:
 - Occupants complained of odors in the past. New A/C ducts, painting, new ceiling tiles, etc. Possible off gassing from new materials.
 - No issues identified at the time of the assessment

Recommendations:

Site Based Maintenance:
 - Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate

IAQ Assessment

Location Number 3041

Coral Park Elementary School

Evaluation Requested May 7, 2008

Time of Day 12:40 pm

Evaluation Date May 20, 2008

Outdoor Conditions Temperature 87.3 Relative Humidity 66.8 Ambient CO2 462

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
503	74.2	72 - 78	57.9	30% - 60%	777	Max 700 > Ambient	2
Noticeable Odor		Visible water damage / staining?		Visible microbial growth?		Amount of material affected	
Ceiling Type		No		No		None	
Wall Type		No		No		None	
Flooring		No		No		None	

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> No	
Walls	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> No	
Flooring	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> No	
HVAC Supply Grills	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> No	
HVAC Return Grills	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> No	
Ceiling at Supply Grills	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> No	
Surfaces in Room	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> No	

Observations

Findings:
 - Occupants complained of odors in the past. New A/C ducts, painting, new ceiling tiles, etc. Possible off gassing from new materials.
 - No issues identified at the time of the assessment

Recommendations:

Site Based Maintenance:
 - Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate

IAQ Assessment

Coral Park Elementary School

Location Number
 Evaluation Requested
 Evaluation Date

Time of Day

Outdoor Conditions Temperature Relative Humidity Ambient CO2

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
<input type="text" value="506"/>	<input type="text" value="77.8"/>	<input type="text" value="72 - 78"/>	<input type="text" value="50.3"/>	<input type="text" value="30% - 60%"/>	<input type="text" value="802"/>	<input type="text" value="Max 700 > Ambient"/>	<input type="text" value="20"/>
Noticeable Odor		Visible water damage / staining?		Visible microbial growth?		Amount of material affected	
<input type="text" value="No"/>		<input type="text" value="No"/>		<input type="text" value="No"/>		<input type="text" value="None"/>	
Ceiling Type	<input type="text" value="2 x 4 Lay In"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		
Wall Type	<input type="text" value="Plaster/Drywall"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		
Flooring	<input type="text" value="12 x 12 Vinyl"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Walls	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Flooring	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Return Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Ceiling at Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Surfaces in Room	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>

Observations

Findings:
 - Occupants complained of odors in the past. New A/C ducts, painting, new ceiling tiles, etc. Possible off gassing from new materials.
 - No issues identified at the time of the assessment

Recommendations:

Site Based Maintenance:
 - Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate