

Tools for Schools - Indoor Air Quality

Follow-up Action Plan for Site

Coral Springs Elementary

69.2 35% 390

Principal: Dr. Frances (Rene) Shaw



Walkthrough Date: 4/14/2004

Temp RH Co2
Outside Measurements

Assignment Member: Aston Henry

Room	Priority	Responsible	Assessment Comments	Recommended Corrective Action
119E	2	Site	Dust and debris was observed on the return registers at the time of the assessment.	Custodial staff should clean and sanitize the return registers in this classroom.
121C	2	Site	Dust and debris was observed on the air supply and return registers at the time of the assessment. Dirty ceiling tiles and walls.	Custodial staff should clean and sanitize the air supply and return registers in this classroom and clean ceiling tiles and walls.
125	2	Site	Dust and debris was observed on the air supply diffuser. Stained ceiling tile.	Custodial staff should clean and sanitize the air supply diffuser and replace stained ceiling tile.
126	3	Site	Minor dust on air supply and missing ceiling tile.	Clean air supply and replace missing ceiling tile.
127	3	Site	Stained ceiling tiles.	Install new ceiling tiles.
131	2	Site	Dust and debris was observed on the air supply and return registers at the time of the assessment. Stained ceiling tiles.	Custodial staff should clean and sanitize the air supply and return registers in this classroom and replace ceiling tiles.
134	2	Site	Dust and debris was observed on the air supply and return registers at the time of the assessment. Stained ceiling tile.	Custodial staff should clean and sanitize the air supply and return registers in this classroom and replace ceiling tile.
138	3	Site	Stained ceiling tiles. Old roof leak has been repaired.	Install new ceiling tiles.
143	2	Site	Dust and debris was observed on the air supply and return registers at the time of the assessment.	Custodial staff should clean and sanitize the air supply and return registers in this classroom.
144	3	Site	Stained ceiling tiles.	Install new ceiling tiles.
146	3	Site	General cleanliness appeared adequate on date of assessment. Dust on ceiling tiles.	Clean ceiling tiles.
147	2	Site	Dust and debris was observed on the air supply and return registers at the time of the assessment.	Custodial staff should clean and sanitize the air supply and return registers in this classroom.
159	2	Site	Dust and debris was observed on the air supply and return registers at the time of the assessment.	Custodial staff should clean and sanitize the air supply and return registers in this classroom.
302	2	Site	no animals in the classroom. But, air freshner was in classroom.	Remove air freshner.
309	3	Site	Dirty ceiling tiles around air supply.	Install new ceiling tiles.
311	3	Site	Dirty ceiling tiles around air supply.	Install new ceiling tiles.