

<b>0101</b>	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
	<input type="text"/>	<input type="text"/>	<input type="text"/>	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	Exterior Inspection	Check for attic leaks.	Indicated identified these items inadvertently. No problems were identified at time of inspection.	No corrective action recommended at this time.
	Dust Control	Purchase and maintain barrier floor mats for all school entrances.	School wants mats.	Site to contact District Maintenance.
	Exterior Inspection	General considerations for roof.	Drains in penthouse sometimes leak to rooms below.	Maintenance to inspect condensate drains and repair as appropriate.
	Floor Cleaning	General items to watch for.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Dust Control	Purchase and maintain barrier floor mats for all school entrances.	School wants mats.	See previous entry for same area.
	Exterior Inspection	Check for attic leaks.	Indicated identified these items inadvertently. No problems were identified at time of inspection.	No corrective action recommended at this time.
	Moisture, Leaks, and Spills	Inspect the building for signs of moisture, leaks, or spills.	Indicated identified these items inadvertently. No problems were identified at time of inspection.	No corrective action recommended at this time.
	Moisture, Leaks, and Spills	Look for signs of water damage.	Indicated identified these items inadvertently. No problems were identified at time of inspection.	No corrective action recommended at this time.
	Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No longer a problem.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly	No longer a problem.	No corrective action recommended at this time.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
<b>106</b>	Exterior Inspection	Check building drainage.	No longer a problem.	No corrective action recommended at this time.
		<input type="text"/>		
	<input type="text" value="77"/> <i>Temp</i>	<input type="text" value="43%"/> <i>RH</i>	<input type="text"/>	<i>Co2</i>
<b>107</b>	Dust Control	Vacuum dust from heating, cooling, and ventilation air return grilles and air supply vents periodically.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
		<input type="text" value="Dania is one of the cleanest schools to which I have ever been assigned."/>		
	<input type="text" value="75"/> <i>Temp</i>	<input type="text" value="44%"/> <i>RH</i>	<input type="text"/>	<i>Co2</i>
<b>108</b>	General Cleanliness	confirm that the office area is cleaned properly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Check for pests.	No longer a problem.	No corrective action recommended at this time.
	Printing/Duplicating Equipment	confirm that the equipment functions properly.	No longer a problem.	No corrective action recommended at this time.
		<input type="text"/>		
	<input type="text"/>	<input type="text"/>	<input type="text"/>	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	General Activities	Clean spills promptly.	Carpeting is stained.	Clean and sanitize carpeting.
	General Classroom Information		Custodian states that windows were installed inside out. There are signs of water intrusion at all windows.	Maintenance to inspect for leaks and repair as appropriate.
	General Cleanliness	Check for pests.	No longer a problem.	No corrective action recommended at this time.
	Thermal Comfort	Humidity level.	The humidity was 45% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>	
<b>116</b>	<div style="border: 1px solid black; width: 100%; height: 20px; margin-bottom: 5px;"></div> <div style="display: flex; justify-content: space-around;"> <div style="border: 1px solid black; padding: 2px 10px;">75</div> <div style="border: 1px solid black; padding: 2px 10px;">45%</div> <div style="border: 1px solid black; padding: 2px 10px;"></div> </div> <p style="text-align: center;"><i>Temp</i>      <i>RH</i>      <i>Co2</i></p>			
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
<b>119</b>	<div style="border: 1px solid black; width: 100%; height: 20px; margin-bottom: 5px;"></div> <div style="display: flex; justify-content: space-around;"> <div style="border: 1px solid black; padding: 2px 10px;">72</div> <div style="border: 1px solid black; padding: 2px 10px;">46%</div> <div style="border: 1px solid black; padding: 2px 10px;"></div> </div> <p style="text-align: center;"><i>Temp</i>      <i>RH</i>      <i>Co2</i></p>			
	General Cleanliness	Confirm that the classroom is cleaned properly	Minor dust accumulation was observed on environmental surfaces in the media center.	Custodial staff should thoroughly clean all environmental surfaces within classroom. Clean and sanitize carpeting.
<b>119B</b>	<div style="border: 1px solid black; width: 100%; height: 20px; margin-bottom: 5px;"></div> <div style="display: flex; justify-content: space-around;"> <div style="border: 1px solid black; padding: 2px 10px;">71</div> <div style="border: 1px solid black; padding: 2px 10px;">47%</div> <div style="border: 1px solid black; padding: 2px 10px;"></div> </div> <p style="text-align: center;"><i>Temp</i>      <i>RH</i>      <i>Co2</i></p>			
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
<b>119D</b>	<div style="border: 1px solid black; width: 100%; height: 20px; margin-bottom: 5px;"></div> <div style="display: flex; justify-content: space-around;"> <div style="border: 1px solid black; padding: 2px 10px;">72</div> <div style="border: 1px solid black; padding: 2px 10px;">46%</div> <div style="border: 1px solid black; padding: 2px 10px;"></div> </div> <p style="text-align: center;"><i>Temp</i>      <i>RH</i>      <i>Co2</i></p>			
	Industrial and Vocational Education Supplies	Learn about your supplies.	No industrial supplies. Only duplicating and laminating equipment.	No corrective action recommended at this time.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
120				
	Temp	RH	Co2	
	Thermal Comfort	Humidity level.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
122				
	Temp	RH	Co2	
	75	49%		
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
123				
	Temp	RH	Co2	
	74	50%		
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	Room is under penthouse and ceiling tiles are stained at HVAC grills.	Maintenance to inspect drainage and repair as appropriate and replace ceiling tiles.
	General Classroom Information		Carpeting and floor tile is stained.	Clean and sanitize carpeting and floor tile.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Interior Inspection	General maintenance items.	Return air grill missing and screws are hanging from ceiling.	Maintenance to inspect and repair as appropriate.
	Interior Inspection	Check preventative indoor items.	Art supplies under sink and moss in a bag that is wet and moldy. Custodian advised to remove.	Remove items.
	Interior Inspection	General considerations for classrooms and other areas.	Water standing on counter at sink.	Clean spills promptly.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
<b>124</b>	74 <i>Temp</i>	48% <i>RH</i>		
	Drain Traps in the Classroom	Drain traps, if present, can become a problem when the water in the drain trap evaporates due to infrequent use, allowing sewer gases to enter the room.	Trap is wet. Water found on counter around sink.	Clean spills promptly.
	General Classroom Information		Glade plug in found at computer station.	Remove plug in.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Clean spills promptly.	Carpet and flooring stained.	Clean and sanitize carpeting and flooring.
<b>127</b>	74 <i>Temp</i>	49% <i>RH</i>		
	Health and Hygiene Education	Provide information about IAQ and health.	Teacher indicated she identified these items inadvertently. No problems were identified at time of inspection.	No corrective action recommended at this time.
	Health and Hygiene Education	Inform students and staff about the importance of good hygiene in preventing the spread of airborne contagious diseases.	Teacher indicated she identified these items inadvertently. No problems were identified at time of inspection.	No corrective action recommended at this time.
	Health and Hygiene Education	Obtain Indoor Air Quality: An introduction for health professionals.	Teacher indicated she identified these items inadvertently. No problems were identified at time of inspection.	No corrective action recommended at this time.
	Health and Hygiene Education	Establish an information and counseling program regarding smoking.	Teacher indicated she identified these items inadvertently. No problems were identified at time of inspection.	No corrective action recommended at this time.
	Health Officer's Office	Ensure that the ventilation system is properly operating.	Teacher indicated she identified these items inadvertently. No problems were identified at time of inspection.	No corrective action recommended at this time.
	Maintain Student Health Records	Recognize indicators that health problems may be IAQ-related.	Teacher indicated she identified these items inadvertently. No problems were identified at time of inspection.	No corrective action recommended at this time.
	Maintain Student Health Records	Track health-related complaints by students and staff.	Teacher indicated she identified these items inadvertently. No problems were identified at time of inspection.	No corrective action recommended at this time.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
128	Maintain Student Health Records	Include information about sensitivities to IAQ problems in student health records.	Teacher indicated she identified these items inadvertently. No problems were identified at time of inspection.	No corrective action recommended at this time.
	74	50%		
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
131	General Classroom Information		Room is too cluttered to clean properly.	No corrective action recommended at this time.
	General Classroom Information		Sink faucet is leaking.	Maintenance to inspect for leak and repair as appropriate.
	Maintain Student Health Records	Recognize indicators that health problems may be IAQ-related.	Teacher indicated she identified these items inadvertently. No problems were identified at time of inspection.	No corrective action recommended at this time.
	73	49%		
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
132	Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly	Dust accumulation was observed on environmental surfaces. Carpet and floor tile stained.	Custodial staff should thoroughly clean all environmental surfaces within classroom. Clean and sanitize carpeting and flooring.
	74	49%		
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	General Classroom Information		Water standing on counter at sink.	Custodial staff should caulk all counters at sinks or call in a work order.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
133	Health and Hygiene Education	Obtain Indoor Air Quality: An introduction for health professionals.	Teacher indicated she identified these items inadvertently. No problems were identified at time of inspection.	No corrective action recommended at this time.
	Maintain Student Health Records	Track health-related complaints by students and staff.	Teacher indicated she identified these items inadvertently. No problems were identified at time of inspection.	No corrective action recommended at this time.
	74	48%		
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
301	General Cleanliness	Confirm that the classroom is cleaned properly	Minor dust accumulation was observed on environmental surfaces. Carpet and flooring stained. Standing water at sink counter.	Custodial staff should thoroughly clean all environmental surfaces within classroom. Clean and sanitize flooring. Caulk counters at sink or call in work order.
	75	51%		
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
308	General Classroom Information		Carpeting is stained.	Clean and sanitize carpeting.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	73	49%		
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	General Classroom Information		Faucet at sink is leaking.	Maintenance to inspect for leak and repair as appropriate.
	General Classroom Information		Carpeting is stained.	Clean and sanitize carpeting.
	General Classroom Information		Water standing on counter at sink.	Clean spills promptly.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
	Health and Hygiene Education	Obtain Indoor Air Quality: An introduction for health professionals.	Teacher indicated she identified these items inadvertently. No problems were identified at time of inspection.	No corrective action recommended at this time.
	Health and Hygiene Education	Inform students and staff about the importance of good hygiene in preventing the spread of airborne contagious diseases.		
	Health Officer's Office	Ensure that the ventilation system is properly operating.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Maintain Student Health Records	Track health-related complaints by students and staff.	Teacher indicated she identified these items inadvertently. No problems were identified at time of inspection.	No corrective action recommended at this time.
	Maintain Student Health Records	Recognize indicators that health problems may be IAQ-related.	Water damage at windows.	Maintenance to inspect for leaks and repair as appropriate.
<b>311</b>		I cough.		
	73	50%		
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	General Classroom Information		Water standing on counter at sink.	Clean spills promptly.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
<b>313</b>				
	74	51%		
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	General Classroom Information		Faucet at sink leaking.	Maintenance to inspect for leak and repair as appropriate.
	General Classroom Information		Water standing on counter at sink.	Clean spills promptly.
	General Classroom Information		carpeting is stained.	Clean and sanitize carpeting.
	Health and Hygiene Education	Inform students and staff about the importance of good hygiene in preventing the spread of airborne contagious diseases.	Teacher indicated she identified these items inadvertently. No problems were identified at time of inspection.	No corrective action recommended at this time.



	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
	Health and Hygiene Education	Provide information about IAQ and health.	Teacher indicated she identified these items inadvertently. No problems were identified at time of inspection.	No corrective action recommended at this time.
	Health and Hygiene Education	Establish an information and counseling program regarding smoking.	Teacher indicated she identified these items inadvertently. No problems were identified at time of inspection.	No corrective action recommended at this time.
	Health and Hygiene Education	Obtain Indoor Air Quality: An introduction for health professionals.	Teacher wants more training for students on health and hygiene.	Site based administration will provide information to site based staff.
	Maintain Student Health Records	Track health-related complaints by students and staff.	Teacher indicated she identified these items inadvertently. No problems were identified at time of inspection.	No corrective action recommended at this time.
	Maintain Student Health Records	Include information about sensitivities to IAQ problems in student health records.	Teacher indicated she identified these items inadvertently. No problems were identified at time of inspection.	No corrective action recommended at this time.
	I have problems daily when I leave school with my breathing. Examples: I feel like I have major allergies - symptoms appear when I leave.			
<b>317</b>	75	50%		
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	General Classroom Information		Water standing on counter at sink.	Clean spills promptly.
	General Classroom Information		Carpeting is stained and torn.	Clean and sanitize carpeting.
	Maintain Student Health Records	Include information about sensitivities to IAQ problems in student health records.	Teacher indicated she identified these items inadvertently. No problems were identified at time of inspection.	No corrective action recommended at this time.
	Maintain Student Health Records	Recognize indicators that health problems may be IAQ-related.	Teacher wants information no IAQ and Health.	Site based administration will provide information to site based staff.
	Sinusitis and coughing disappear on Friday evening and reoccur every Monday morning.			
<b>319</b>	74	49%		
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	General Classroom Information		Tackboard under window is water stained.	Maintenance to inspect for leak and repair as appropriate and replace tackboard.
	General Classroom Information		Water standing on counter at sink.	Clean spills promptly.
	General Classroom Information		carpeting is stained.	Clean and sanitize carpeting.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
501	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
		<div style="display: flex; justify-content: space-around;"> <div style="border: 1px solid black; padding: 2px;">76</div> <div style="border: 1px solid black; padding: 2px;">50%</div> <div style="border: 1px solid black; padding: 2px; width: 40px;"></div> </div> <p style="text-align: center;"><i>Temp</i>      <i>RH</i>      <i>Co2</i></p>		
503	General Classroom Information		Water standing on counter at sink.	Clean spills promptly.
	Thermal Comfort	General items to watch for.	Teacher reported the room is generally hotter than surrounding rooms. Temperature was within recommended range.	Maintenance needs to inspect HVAC for proper operation.
		<div style="display: flex; justify-content: space-around;"> <div style="border: 1px solid black; padding: 2px;">74</div> <div style="border: 1px solid black; padding: 2px;">48%</div> <div style="border: 1px solid black; padding: 2px; width: 40px;"></div> </div> <p style="text-align: center;"><i>Temp</i>      <i>RH</i>      <i>Co2</i></p>		
504	General Classroom Information		Wall damaged at refrigerator.	Maintenance to inspect for roof leak and repair as appropriate.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Clean spills promptly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Ventilation	Check for unexplained odors.	There are two aquariums in the room -- 1 with fish and 1 with turtles. No odor was identified at time of assessment.	No corrective action recommended at this time.
		<div style="display: flex; justify-content: space-around;"> <div style="border: 1px solid black; padding: 2px;">76</div> <div style="border: 1px solid black; padding: 2px;">48%</div> <div style="border: 1px solid black; padding: 2px; width: 40px;"></div> </div> <p style="text-align: center;"><i>Temp</i>      <i>RH</i>      <i>Co2</i></p>		
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	Cabinet is water damaged.	Maintenance to inspect for leaks and repair as appropriate.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
General Classroom Information		Water standing on counter at sink.	Clean spills promptly.