

# RISK MANAGEMENT...

managing risk with responsibility

Jeffrey S. Moquin, Director  
Risk Management Department

Telephone: 754-321-3200  
Facsimile: 754-321-3290

September 6, 2007

**Signature on File**

TO: Ms. Angela Fulton,, Principal  
**Dillard Elementary School**

FROM: Robert Krickovich, Coordinator, LEA  
Facilities and Construction Management

SUBJECT: Indoor Air Quality (IAQ) Assessment  
**FISH 203 and 521**

<u>For Custodial Supervisor Use Only</u>	
<input type="checkbox"/>	Custodial Issues Addressed
<input type="checkbox"/>	Custodial Issues Not Addressed
_____	
_____	

On August 31, 2007 I conducted an assessment of FISH 203 and 521 at **Dillard Elementary School**. This evaluation included observations of the flooring system, ceiling tiles, false ceiling plenum, environmental surfaces, interior and exterior walls, and the accessible ventilation equipment. Additionally, environmental parameter measurements were taken to include temperature, relative humidity, and carbon dioxide. The detailed findings, along with the recommended corrective action can be found on the attached IAQ Assessment Worksheets.

The IAQ assessment did identify one or more existing conditions impacting IAQ and has generated appropriate work orders to correct deficiencies in systems and maintenance that could contribute to decreased indoor air quality. At the time of the assessment, these concerns were not an immediate health or safety concern to building occupants. However, due to individual sensitivities and predisposing health factors, it is possible that some building occupants may elicit a health response to agents and / or conditions identified during the evaluation. Therefore, to further improve IAQ, prevent development of future IAQ-related problems, and to reduce the potential for IAQ-related complaints by building occupants, the IAQ Assessment Team recommends appropriate follow up of each item identified and listed in the attached evaluation.

*Please ensure that your Head Facilities Serviceperson receives a copy of this correspondence so that the recommendations requiring their attention can be addressed. Within two weeks a representative from the Custodial/Grounds Department will conduct a follow-up visit to ensure that all issues have been appropriately addressed.*

Should any questions arise, or if the current concerns continue after the attached recommendations have been addressed, please feel free to contact me at 754-321-1638.

cc: Dr. Verda Farrow, Area Superintendent  
Michaelle Pope, Area Director  
Jeffrey S. Moquin, Director, Risk Management  
Frank Alfieri, Project Manager, Facilities and Construction Management  
Charles Ricks, Project Manager, Facilities and Construction Management  
Dane Ramson, Broward Teachers Union  
Roy Jarrett, National Federation of Public and Private Employees  
Mark Dorsett, Manager 1, Physical Plant Operations Division, Zone 1  
Roy Norton, Manager Custodial/Grounds, Physical Plant Operations Division

RK/tc  
Enc.

# IAQ Assessment

Dillard Elementary School

Location Number

Evaluation Requested

Time of Day

Evaluation Date

Outdoor Conditions      Temperature       Relative Humidity       Ambient CO2

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
<input type="text" value="203"/>	<input type="text" value="75.1"/>	<input type="text" value="72 - 78"/>	<input type="text" value="48.6"/>	<input type="text" value="30% - 60%"/>	<input type="text" value="1396"/>	<input type="text" value="Max 700 &gt; Ambient"/>	<input type="text" value="24"/>
Noticeable Odor		Visible water damage / staining?		Visible microbial growth?		Amount of material affected	
<input type="text" value="No"/>		<input type="text" value="No"/>		<input type="text" value="No"/>		<input type="text" value="None"/>	
Ceiling Type	<input type="text" value="2 x 2 Lay In"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		
Wall Type	<input type="text" value="Tackboard"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		
Flooring	<input type="text" value="12 x 12 Vinyl"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Walls	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Flooring	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Return Grills	<input type="text" value="No"/>	<input type="text" value="Yes"/>	<input type="text" value="Yes"/>	<input type="text" value="Clean with Wexcide disinfectant"/>
Ceiling at Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Surfaces in Room	<input type="text" value="No"/>	<input type="text" value="Yes"/>	<input type="text" value="Yes"/>	<input type="text" value="Clean as appropriate"/>

**Observations**

**Findings:**

- Dust and debris on HVAC return grills
- Dust build up on environmental surfaces
- CO2 level was slightly elevated

**-Recommendations:**

**Site Based Maintenance:**

- Clean HVAC return grills with Wexcide disinfectant solution
- Clean all surfaces throughout the room
- Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate

**Physical Plant Operations:**

- Evaluate fresh air dampers for proper operation and repair as appropriate to lower CO2 level

# IAQ Assessment

Location Number

Dillard Elementary School

Evaluation Requested

Time of Day

Evaluation Date

Outdoor Conditions      Temperature       Relative Humidity       Ambient CO2

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
<input type="text" value="521"/>	<input type="text"/>	<input type="text" value="72 - 78"/>	<input type="text"/>	<input type="text" value="30% - 60%"/>	<input type="text"/>	<input type="text" value="Max 700 &gt; Ambient"/>	<input type="text"/>
Noticeable Odor	<input type="text" value="No"/>		Visible water damage / staining?	Visible microbial growth?	Amount of material affected		
Ceiling Type	<input type="text" value="Plaster"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		
Wall Type	<input type="text" value="Plaster"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		
Flooring	<input type="text" value="Quarry Tile"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Walls	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Flooring	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Supply Grills	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text" value="N/A"/>
HVAC Return Grills	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text" value="N/A"/>
Ceiling at Supply Grills	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text" value="N/A"/>
Surfaces in Room	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>

**Observations**

**Findings: (Kitchen Can Wash Room)**  
 - Complaint of reoccurring microbial growth on wall surfaces. None visible at the time of the assessment. However, room was damp and humid.

**-Recommendations:**  
**Site Based Maintenance:**  
 - Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate

**Physical Plant Operations:**  
 - Evaluate exhaust fan for proper operation. Room is very damp and humid.