

# Dillard Elementary

Outdoor Parameter Measurements:

WalkthroughDate: 4/14/2004

Temp

RH

Co2

68.6

43%

	Category	Detail	Assessment Comments	Recommended Corrective Action
101	<input type="text"/>	<input type="text"/>	<input type="text"/>	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	Health and Hygiene Education	Provide information about IAQ and health.		Site based administration will provide information to site based staff.
111	<input type="text"/>	<input type="text"/>	<input type="text"/>	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	Excess Moisture	Check for condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the office area is cleaned properly.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	Printing/Duplicating Equipment	Minimize staff and student exposure to equipment.		Site based administration will provide information to site based staff.
	Thermal Comfort	Check comfort factors.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
	Thermal Comfort	Humidity level.	The humidity was 54% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.
	Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
112	<input type="text"/>	<input type="text"/>	<input type="text"/>	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	General Classroom Information		There were no signs of microbial growth in this office.	No corrective action recommended at this time.

	<i>Category</i>		<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
<b>115</b>	69.2	63.3	987		
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>		
	General Classroom Information			There were no signs of microbial growth in this office. Humidity is slightly elevated.	Staff was advised to raise the temperature up to 72 degrees.
<b>122</b>					
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>		
	Animals in Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.	
	Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.	
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.	
	General Cleanliness	Clean spills promptly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.	
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.	
	General Cleanliness	Confirm that the classroom is cleaned properly.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.	
	Local Exhaust Fans	General Items.	There were no problems observed at time of assessment.	No corrective action recommended at this time.	
	Thermal Comfort	General items to watch for.	There were no problems observed at time of assessment.	No corrective action recommended at this time.	
	Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.	
	Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.	
	Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.	
	Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.	
<p>I am constantly sick and hospitalized with asthma from whatever is going through the air vents. When I was home in the summer, I was not sick one day. I have doctor notes to prove it. As soon as this school year started up, I was in the hospital for 6 days. I changed my room, but I guess that the mold and mildew problem is in the air.</p>					

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
<b>124</b>	73.3 <i>Temp</i>	51% <i>RH</i>		
	General Cleanliness	Clean spills promptly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly.	General cleanliness appeared adequate on date of assessment. Live plants were observed in room.	No corrective action recommended at this time.
	General Cleanliness	Check for pests.	Teacher reported that there are ants at times.	Maintenance needs to establish work order to inspect room for pests and implement appropriate corrective action.
	Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
<b>129</b>	73.1 <i>Temp</i>	52% <i>RH</i>		
	General Classroom Information		Dust and debris was observed on the A/C coils.	Clean and sanitize A/C coils.
	General Classroom Information		Carpeting is stained and soiled and has a musty odor.	Replace carpeting.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Thermal Comfort	Humidity level.	The humidity was 52% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.
	Ventilation	Check for unexplained odors.	There is a distinct odor when entering the room. Air freshener found in room.	Remove air freshener from room.
	<p>I have a bad problem in my room with mosquitos, ants and spiders. In the morning upon arriving, approximately 10-15 mosquitos are waiting on the ceiling right outside the classroom door to enter the room. Throughout the day 11 classes are in and out of this room and the students and myself are getting bit up. I am concerned about contracting an infectious disease in this manner. Upon voicing my concerns, I was told to purchase bug spray, but I don't feel that it is my responsibility to have to purchase the spray so often. I have repeatedly asked for help with this problem, but nothing has been resolved. Also, there seems to be an unexplicable musty, mold smell in the room that everyone in the school complains about and on a daily basis I spray air freshener to relieve the problem.</p>			

	<i>Category</i>		<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
<b>136</b>	73.3 <i>Temp</i>	53% <i>RH</i>	 <i>Co2</i>		
	Excess Moisture in Classrooms		Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Classroom Information			Ceiling tiles are stained.	Maintenance to inspect for roof leak and repair as appropriate and replace ceiling tiles.
	General Classroom Information			Additional walkthrough of this room was done on 8/11/04 and water, condensation and microbial growth was identified on the hood range over the stove. Tackable wall surface directly underneath the hood range is damaged. Bubbling paint on south wall.	Maintenance to inspect and repair as appropriate.
	General Classroom Information			Fresh air damper is 80% closed.	Maintenance needs to inspect HVAC for proper operation.
	General Classroom Information			Unapproved chemicals in room.	Remove unapproved chemicals.
	General Classroom Information			Another visit was made to this room on 8/11/04 and the temperature was 67.9 and the humidity was 64.7%.	Site was advised to raise the temperature to 72 degrees.
	General Cleanliness		Confirm that the classroom is cleaned properly.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	General Cleanliness		Check for pests.	There were no problems observed at time of assessment. Food items in cabinets.	No corrective action recommended at this time.
	Thermal Comfort		Humidity level.	The humidity was 53% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.
	Thermal Comfort		General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
	Ventilation		If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.
	Ventilation		If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
	Ventilation		Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
<b>137</b>	71.6 <i>Temp</i>	54% <i>RH</i>		
	Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	Wall behind stove is warped. Appears to be a leak. Additional walkthrough of this room was done on 8/11/04 and microbial growth was found in cabinet over the stove and condensation is forming.	Maintenance to inspect for leak and repair as appropriate.
	General Classroom Information		Fresh air damper is closed.	Maintenance needs to inspect HVAC for proper operation.
	General Classroom Information		Paint supplies found under cabinet.	Remove unapproved supplies.
	General Cleanliness	Confirm that the classroom is cleaned properly.	Carpeting is stained.	Replace carpeting.
	Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
<b>138</b>				
	General Classroom Information		Walkthrough of this room was done on 8/11/04 and rear wall (directly under window) shows signs of microbial growth.	Maintenance to inspect and repair as appropriate.
<b>139</b>	70.6 <i>Temp</i>	51% <i>RH</i>		
	Animals in Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	Signs of water intrusion on exterior wall. Paint is bubbling.	Maintenance to inspect for leak and repair as appropriate.
	General Classroom Information		Mechanical room roof has signs of mold.	Maintenance to inspect for leak and repair/remediate as appropriate.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
General Cleanliness	Clean spills promptly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly.	Carpeting is stained.	Replace carpeting.
General Cleanliness	Check for pests.	Pests found outside exterior wall.	Maintenance needs to establish work order to inspect room for pests and implement appropriate corrective action.
Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm at air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
Ventilation	Determine how your classroom is ventilated.	Fresh air damper is 90% closed.	Maintenance needs to inspect HVAC for proper operation.
<b>139C</b>			
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>
	General Information		
		This is a mechanical room. Walkthrough done on 8/11/04 shows microbial growth on the ceiling drywall throughout.	Maintenance to inspect and repair as appropriate.
<b>142</b>	74.3	55%	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>
	General Classroom Information		
		Carpeting is stained.	Replace carpeting.
General Classroom Information		Fan over stove is constantly running.	Maintenance to inspect and repair as appropriate.
General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Ventilation	Check for unexplained odors.	Potting soil, scented candle, and sofa in room.	Remove items from room.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
<b>200</b>	73.8 <i>Temp</i>	49% <i>RH</i>	<i>Co2</i>	
	Animals in Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
	Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Classroom Information		Carpeting is stained.	Replace carpeting.
	General Classroom Information		Unauthorized chemicals in room.	Remove unauthorized chemicals.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment. Fresh air damper is closed. Drain pan clogged.	Maintenance needs to inspect HVAC for proper operation.
<b>201</b>	73.1 <i>Temp</i>	51% <i>RH</i>	<i>Co2</i>	
	Animals in Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
	General Classroom Information		Carpeting is stained.	Replace carpeting.
	General Classroom Information		Roaches in room.	Maintenance needs to establish work order to inspect room for pests and implement appropriate corrective action.
	General Classroom Information		Unauthorized chemicals and magazine rack in room.	Remove items from room.
	Industrial and Vocational Education Supplies	Learn about your supplies.		Site based administration will provide information to site based staff.
	Thermal Comfort	Humidity level.	The humidity was 51% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
<b>202</b>	72	50%		
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	General Classroom Information		Fresh air vent is closed. Water is pooling in drain pan.	Maintenance needs to inspect HVAC for proper operation.
	General Classroom Information		Ceiling tiles misaligned.	Repair ceiling tiles.
	General Classroom Information		Scented candle and live plants in room.	Remove items from room.
	General Cleanliness	Confirm that the classroom is cleaned properly.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
<b>203</b>	73.3	54%		
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	General Classroom Information		Access panel in need of repair.	Maintenance to inspect and repair as appropriate.
	General Classroom Information		Unauthorized chemicals, live plants and air freshener in room.	Remove items from room.
	General Cleanliness	Clean spills promptly.	Carpeting is stained.	Replace carpeting.
<b>206</b>	73.1	51%		
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	Animals in Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
	Drain Traps in the Classroom	Drain traps, if present, can become a problem when the water in the drain trap evaporates due to infrequent use, allowing sewer gases to enter the room.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Classroom Information		Unauthorized chemicals in room.	Remove chemicals.
	General Cleanliness	Clean spills promptly.	Carpeting is stained.	Replace carpeting.



<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.
Ventilation	Determine how your classroom is ventilated.	Fresh air vent is closed. Water is pooling in drain pan.	Maintenance needs to inspect HVAC for proper operation.

207

72.4	52%	
<i>Temp</i>	<i>RH</i>	<i>Co2</i>

Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Classroom Information		Windows have been repaired.	No corrective action recommended at this time.
General Classroom Information		Unauthorized chemicals in room.	Remove chemicals.
General Cleanliness	Confirm that the classroom is cleaned properly.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
Thermal Comfort	Humidity level.	The humidity was 52% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.
Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.

I have windows that do not close properly. What should be the regular interval cleaning air vents and champoing carpets?

209

73.1	51%	
<i>Temp</i>	<i>RH</i>	<i>Co2</i>

Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
-------------------------------	--	--	--

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly.	Carpeting is stained.	Replace carpeting.
Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.

210

<i>Temp</i>	<i>RH</i>	<i>Co2</i>	

Animals in Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Clean spills promptly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.

212

	It is difficult to have custodians come and change the temperature on cool/cold days for the classroom air conditioner. Although the temperature is changed, it is difficult to get the temperature turned back down if it is warm/hot the next day.		
<i>Temp</i>	<i>RH</i>	<i>Co2</i>	

Animals in Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
----------------------	---	------------------------------	--

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
Art Supplies	Minimize exposure to hazardous materials.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Clean spills promptly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Local Exhaust Fans	General Items	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Local Exhaust Fans	Confirm that fume hoods and local exhaust fans function properly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Local Exhaust Fans	Confirm that fume hoods and local exhaust fans are used whenever activities that generate pollutants take place.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Thermal Comfort	Humidity level.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.

The air quality in my room is awful. The room smells of mold and mildew. The air smells unclean. I am asthmatic and since I have been in my classroom I have been hospitalized 2 times last year and continue to need constant medical attention for my attacks. This year I had an asthma attack and today I had a mild attack at 9:00 a.m. this morning. I will be moved to another classroom after today's incident but I am concerned for my safety and my student's safety exposed to such hazardous conditions. Please help!!!

214

73.4	48%	_____
<i>Temp</i>	<i>RH</i>	<i>Co2</i>

Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly.	Carpeting is stained.	Replace carpeting.
Local Exhaust Fans	General Items.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
	Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
222	<input type="text"/> <i>Temp</i>	<input type="text"/> <i>RH</i>	<input type="text"/> <i>Co2</i>	My allergies have been bad this year. I needed to clean my room at the beginning of the year, it smelled awful and still does. I have had difficulty breathing as well.
	Animals in Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly.	Carpeting is stained.	Replace carpeting.
	Local Exhaust Fans	General Items.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Local Exhaust Fans	Confirm that fume hoods and local exhaust fans function properly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
224	<input type="text"/> <i>Temp</i>	<input type="text"/> <i>RH</i>	<input type="text"/> <i>Co2</i>	
	Animals in Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.
	Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
500	<input type="text"/> <i>Temp</i>	<input type="text"/> <i>RH</i>	<input type="text"/> <i>Co2</i>	
	Animals in Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
	Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Classroom Information		Paint on northwest wall bubbling.	Maintenance to inspect and repair as appropriate.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Thermal Comfort	Humidity level.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
	Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.
	Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
<b>501</b>	<input type="text"/>	<input type="text"/>	<input type="text"/>	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	General Classroom Information		Paint on wall bubbling.	Maintenance to inspect and repair as appropriate.
<b>504</b>	<input type="text"/>	<input type="text"/>	<input type="text"/>	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	General Classroom Information		Paint on wall bubbling.	Maintenance to inspect and repair as appropriate.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
<b>902</b>	<input type="text"/> <i>Temp</i>	<input type="text"/> <i>RH</i>	<input type="text"/> <i>Co2</i>	
	General Classroom Information		Additional walkthrough of this room was done on 8/11/04 and there is water condensating in the light fixture and the hood range directly over the stove. Signs of microbial growth identified on the hood range.	Maintenance to inspect and repair as appropriate.
	General Cleanliness	Clean spills promptly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Science Supplies	Follow good safety, handling, and storage practices.		Site based administration will provide information to site based staff.
	Thermal Comfort	General items to watch for.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	<input type="text"/>			
<b>903</b>	<input type="text"/> <i>Temp</i>	<input type="text"/> <i>RH</i>	<input type="text"/> <i>Co2</i>	
	General Cleanliness	Confirm that the classroom is cleaned properly.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	<input type="text"/>			
<b>904</b>	<input type="text" value="74.3"/> <i>Temp</i>	<input type="text" value="49%"/> <i>RH</i>	<input type="text"/> <i>Co2</i>	
	Animals in Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
	Drain Traps in the Classroom	Drain traps, if present, can become a problem when the water in the drain trap evaporates due to infrequent use, allowing sewer gases to enter the room.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Classroom Information		Unauthorized chemicals and large knife in room.	Remove items from room.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
General Cleanliness	Confirm that the classroom is cleaned properly.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
General Cleanliness	Clean spills promptly.	Carpeting is stained.	Replace carpeting.
Local Exhaust Fans	Confirm that fume hoods and local exhaust fans function properly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.

908

*Temp*

*RH*

*Co2*

Animals in Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
Drain Traps in the Classroom	Drain traps, if present, can become a problem when the water in the drain trap evaporates due to infrequent use, allowing sewer gases to enter the room.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
Local Exhaust Fans	Confirm that fume hoods and local exhaust fans function properly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Thermal Comfort	Humidity level.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Thermal Comfort	General items to watch for.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.
Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.

The school appears to have active dust and mold in many places in the school. Many people are frequently sick with difficulties breathing, coughing, headaches, laryngitis, etc.

	<i>Category</i>		<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
909	<input type="text"/>	<input type="text"/>	<input type="text"/>		
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>		
General Cleanliness			Confirm that the classroom is cleaned properly.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
<input type="text"/>					