

# Discovery Elementary

## IAQ Walkthrough 5/16/2012

3962

Outside Temp  RH%  CO2

FISH/Room	Concern	Findings	Recommendation	Responsible	Priority
157	Classroom lavatories/water fountains free of leaks?	Temp <input type="text" value="73.1"/> RH% <input type="text" value="58.1"/> CO2 <input type="text" value="820"/> No issues were identified at the time of the assessment.	None at this time.		
212	Classroom is dusted/vacuumed thoroughly and regularly?	Temp <input type="text" value="72"/> RH% <input type="text" value="51.1"/> CO2 <input type="text" value="873"/> No issues were identified at the time of the assessment.	None at this time.		