

Report: Site

EMBASSY CREEK ELEMENTARY

Walkthrough Date: 04/24/2006 Temp RH CO2
 Outdoor Parameters: 88 48.7 523

Room	Priority	Responsible	Answer	Recommendation
101G	Inside Parameters:	Temp	RH	CO2
		74	49.4	867

2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.

Room	Priority	Responsible	Answer	Recommendation
101T	Inside Parameters:	Temp	RH	CO2
		69.9	56.7	884

2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
108	Inside Parameters:	Temp	RH	CO2
		72.6	52.3	913

2 Site Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment. Excessive stuffed animals. Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts

Room	Priority	Responsible	Answer	Recommendation
110	Inside Parameters:	Temp	RH	CO2
		72.6	52.3	913

2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.

2 Site Ceiling tiles broken damaged or missing. Leak is currently being repaired. Facilities serviceperson to replace ceiling tiles.

Odor detected at the time of assessment. Room is adjacent to kitchen Facilities serviceperson to evaluate cause of odor and inspect exhaust fans/fume hoods for

2	Site	and/or home economics room.	proper operation.	
Room	Priority	Responsible	Answer	Recommendation
201	Inside Parameters:	Temp 73.5	RH 51.9	CO2 1201
2	Site	Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment. Insect carcasses found in cabinets and on closet floor.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	
Room	Priority	Responsible	Answer	Recommendation
202	Inside Parameters:	Temp 74.2	RH 52.3	CO2 1277
2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	
2	Site	Dust observed on return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	
2	Site	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.	
Room	Priority	Responsible	Answer	Recommendation
203	Inside Parameters:	Temp 73.9	RH 52.7	CO2 1250
2	Site	Excessive dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	
2	Site	Dust observed on return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	
Room	Priority	Responsible	Answer	Recommendation
204	Inside Parameters:	Temp 70.7	RH 58.4	CO2 1294
2	Site	Dust and dirt accumulation on floor. Also insect carcasses.	Facilities serviceperson to thoroughly clean and sanitize. Site based administration to encourage facility serviceperson staff to adjust the thermostat.	
2	Site	Temperature was low at the time of assessment.	Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	
Room	Priority	Responsible	Answer	Recommendation

211	Inside Parameters:	Temp	RH	CO2
		71.6	55.7	1352

- | | | | |
|---|------|---|--|
| 2 | Site | Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment. | Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts |
| 2 | Site | Dust and dirt accumulation on floor. | Facilities serviceperson to thoroughly clean and sanitize. |
| 3 | Site | This is a general issue requiring approved communication among all stakeholders. | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. |

Room	Priority	Responsible	Answer	Recommendation
212	Inside Parameters:	Temp	RH	CO2
		74.4	53.1	1525

- | | | | |
|---|------|--|--|
| 2 | Site | Slight dust accumulation was observed on environmental surfaces at the time of assessment. | Site based administration should address general cleanliness with facility serviceperson staff. |
| 2 | Site | Dust observed on return register at the time of assessment. | Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. |

Room	Priority	Responsible	Answer	Recommendation
213	Inside Parameters:	Temp	RH	CO2
		74.4	52.9	1474

- | | | | |
|---|------|--|--|
| 2 | Site | Slight dust accumulation was observed on environmental surfaces at the time of assessment. | Site based administration should address general cleanliness with facility serviceperson staff. |
| 2 | Site | Dust observed on return register at the time of assessment. | Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. |

Room	Priority	Responsible	Answer	Recommendation
214	Inside Parameters:	Temp	RH	CO2
		79.1	48.8	1513

- | | | | |
|---|------|---|--|
| 2 | Site | Slight dust accumulation was observed on environmental surfaces at the time of assessment. | Site based administration should address general cleanliness with facility serviceperson staff. |
| 2 | Site | Dust observed on return register at the time of assessment. | Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. |
| 2 | Site | There appears to be a problem with spill clean up practices. To address all spills in a timely manner all moisture effected materials must be dried within a 24-hour timeframe. | Site based administration should address general cleanliness with facility serviceperson staff. |

- 3 Site This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
- 2 Site Temperature was elevated at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
215	Inside Parameters:	Temp	RH	CO2
		76.5	50.7	1535

- 2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.
- 2 Site Dust observed on supply register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
- 2 Site Dust and dirt accumulation on floor. Facilities serviceperson to thoroughly clean and sanitize.

Room	Priority	Responsible	Answer	Recommendation
218	Inside Parameters:	Temp	RH	CO2
		76.1	46.4	1184

- 2 Site Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment. Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts
- 2 Site Dust observed on return register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
- 1 Site Non-approved chemicals scented cleaners or air fresheners found at the time of assessment. Facilities serviceperson to remove all non-approved chemicals scented cleaners or air fresheners from the room.

Room	Priority	Responsible	Answer	Recommendation
219	Inside Parameters:	Temp	RH	CO2
		74.4	47.4	1295

- 2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.
- 2 Site Dust observed on return register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
- 1 Site Non-approved chemicals scented cleaners or air fresheners found at the time of assessment. Facilities serviceperson to remove all non-approved chemicals scented cleaners or air fresheners from the room.
- 2 Site Dust and dirt accumulation on floor. Facilities serviceperson to thoroughly clean and sanitize.

Room	Priority	Responsible	Answer	Recommendation

Room	Priority	Responsible	Answer	Recommendation
220	Inside Parameters:	Temp	RH	CO2
		72.1	48.9	1278

2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
2	Site	Dust observed on return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
2	Site	Teacher has live plants in room, source of mold spores. Recommended removal.	Site based administration to advise staff to remove plants.

Room	Priority	Responsible	Answer	Recommendation
227	Inside Parameters:	Temp	RH	CO2
		72.7	51.1	1505

2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
1	Site	Non-approved chemicals scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals scented cleaners or air fresheners from the room.

Room	Priority	Responsible	Answer	Recommendation
228	Inside Parameters:	Temp	RH	CO2
		76.4	46.7	1436

2	Site	Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts
2	Site	Live plants in room. Plant soil is a source of microbial growth.	Site based administration to advise staff to remove live plants.

Room	Priority	Responsible	Answer	Recommendation
229	Inside Parameters:	Temp	RH	CO2
		75.5	46.6	1561

2	Site	Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts
---	------	---	--

Room	Priority	Responsible	Answer	Recommendation
231	Inside Parameters:	Temp	RH	CO2

		75.3	46.6	1563
2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.
1	Site	Non-approved chemicals scented cleaners or air fresheners found at the time of assessment.		Facilities serviceperson to remove all non-approved chemicals scented cleaners or air fresheners from the room.
2	Site	There appears to be a problem with spill clean up practices. To address all spills in a timely manner all moisture effected materials must be dried within a 24-hour timeframe.		Site based administration should address general cleanliness with facility serviceperson staff.
2	Site	No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.		Facilities serviceperson to replace ceiling tiles.

Room	Priority	Responsible	Answer	Recommendation
232	Inside Parameters:	Temp	RH	CO2
		75.3	46.6	1563
2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.

Room	Priority	Responsible	Answer	Recommendation
304	Inside Parameters:	Temp	RH	CO2
		75.3	46.6	1563
2	Site	Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment.		Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts
2	Site	Dust observed on supply register at the time of assessment.		Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
3	Site	This is a general issue requiring approved communication among all stakeholders.		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Answer	Recommendation
305	Inside Parameters:	Temp	RH	CO2
		73.3	56.3	1368
2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.
2	Site	Dust observed on return register at the time of assessment.		Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
3	Site	This is a general issue requiring approved communication among all stakeholders.		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Answer	Recommendation
307	Inside Parameters:	Temp	RH	CO2
		71.3	59.4	1221

2	Site	Excessive dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
2	Site	Dust observed on return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
2	Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Answer	Recommendation
308	Inside Parameters:	Temp	RH	CO2
		73.5	53.7	1263

2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
2	Site	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.
3	Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Answer	Recommendation
315	Inside Parameters:	Temp	RH	CO2
		71.5	54.5	1202

2	Site	Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts
2	Site	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.
3	Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
3	Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Answer	Recommendation
316	Inside Parameters:	Temp	RH	CO2
		71.8	52	1171

Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal

2	Site	Dust observed on return register at the time of assessment.	cleaner.
2	Site	No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace ceiling tiles.

Room	Priority	Responsible	Answer	Recommendation
317C	Inside Parameters:	Temp	RH	CO2
		73.5	53.1	1281

2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
3	Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
2	Site	No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace ceiling tiles.

Room	Priority	Responsible	Answer	Recommendation
323	Inside Parameters:	Temp	RH	CO2
		70.8	50.9	1510

2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
---	------	--	---

Room	Priority	Responsible	Answer	Recommendation
324	Inside Parameters:	Temp	RH	CO2
		70.8	50.9	1510

2	Site	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
1	Site	Air fresheners used in room.	Facility serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from room.

Room	Priority	Responsible	Answer	Recommendation
325	Inside Parameters:	Temp	RH	CO2
		73.3	48.6	1671

2	Site	Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts
		This is a general issue requiring approved communication among all	Site based administration is encouraged to communicate all known student allergies to the

Room	Priority	Responsible	Answer	Recommendation
326	Inside Parameters:	Temp 72.4	RH 49	CO2 1600

2	Site	Excessive dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
2	Site	Dust observed on return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
2	Site	Excessive dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
2	Site	Dust observed on return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Room	Priority	Responsible	Answer	Recommendation
332	Inside Parameters:	Temp 77	RH 50.3	CO2 1619

2	Site	Excessive dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
---	------	---	---

Room	Priority	Responsible	Answer	Recommendation
333	Inside Parameters:	Temp 68	RH 49.3	CO2 1453

2	Site	Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts
3	Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
2	Site	No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace ceiling tiles.
2	Site	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
335	Inside Parameters:	Temp	RH	CO2

		68	53.4	1386
2	Site	Excessive dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.
2	Site	Temperature was low at the time of assessment.		Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
336	Inside Parameters:	Temp	RH	CO2
		70.5	54.3	1540
2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.
2	Site	Dust observed on supply register at the time of assessment.		Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
2	Site	Dust and dirt accumulation on floor.		Facilities serviceperson to thoroughly clean and sanitize.
2	Site	Temperature was low at the time of assessment.		Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
337	Inside Parameters:	Temp	RH	CO2
		69.9	52.5	1407
2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.
2	Site	Temperature was low at the time of assessment.		Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
401	Inside Parameters:	Temp	RH	CO2
		72	54.4	817
2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.

Room	Priority	Responsible	Answer	Recommendation
401E	Inside	Temp	RH	CO2

	Parameters:	70.5	55.4	768
2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.
2	Site	Temperature was low at the time of assessment.		Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
2	Site	Temperature was low at the time of assessment.		Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
850	Inside Parameters:	Temp	RH	CO2
		72.7	52	1585
2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.
2	Site	Dust observed on supply register at the time of assessment.		Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
2	Site	Dust and dirt accumulation on floor.		Facilities serviceperson to thoroughly clean and sanitize.

Room	Priority	Responsible	Answer	Recommendation
851	Inside Parameters:	Temp	RH	CO2
		70.7	53.3	958
2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.
2	Site	Dust observed on supply register at the time of assessment.		Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Room	Priority	Responsible	Answer	Recommendation
853	Inside Parameters:	Temp	RH	CO2
		70.6	49.7	886
2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.
2	Site	Dust observed on supply register at the time of assessment.		Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

2	Site	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
2	Site	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.