

# Fairway Elementary

## IAQ Walkthrough 5/18/2012

1641

Outside Temp  RH%  CO2

FISH/Room	Concern	Findings	Recommendation	Responsible	Priority
<b>104</b>		Temp <input type="text" value="73.5"/> RH% <input type="text" value="56.1"/> CO2 <input type="text" value="689"/>			
	Classroom is dusted/vacuumed thoroughly and regularly?	General cleanliness Issues were identified at the time of the assessment <i>Dust on surfaces.</i>	Custodial staff to address general cleanliness issues. Dusting, mopping, trash removal, etc.	Site	2
	Classroom is free of significant temperature shifts?	No issues were identified at the time of the assessment.	None at this time.		
	Floor is cleaned on a regular basis?	General cleanliness Issues were identified at the time of the assessment <i>Debris and minor staining on carpet.</i>	Custodial staff to address general cleanliness issues. Dusting, mopping, trash removal, etc.	Site	2
	Room is free of pests?	No issues were identified at the time of the assessment.	None at this time.		
	Room is usually comfortable? (If no, please explain in the notes below.)	No issues were identified at the time of the assessment.	None at this time.		
	Temperature in my classroom is generally comfortable (72F-78F)?	No issues were identified at the time of the assessment.	None at this time.		
<b>302</b>		Temp <input type="text" value="72"/> RH% <input type="text" value="47.8"/> CO2 <input type="text" value="1000"/>			
	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site	3
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust and debris on HVAC supply and/or return grills.	Clean HVAC supply and/or return grills with District approved germicidal cleaner	Site	2

FISH/Room	Concern	Findings	Recommendation	Responsible	Priority
302		Temp <input type="text" value="72"/> RH% <input type="text" value="47.8"/> CO2 <input type="text" value="1000"/>			
	Classroom is dusted/vacuumed thoroughly and regularly?	General cleanliness Issues were identified at the time of the assessment  Minor dust and debris on surfaces.	Custodial staff to address general cleanliness issues. Dusting, mopping, trash removal, etc.	Site	2
	Classroom is free of significant temperature shifts?	No issues were identified at the time of the assessment.	None at this time.		
	Classrooms general appearance is clean and acceptable?	No issues were identified at the time of the assessment.	None at this time.		
	Floor is cleaned on a regular basis?	General cleanliness Issues were identified at the time of the assessment  Dust and debris on floor.	Custodial staff to address general cleanliness issues. Dusting, mopping, trash removal, etc.	Site	2
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	No issues were identified at the time of the assessment.	None at this time.		
	Room is free of pests?	No issues were identified at the time of the assessment.	None at this time.		
	Room is free of smell of kitchen/food?	No issues were identified at the time of the assessment.	None at this time.		
	Room is free of smell of mold or mildew?	No issues were identified at the time of the assessment.	None at this time.		
	Room is usually comfortable? (If no, please explain in the notes below.)	No issues were identified at the time of the assessment.	None at this time.		
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?	No issues were identified at the time of the assessment.	None at this time.		
	Temperature in my classroom is generally comfortable (72F-78F)?	No issues were identified at the time of the assessment.	None at this time.		

FISH/Room	Concern	Findings	Recommendation	Responsible	Priority						
302	Temp	72	RH%	47.8	CO2	1000	X	Stuffed animals, rugs, material furniture and/or other non-School Board items in room.	Remove items from room or clean regularly to remove dust and dirt.	Site	2
								Large upholstered chair has visible water damage and needs to be removed.			