

Flamingo Elementary

IAQ Walkthrough 5/9/2005

Outside Temp RH% CO2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
101C	Temp	<input type="text" value="69.3"/>	RH% <input type="text" value="42.4"/>	CO2 <input type="text" value="900"/>	Occupants: <input type="text"/>		
THERMAL COMFORT							
	Temperature in my classroom is generally comfortable (72F-76F)?	Too cold		Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Room is usually comfortable? (If no, please explain in the notes below.)	Too cold		See previous item.	None	None	
108	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
Walkthrough							
				Exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
111	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
Walkthrough							
				Exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
116	Temp	<input type="text" value="71"/>	RH% <input type="text" value="43.4"/>	CO2 <input type="text" value="863"/>	Occupants: <input type="text" value="13"/>		
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?	A small vacuum may help eliminate the excessive dust that accumulates on the library shelves. Otherwise, the dust just circulates in the air. Review is incorrect. Note (b) answer.		Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
LOCAL EXHAUST FANS							
	Other exhaust fans that may exist in the classroom are functioning properly?			Exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as necessary.	Physical Plant Operations	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
116	Temp	71	RH% 43.4	CO2 863	Occupants: 13		
	Bathroom exhaust fan is functioning properly?			Bathroom exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
121	Temp	70.9	RH% 44.3	CO2 1096	Occupants: 29		
	ANIMALS IN THE CLASSROOM						
	Activities and/or room conditions are modified to address student allergies?				None	None	
124	Temp	70.9	RH% 45.2	CO2 1061	Occupants: 28		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None	None	
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?			General cleanliness of the room at the time of assessment was acceptable.	None	None	
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None	None	
	Room is free of pests?			Terrarium in room behind desk.	Remove terrarium from room.	Site Based	3
127	Temp	71.1	RH% 45.8	CO2 1136	Occupants:		
	EXCESS MOISTURE IN CLASSROOMS						
	Classroom lavatories/water fountains free of leaks?			No leaks identified. Signs of previous water intrusion as evidenced by staining.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	1
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?			Trash is removed daily. Answer to "c" is YES. HOWEVER, the answer comes up as "no" on the survey review board.	General cleanliness of the room at the time of assessment was acceptable.	None	None
	Floor is cleaned on a regular basis?			Trash is removed daily. Answer to "c" is YES. HOWEVER, the answer comes up as "no" on the survey review board.	Floor was clean at the time of assessment.	None	None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
129	Temp	71.4	RH% 44.6	CO2 1042	Occupants: 28		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	Site Based	2
130	Temp	72	RH% 45.6	CO2 965	Occupants: 22		
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations	1
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?			The floor is swept daily, but needs to be mopped more often.	General cleanliness of the room at the time of assessment was acceptable.	None	None	
Room is free of pests?			The floor is swept daily, but needs to be mopped more often.	Pests observed at the time of assessment.	Physical Plant Operation to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	2
THERMAL COMFORT							
Classroom is free of significant temperature shifts?				Temperature was acceptable at the time of assessment.	None	None	
131	Temp	71.7	RH% 44.6	CO2 947	Occupants: 18		
GENERAL CLEANLINESS							
Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was acceptable.	None	None	
Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None	None	
132	Temp	72.1	RH% 45.4	CO2 1000	Occupants: 25		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?					None	None	
You are informed about the potential allergies of your students?					None	None	
GENERAL CLEANLINESS							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
132	Temp	<input type="text" value="72.1"/>	RH%	<input type="text" value="45.4"/>	CO2	<input type="text" value="1000"/>	Occupants:	<input type="text" value="25"/>			
	Classroom is dusted/vacuumed thoroughly and regularly?						General cleanliness of the room at the time of assessment was not acceptable.		Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classrooms general appearance is clean and acceptable?						General cleanliness of the room at the time of assessment was acceptable.		None	None	
	Floor is cleaned on a regular basis?						Floor was clean at the time of assessment.		None	None	
134B	Temp	<input type="text" value="71.4"/>	RH%	<input type="text" value="45.9"/>	CO2	<input type="text" value="922"/>	Occupants:	<input type="text" value="8"/>			
	ANIMALS IN THE CLASSROOM										
	You are informed about the potential allergies of your students?								None	None	
	GENERAL CLEANLINESS										
	Classroom is dusted/vacuumed thoroughly and regularly?						General cleanliness of the room at the time of assessment was acceptable.		None	None	
	Classrooms general appearance is clean and acceptable?						General cleanliness of the room at the time of assessment was not acceptable.		Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?						Floor was clean at the time of assessment.		None	None	
136	Temp	<input type="text" value="72.1"/>	RH%	<input type="text" value="44.1"/>	CO2	<input type="text" value="965"/>	Occupants:	<input type="text"/>			
	GENERAL CLEANLINESS										
	Classroom is dusted/vacuumed thoroughly and regularly?		I have never had a problem or time when I thought the air supply/return registers were not cleaned regularly and free of dust and debris accumulation but I do not know how often they are cleaned.				Slight dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	Site Based	2
	Walkthrough										
							Dust observed on supply/return registers at the time of assessment.		Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
							No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.		Facilities serviceperson to replace stained ceiling tiles.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
136C	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
Walkthrough				Dust observed on exhaust grill in bathroom.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
137	Temp	<input type="text" value="72.4"/>	RH% <input type="text" value="40.9"/>	CO2 <input type="text" value="1073"/>	Occupants: <input type="text"/>		
LOCAL EXHAUST FANS							
Bathroom exhaust fan is functioning properly?				Bathroom exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
THERMAL COMFORT							
Room is usually comfortable? (If no, please explain in the notes below.)			Temperature in the room is too cold.	Temperature was acceptable at the time of assessment.	None	None	
Temperature in my classroom is generally comfortable (72F-76F)?			Temperature in the room is too cold.	Temperature was acceptable at the time of assessment.	None	None	
138	Temp	<input type="text" value="73.1"/>	RH% <input type="text" value="41.7"/>	CO2 <input type="text" value="1031"/>	Occupants: <input type="text" value="5"/>		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				General cleanliness of the room at the time of assessment was acceptable.	None	None	
THERMAL COMFORT							
Room is usually comfortable? (If no, please explain in the notes below.)			In general it is too cold, 68-70 degrees.	Temperature was acceptable at the time of assessment.	None	None	
Temperature in my classroom is generally comfortable (72F-76F)?			In general it is too cold, 68-70 degrees.	Temperature was acceptable at the time of assessment.	None	None	
Walkthrough				Dust observed on bathroom exhaust fan at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
139	Temp	<input type="text" value="72.9"/>	RH% <input type="text" value="42.6"/>	CO2 <input type="text" value="1004"/>	Occupants: <input type="text"/>		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?					None	None	
LOCAL EXHAUST FANS							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
139	Temp	72.9	RH% 42.6	CO2 1004	Occupants:		
	Bathroom exhaust fan is functioning properly?				Bathroom exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations 2
	Walkthrough				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
141	Temp		RH%		CO2		Occupants:
	GENERAL CLEANLINESS						
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None	None
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	Site Based 2
	Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was acceptable.	None	None
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
	LOCAL EXHAUST FANS						
	Bathroom exhaust fan is functioning properly?				Bathroom exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations 2
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?		IT can often be cold		Temperature was acceptable at the time of assessment.	None	None
	Temperature in my classroom is generally comfortable (72F-76F)?		IT can often be cold		Temperature was acceptable at the time of assessment.	None	None
	Room is usually comfortable? (If no, please explain in the notes below.)		IT can often be cold		Temperature was acceptable at the time of assessment.	None	None
143	Temp	72.7	RH% 41.9	CO2 988	Occupants:	6	
	LOCAL EXHAUST FANS						
	Bathroom exhaust fan is functioning properly?				Bathroom exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as necessary.	Physical Plant Operations 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
145	Temp	72.8	RH% 45.6	CO2 1247	Occupants: 22			
ANIMALS IN THE CLASSROOM								
Activities and/or room conditions are modified to address student allergies?					None	None		
GENERAL CLEANLINESS								
Floor is cleaned on a regular basis?					Floor was clean at the time of assessment.	None	None	
Classroom is dusted/vacuumed thoroughly and regularly?					Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	Site Based	2
THERMAL COMFORT								
Temperature in my classroom is generally comfortable (72F-76F)?			usually too cold. Students have to wear jackets.	Temperature was acceptable at the time of assessment.	None	None		
Room is usually comfortable? (If no, please explain in the notes below.)			usually too cold. Students have to wear jackets.	Temperature was acceptable at the time of assessment.	None	None		
Classroom is free of significant temperature shifts?			usually too cold. Students have to wear jackets.	Temperature was acceptable at the time of assessment.	None	None		
Walkthrough								
					Bathroom exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
175	Temp	72.6	RH% 50.6	CO2 923	Occupants:			
GENERAL CLEANLINESS								
Classroom is dusted/vacuumed thoroughly and regularly?					Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	Site Based	2
Walkthrough								
					Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
180	Temp	72.7	RH% 52.8	CO2 1062	Occupants:			
GENERAL CLEANLINESS								
Classroom is dusted/vacuumed thoroughly and regularly?					General cleanliness of the room at the time of assessment was acceptable.	None	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
180	Temp	<input type="text" value="72.7"/>	RH% <input type="text" value="52.8"/>	CO2 <input type="text" value="1062"/>	Occupants: <input type="text"/>		
Room is free of pests?				No pests observed at the time of assessment.	None	None	
Walkthrough				Ceiling tiles broken, damaged or missing.	Facilities serviceperson to replace damaged ceiling tiles.	Site Based	2
181	Temp	<input type="text" value="72.5"/>	RH% <input type="text" value="53"/>	CO2 <input type="text" value="1078"/>	Occupants: <input type="text"/>		
AIR CONDITIONING							
Room is free of smell of mold or mildew?			VERY CLAMMY WET FEELING IN MORNINGS WHEN OPENING UP CLASSROOM FOR THE DAY	No odor detected at the time of assessment.	None	None	
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?					None	None	
GENERAL CLEANLINESS							
Room is free of pests?				No pests observed at the time of assessment.	None	None	
THERMAL COMFORT							
Room is usually comfortable? (If no, please explain in the notes below.)			CLASSROOM HAS BEEN FAIRLY COMFORTABLE THIS WINTER BUT WHEN IT GETS WARMER THE CLASSROOM WILL GET EXTREMELY COLD.	Temperature was acceptable at the time of assessment.	None	None	
Temperature in my classroom is generally comfortable (72F-76F)?			CLASSROOM HAS BEEN FAIRLY COMFORTABLE THIS WINTER BUT WHEN IT GETS WARMER THE CLASSROOM WILL GET EXTREMELY COLD.	Temperature was acceptable at the time of assessment.	None	None	
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)			CLASSROOM HAS BEEN FAIRLY COMFORTABLE THIS WINTER BUT WHEN IT GETS WARMER THE CLASSROOM WILL GET EXTREMELY COLD.	Humidity was acceptable at the time of assessment.	None	None	
Classroom is free of significant temperature shifts?			CLASSROOM HAS BEEN FAIRLY COMFORTABLE THIS WINTER BUT WHEN IT GETS WARMER THE CLASSROOM WILL GET EXTREMELY COLD.	Temperature was acceptable at the time of assessment.	None	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
182	Temp	<input type="text" value="72.3"/>	RH% <input type="text" value="53.7"/>	CO2 <input type="text" value="923"/>	Occupants: <input type="text"/>			
GENERAL CLEANLINESS								
Floor is cleaned on a regular basis?					Floor was clean at the time of assessment.	None	None	
Room is free of pests?					No pests observed at the time of assessment.	None	None	
LOCAL EXHAUST FANS								
Bathroom exhaust fan is functioning properly?					Bathroom exhaust fan is functioning properly.	None	None	
183	Temp	<input type="text" value="72.4"/>	RH% <input type="text" value="51.8"/>	CO2 <input type="text" value="993"/>	Occupants: <input type="text"/>			
ANIMALS IN THE CLASSROOM								
Classroom is free of animals and pets?					No animals identified at the time of assessment.	None	None	
GENERAL CLEANLINESS								
Room is free of pests?					No pests observed at the time of assessment.	None	None	
184	Temp	<input type="text" value="71.8"/>	RH% <input type="text" value="48.9"/>	CO2 <input type="text" value="915"/>	Occupants: <input type="text"/>			
GENERAL CLEANLINESS								
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?					No issues identified at the time of assessment.	None	None	
Room is free of pests?					No pests observed at the time of assessment.	None	None	
THERMAL COMFORT								
Classroom is free of significant temperature shifts?					Temperature was acceptable at the time of assessment.	None	None	
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)					Humidity was acceptable at the time of assessment.	None	None	
Room is usually comfortable? (If no, please explain in the notes below.)					Temperature was acceptable at the time of assessment.	None	None	
Walkthrough								
					Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
184	Temp	<input type="text" value="71.8"/>	RH% <input type="text" value="48.9"/>	CO2 <input type="text" value="915"/>	Occupants: <input type="text"/>		
185	Temp	<input type="text" value="71.1"/>	RH% <input type="text" value="51.9"/>	CO2 <input type="text" value="892"/>	Occupants: <input type="text"/>		
AIR CONDITIONING							
Air is flowing without obstruction?					No issues identified at the time of assessment.	None	None
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?						None	None
EXCESS MOISTURE IN CLASSROOMS							
Windows, windowsills and window frames free of continuous condensation?					No condensation on windows at the time of assessment.	None	None
Classroom lavatories/water fountains free of leaks?					No leaks or signs of water intrusion identified.	None	None
LOCAL EXHAUST FANS							
My classroom has sufficient exhaust systems based on the activities/functionality of the room?			No exhaust fans		No exhaust fans in room. Identified in error.	None	None
Other exhaust fans that may exist in the classroom are functioning properly?			No exhaust fans		No exhaust fans in room. Identified in error.	None	None
Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)			No exhaust fans		No exhaust fans in room. Identified in error.	None	None
Bathroom exhaust fan is functioning properly?			No exhaust fans		No exhaust fans in room. Identified in error.	None	None
THERMAL COMFORT							
Temperature in my classroom is generally comfortable (72F-76F)?			Usually too warm in the AM and too cold in the PM		Temperature was acceptable at the time of assessment.	None	None
Room is usually comfortable? (If no, please explain in the notes below.)			Usually too warm in the AM and too cold in the PM		Temperature was acceptable at the time of assessment.	None	None
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)			Usually too warm in the AM and too cold in the PM		Humidity was acceptable at the time of assessment.	None	None
Classroom is free of significant temperature shifts?			Usually too warm in the AM and too cold in the PM		Temperature was acceptable at the time of assessment.	None	None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
186	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
THERMAL COMFORT							
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Usually, in the morning, it is hot, and in the afternoon, it is too cold.			See previous item.	None	None
	Room is usually comfortable? (If no, please explain in the notes below.)	Usually, in the morning, it is hot, and in the afternoon, it is too cold.			See previous item.	None	None
	Temperature in my classroom is generally comfortable (72F-76F)?	Usually, in the morning, it is hot, and in the afternoon, it is too cold.			See previous item.	None	None
	Classroom is free of significant temperature shifts?	Usually, in the morning, it is hot, and in the afternoon, it is too cold.			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based 2
Walkthrough							
					Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	Site Based 2
188	Temp	<input type="text" value="70.2"/>	RH% <input type="text" value="48.9"/>	CO2 <input type="text" value="861"/>	Occupants: <input type="text"/>		
AIR CONDITIONING							
	Windows/doors are operable and are kept closed?				No issues identified at the time of assessment.	None	None
DRAIN TRAPS IN THE CLASSROOM							
	Water run in sinks at least once per week (about 2 cups of water).				No issues identified at the time of assessment.	None	None
	If not regularly used, toilets flushed once each week.					None	None
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?				Bathroom exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations 2
THERMAL COMFORT							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
188	Temp	70.2	RH% 48.9	CO2 861	Occupants:			
	Temperature in my classroom is generally comfortable (72F-76F)?	The room is very warm in the morning.			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Room is usually comfortable? (If no, please explain in the notes below.)	The room is very warm in the morning.			Temperature was low at the time of assessment.	None	None	
	Classroom is free of significant temperature shifts?	The room is very warm in the morning.			Temperature was low at the time of assessment.	None	None	
666C	Temp	72.7	RH% 40.2	CO2 1504	Occupants:	8		
	LOCAL EXHAUST FANS							
	Other exhaust fans that may exist in the classroom are functioning properly?	There are no bathrooms or exhaust fans in this room. Answer should really be n/a			No exhaust fans in room. Identified in error.	None	None	
	Bathroom exhaust fan is functioning properly?	There are no bathrooms or exhaust fans in this room. Answer should really be n/a			No bathroom. Identified in error.	None	None	
	Walkthrough							
					Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
					Both A/C units were not on at the time of assessment and filters were not installed/cut properly.	Facilities serviceperson to replace HVAC filters and ensure that both A/C units are on.	Site Based	1
705C	Temp	74.7	RH% 40.6	CO2 2466	Occupants:			
	GENERAL CLEANLINESS							
	Room is free of pests?				No pests observed at the time of assessment.	None	None	
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None	None	
	Classroom is dusted/vacuumed thoroughly and regularly?				General cleanliness of the room at the time of assessment was acceptable.	None	None	
	LOCAL EXHAUST FANS							
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?				No issues identified at the time of assessment.	None	None	
	Other exhaust fans that may exist in the classroom are functioning properly?				No issues identified at the time of assessment.	None	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
705C	Temp	74.7	RH% 40.6	CO2 2466	Occupants: <input type="text"/>		
	Bathroom exhaust fan is functioning properly?				No issues identified at the time of assessment.	None	None
	Walkthrough						
					Both A/C units were not on at the time of assessment and filters were not installed/cut properly.	Facilities serviceperson to replace HVAC filters and ensure that both A/C units are on.	Site Based 1
					Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
706C	Temp	76.5	RH% 44.2	CO2 2396	Occupants: <input type="text"/>		
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?				General cleanliness of the room at the time of assessment was acceptable.	None	None
	LOCAL EXHAUST FANS						
	Other exhaust fans that may exist in the classroom are functioning properly?		I teach in a portable and to my knowledge, there are no exhaust fans and I do not have a bathroom.		No exhaust fans in room. Identified in error.	None	None
	Bathroom exhaust fan is functioning properly?		I teach in a portable and to my knowledge, there are no exhaust fans and I do not have a bathroom.		No exhaust fans in room. Identified in error.	None	None
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)		I teach in a portable and to my knowledge, there are no exhaust fans and I do not have a bathroom.		No exhaust fans in room. Identified in error.	None	None
	Walkthrough						
					Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
					Both A/C units were not on at the time of assessment and filters were not installed/cut properly.	Facilities serviceperson to replace HVAC filters and ensure that both A/C units are on.	Site Based 1