

Aston A. Henry, Supervisor
Risk Management Department

Telephone: 754 321-1900
Fax: 754 321-1917

April 13, 2012

Signature on File

TO: Keith Peters, Principal
Floranada Elementary School

FROM: Robert Krickovich, Coordinator I, LEA
Facilities and Construction Management

SUBJECT: Indoor Air Quality (IAQ) Assessment

<u>For Custodial Supervisor Use Only</u>	
<input type="checkbox"/>	Custodial Issues Addressed
<input type="checkbox"/>	Custodial Issues Not Addressed

On December 5, 2011, I conducted an assessment at **Floranada Elementary School**. Attached are findings and recommendations for further assessment, remediation, or corrective actions, if needed.

The IAQ Assessment did not identify any existing conditions significantly impacting IAQ or presenting immediate health and safety concerns to building occupants. However, due to individual sensitivities and predisposing health factors, it is possible that some building occupants may elicit a health response to allergens and / or conditions noted during the evaluation. Therefore, to further improve IAQ, prevent development of future IAQ-related problems, and to reduce the potential for IAQ-related complaints by building occupants, the IAQ Assessment Team recommends appropriate follow up of any item/s identified and noted in the attached evaluation.

Please ensure that your Head Facilities Serviceperson receives a copy of this correspondence so that the recommendations requiring their attention can be addressed. In an attempt to separate IAQ issues from general maintenance items, the attached assessment may contain direction for site based staff to generate a work order through COMPASS. Within two weeks a representative from the Custodial/Grounds Department will conduct a follow-up visit to ensure that all site based custodial issues have been appropriately addressed.

Should any questions arise, or if the current concerns continue after the attached recommendations have been addressed, please feel free to contact us at 754-321-1907.

cc: Area Superintendent
Area Directors
Shelley Meloni, Executive Director, Facilities and Construction Management
Mark Dorsett, Acting Director, Physical Plant Operations Division, Maintenance
Sonja Coley, Project Manager III, Facilities and Construction Management
Roy Norton, Manager Custodial/Grounds, Physical Plant Operations Division
Aston Henry, Supervisor, Risk Management
Broward Teachers Union
Federation of Public Employees

RK/tc
Enc.

IAQ Assessment

Location Number 0851
 Evaluation Requested December 2, 2011
 Evaluation Date December 5, 2011

Floranada Elementary School

Time of Day 2:30

Outdoor Conditions Temperature 82.1 Relative Humidity 48.3 Ambient CO2 430

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
213	71.3	72 - 78	49.3	30% - 60%	582	Max 700 > Ambient	17
Noticeable Odor		Visible water damage / staining?		Visible microbial growth?		Amount of material affected	
No		No		No		None	
Ceiling Type	2 x 4 Lay In		No	No	None		
Wall Type	Drywall		No	No	None		
Flooring	12 x 12 Vinyl		No	No	None		

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	Yes	No	No	
Walls	Yes	No	No	
Flooring	Yes	No	No	
HVAC Supply Grills	Yes	No	No	
HVAC Return Grills	Yes	No	No	
Ceiling at Supply Grills	Yes	No	No	
Surfaces in Room	Yes	No	No	

Observations

Findings
 - Six cardboard boxes in room being used for storage
 - No signs of water intrusion or microbial growth

Site Based Maintenance:
 - Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate