

managing risk with responsibility

	enry, Director ement Departi	ment	Telephone: Fax:	754 321-1900 754 321-1917
September 8	3, 2014	Signature on File	For Custodial S	Supervisor Use Only
TO:		othman, Principal Ils Elementary School		sues Addressed
FROM:		er, Project Manager agement Department		
SUBJECT:	Indoor Ai	r Quality (IAQ) Assessment		

On September 3, 2014, I conducted an assessment at **Forest Hills Elementary School**. Attached are findings and recommendations for further assessment, remediation, or corrective actions needed.

The IAQ Assessment did not identify any existing conditions significantly impacting IAQ or presenting immediate health and safety concerns to building occupants. However, due to individual sensitivities and predisposing health factors, it is possible that some building occupants may elicit a health response to allergens and / or conditions noted during the evaluation. Therefore, to further improve IAQ, prevent development of future IAQ-related problems, and to reduce the potential for IAQ-related complaints by building occupants, the IAQ Assessment Team recommends appropriate follow up of any item/s identified and noted in the attached evaluation.

Please ensure that your Head Facilities Serviceperson receives a copy of this correspondence so that the recommendations requiring their attention can be addressed. In an attempt to separate IAQ issues from general maintenance items, the attached assessment may contain direction for site based staff to generate a work order through COMPASS. Within two weeks a representative from the Custodial/Grounds Department will conduct a follow-up visit to ensure that all site based custodial issues have been appropriately addressed.

Should any questions arise, or if the current concerns continue after the attached recommendations have been addressed, please feel free to contact us at 754-321-1907.

cc: Shelley Meloni, Executive Director, Facilities & Construction
Mark Dorsett, Manager, Zone 1, Physical Plant Operations Division
Roy Norton, Manager, Custodial/Grounds, Physical Plant Operations Division
Aston Henry, Director, Risk Management
Sonja Coley, Senior Project Manager, Facilities & Construction
Broward Teachers Union
Federation of Public Employees

DM/tc Enc.

Install filter in proper location	▼
Replace stained ceiling tiles after repair	•
Set the thermostat to SBBC limits 72-78	▼
	•
	•
	•
	▼

Corrective Actions to be Completed by PPO	
	▼
	▼
	▼
	▼
	▼
	▼
	▼
	▼
	•