

Report: PPO

**FOREST HILLS ELEMENTARY**

Walkthrough Date: 03/28/2007 Temp RH CO2

Outdoor Parameters: 77.7 58.2 542

Room	Priority	Responsible	Answer	Recommendation
101A	Inside Parameters:	Temp 78.1	RH 53-2	CO2 1335
1	PPO		Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate and replace ceiling tiles as appropriate.
101C	Inside Parameters:	Temp 76.7	RH 48.3	CO2 1215
1	PPO		Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate and replace ceiling tiles as appropriate.
101H	Inside Parameters:	Temp 76.3	RH 48.3	CO2 1215
1	PPO		No leaks or signs of water intrusion identified around sink. However, water staining on ceiling.	Physical Plant Operations to evaluate for leaks and repair as appropriate and replace ceiling tiles as appropriate.
101J	Inside Parameters:	Temp 73.8	RH 48.1	CO2 1170
1	PPO		Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate and replace ceiling tiles as appropriate.
117	Inside Parameters:	Temp 74.5	RH 48.2	CO2 946
1	PPO		Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate and replace ceiling tiles as appropriate.

Room	Priority	Responsible	Answer	Recommendation
144	Inside Parameters:	Temp	RH	CO2
		70.6	53.2	957

2 PPO Exhaust fan is too loud. Physical Plant Operations to evaluate and repair as appropriate.

Room	Priority	Responsible	Answer	Recommendation
145C	Inside Parameters:	Temp	RH	CO2
		69.7	53.7	1091

2 PPO Carpet was stained, torn, rippled or buckled. Physical Plant Operations to evaluate and repair/replace as appropriate.

Room	Priority	Responsible	Answer	Recommendation
147	Inside Parameters:	Temp	RH	CO2
		68.8	54.9	1022

2 PPO Exhaust fan is not functioning properly. Physical Plant Operations to evaluate and repair as appropriate.

Room	Priority	Responsible	Answer	Recommendation
147A	Inside Parameters:	Temp	RH	CO2
		68.3	55.4	1016

2 PPO Bathroom exhaust fan is not functioning properly. Physical Plant Operations to evaluate and repair as appropriate.

Room	Priority	Responsible	Answer	Recommendation
163D	Inside Parameters:	Temp	RH	CO2
		00	00	00

2 PPO Air supply/return ventilation is not functioning. Physical Plant Operations to evaluate and repair as appropriate.

Room	Priority	Responsible	Answer	Recommendation
165	Inside Parameters:	Temp	RH	CO2
		73.3	49.3	1047

1 PPO Signs of water intrusion. Stained ceiling tiles. Physical Plant Operations to evaluate for leaks and repair as appropriate and replace ceiling tiles as appropriate.

Room	Priority	Responsible	Answer	Recommendation
185	Inside Parameters:	Temp 71.5	RH 51.5	CO2 952
3		PPO	Windows are not operable. Open doors and windows allow humid untreated air into occupied environment.	Physical Plant Operations to evaluate and repair as appropriate. However site based administration to encourage staff to keep doors and windows closed.
Room	Priority	Responsible	Answer	Recommendation
189A	Inside Parameters:	Temp 00	RH 00	CO2 00
2		PPO	Exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.
Room	Priority	Responsible	Answer	Recommendation
191	Inside Parameters:	Temp 73.3	RH 49.3	CO2 1047
1		PPO	Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate and replace ceiling tiles as appropriate.