

Report: Site

FOREST HILLS ELEMENTARY

Walkthrough Date: 03/28/2007 Temp RH CO2

Outdoor Parameters: 77.7 58.2 542

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|--------|----------------|
| 101A | Inside Parameters: | Temp | RH | CO2 |
| | | 78.1 | 53-2 | 1335 |

- 2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.
- 2 Site Dust observed on supply register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|--------|----------------|
| 101D | Inside Parameters: | Temp | RH | CO2 |
| | | 76.3 | 48.3 | 1215 |

- 2 Site Dust observed on supply register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|--------|----------------|
| 101F | Inside Parameters: | Temp | RH | CO2 |
| | | 76.3 | 48.3 | 1215 |

- 2 Site Dust observed on return register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|--------|----------------|
| 101G | Inside Parameters: | Temp | RH | CO2 |
| | | 76.3 | 48.3 | 1215 |

- 2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.
- 2 Site Dust and dirt accumulation on floor. Facilities serviceperson to thoroughly clean and sanitize.

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|--------|----------------|
| 110 | Inside Parameters: | Temp | RH | CO2 |

| | | 73.5 | 49.5 | 1211 |
|------|--------------------|--|--------|--|
| 2 | Site | Dust observed on supply register at the time of assessment. | | Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. |
| Room | Priority | Responsible | Answer | Recommendation |
| 113A | Inside Parameters: | Temp | RH | CO2 |
| | | 72.5 | 49.4 | 1076 |
| 2 | Site | Dust observed on supply register at the time of assessment. | | Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. |
| Room | Priority | Responsible | Answer | Recommendation |
| 113B | Inside Parameters: | Temp | RH | CO2 |
| | | 72.0 | 50.2 | 1083 |
| 2 | Site | Dust observed on supply register at the time of assessment. | | Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. |
| Room | Priority | Responsible | Answer | Recommendation |
| 113C | Inside Parameters: | Temp | RH | CO2 |
| | | 00 | 00 | 00 |
| 2 | Site | Dust observed on supply register at the time of assessment. | | Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. |
| Room | Priority | Responsible | Answer | Recommendation |
| 116 | Inside Parameters: | Temp | RH | CO2 |
| | | 74.5 | 48.6 | 1103 |
| 2 | Site | Dust observed on supply register at the time of assessment. | | Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. |
| 2 | Site | Dust observed on supply register at the time of assessment. | | Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. |
| 3 | Site | This is a general issue requiring approved communication among all stakeholders. | | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. |
| 3 | Site | This is a general issue requiring approved communication among all stakeholders. | | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. |

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|--------|----------------|
| 116B | Inside Parameters: | Temp | RH | CO2 |
| | | 76.4 | 44.2 | 1080 |

- 2 Site General cleanliness of the room at the time of assessment was not acceptable. Site based administration should address general cleanliness with facility serviceperson staff.
- 2 Site Dust observed on supply register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|--------|----------------|
| 116C | Inside Parameters: | Temp | RH | CO2 |
| | | 74.5 | 47.7 | 1067 |

- 2 Site Room is not a classroom. Stuffed animals in room. Remove stuffed animals.
- 3 Site This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
- 3 Site This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|--------|----------------|
| 116D | Inside Parameters: | Temp | RH | CO2 |
| | | 00 | 00 | 00 |

- 2 Site Room is not a classroom. Stuffed animals in room. Remove stuffed animals.
- 3 Site This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
- 3 Site This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|--------|----------------|
| 117 | Inside Parameters: | Temp | RH | CO2 |
| | | 74.5 | 48.2 | 946 |

- 2 Site Supply vents closed at the time of assessment. Facilities serviceperson to open supply vents.

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|--------|----------------|
| 118 | Inside Parameters: | Temp | RH | CO2 |
| | | 76.5 | 50.5 | 893 |

- 2 Site Dust observed on return register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
- 1 Site Stuffed animals and live plants in room. Site based administration to advise staff to remove live plants and stuffed animals.

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|--------|----------------|
| 119A | Inside Parameters: | Temp | RH | CO2 |
| | | 72.5 | 00 | 00 |

- 2 Site Dust observed on supply register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|--------|----------------|
| 119F | Inside Parameters: | Temp | RH | CO2 |
| | | 75.2 | 00 | 00 |

- 1 Site Dust observed on return register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|--------|----------------|
| 121 | Inside Parameters: | Temp | RH | CO2 |
| | | 71.8 | 49.2 | 1175 |

- 2 Site Dust observed on supply register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|--------|----------------|
| 122 | Inside Parameters: | Temp | RH | CO2 |
| | | 71.3 | 49.9 | 1135 |

- 2 Site Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment. Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts
- 2 Site Dust observed on supply register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

assessment.

District approved germicidal cleaner.

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|--------------|---|--|
| 124 | Inside Parameters: | Temp 72.4 | RH 48.5 | CO2 1336 |
| 2 | Site | | Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment. | Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts |
| 3 | Site | | This is a general issue requiring approved communication among all stakeholders. | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. |

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|--------------|---|--|
| 127 | Inside Parameters: | Temp 72.8 | RH 50.6 | CO2 1045 |
| 2 | Site | | Dust observed on supply register at the time of assessment. | Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. |

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|--------------|---|--|
| 128 | Inside Parameters: | Temp 72.2 | RH 53.8 | CO2 996 |
| 3 | Site | | This is a general issue requiring approved communication among all stakeholders. | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. |
| 3 | Site | | This is a general issue requiring approved communication among all stakeholders. | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. |
| 2 | Site | | Humidity was acceptable at the time of assessment. However, occupant advised that doors are opened in the morning and afternoon allowing humid untreated air into occupied space. | Site based administration to encourage staff to keep doors and windows closed. |

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|--------------|------------|----------------|
| 129 | Inside Parameters: | Temp 72.7 | RH 51.4 | CO2 1011 |

| | | | |
|---|------|--|--|
| 3 | Site | This is a general issue requiring approved communication among all stakeholders. | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. |
| 2 | Site | This is a general issue requiring approved communication among all stakeholders. | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. |

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|--------|----------------|
| 130 | Inside Parameters: | Temp | RH | CO2 |
| | | 72.1 | 51.0 | 1141 |

| | | | |
|---|------|--|--|
| 3 | Site | This is a general issue requiring approved communication among all stakeholders. | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. |
| 3 | Site | This is a general issue requiring approved communication among all stakeholders. | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. |

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|--------|----------------|
| 133 | Inside Parameters: | Temp | RH | CO2 |
| | | 74.1 | 47.7 | 1255 |

| | | | |
|---|------|---|---|
| 2 | Site | Excessive dust accumulation was observed on environmental surfaces at the time of assessment. | Site based administration should address general cleanliness with facility serviceperson staff. |
|---|------|---|---|

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|--------|----------------|
| 134 | Inside Parameters: | Temp | RH | CO2 |
| | | 72.0 | 48.8 | 1163 |

| | | | |
|---|------|---|--|
| 2 | Site | Dust observed on return register at the time of assessment. | Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. |
| 2 | Site | Slight dust and dirt accumulation on floor. | Facilities serviceperson to thoroughly clean and sanitize. |

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|--------|----------------|
| 135A | Inside Parameters: | Temp | RH | CO2 |
| | | 72.3 | 48.9 | 1337 |

| | | | |
|---|------|--|---|
| 2 | Site | Slight dust accumulation was observed on environmental surfaces at the time of assessment. | Site based administration should address general cleanliness with facility serviceperson staff. |
|---|------|--|---|

3 Site This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|--------|----------------|
| 136 | Inside Parameters: | Temp | RH | CO2 |
| | | 72.2 | 52.8 | 1280 |

2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|--------|----------------|
| 138 | Inside Parameters: | Temp | RH | CO2 |
| | | 71.4 | 50.3 | 1129 |

2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.

2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|--------|----------------|
| 139 | Inside Parameters: | Temp | RH | CO2 |
| | | 71.5 | 50.6 | 1000 |

2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|--------|----------------|
| 140 | Inside Parameters: | Temp | RH | CO2 |
| | | 71.8 | 52.3 | 1100 |

2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

| Room | Priority | Responsible | Answer | Recommendation |
|------|----------|-------------|--------|----------------|
| | | | | |

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|--------|----------------|
| 141 | Inside Parameters: | Temp | RH | CO2 |
| | | 71.3 | 50.7 | 987 |

- 2 Site Stuffed animals in room. Minor dust and debris on area rug. Facilities serviceperson to thoroughly clean area rug.
- 2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.
- 2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|--------|----------------|
| 141A | Inside Parameters: | Temp | RH | CO2 |
| | | 71.1 | 50.9 | 976 |

- 2 Site Dust observed on supply register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|--------|----------------|
| 143 | Inside Parameters: | Temp | RH | CO2 |
| | | 70.7 | 52.0 | 1016 |

- 2 Site Dust observed on return register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
- 2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|--------|----------------|
| 143A | Inside Parameters: | Temp | RH | CO2 |
| | | 00 | 00 | 00 |

- 2 Site Dust observed on supply register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

| Room | Priority | Responsible | Answer | Recommendation |
|------|----------|-------------|--------|----------------|
|------|----------|-------------|--------|----------------|

| | | | | |
|-----|--------------------|------|------|-----|
| 144 | Inside Parameters: | Temp | RH | CO2 |
| | | 70.6 | 53.2 | 957 |

- 2 Site Dust observed on supply register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
- 2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|--------|----------------|
| 145 | Inside Parameters: | Temp | RH | CO2 |
| | | 71.0 | 51.1 | 1098 |

- 2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|--------|----------------|
| 145B | Inside Parameters: | Temp | RH | CO2 |
| | | 71,0 | 51.0 | 1097 |

- 2 Site Dust observed on return register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|--------|----------------|
| 145C | Inside Parameters: | Temp | RH | CO2 |
| | | 69.7 | 53.7 | 1091 |

- 2 Site Dust observed on return register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|--------|----------------|
| 147 | Inside Parameters: | Temp | RH | CO2 |
| | | 68.8 | 54.9 | 1022 |

- 2 Site Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment. Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson

2 Site assessment.
Slight dust accumulation was observed on environmental surfaces at the time of assessment.

with their dusting efforts
Site based administration should address general cleanliness with facility serviceperson staff.
Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|--------------|------------|----------------|
| 147A | Inside Parameters: | Temp 68.3 | RH 55.4 | CO2 1016 |

2 Site Temperature was low at the time of assessment.

Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|--------------|------------|----------------|
| 148 | Inside Parameters: | Temp 72.1 | RH 51.5 | CO2 999 |

2 Site Dust observed on return register at the time of assessment.

Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|----------|----------------|
| 155 | Inside Parameters: | Temp 00 | RH 00 | CO2 00 |

2 Site Dust observed on return register at the time of assessment.

Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|-------------|----------------|
| 161 | Inside Parameters: | Temp 76 | RH 50..8 | CO2 982 |

2 Site Dust observed on return register at the time of assessment.

Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

| Room | Priority | Responsible | Answer | Recommendation |
|------|----------|-------------|--------|----------------|
| | Inside | | | |

| | | | | |
|------|-------------|------------|----------|-----------|
| 187A | Parameters: | Temp 00 | RH 00 | CO2 00 |
|------|-------------|------------|----------|-----------|

2 Site Dust and dirt accumulation on floor. Facilities serviceperson to thoroughly clean and sanitize.

| Room | Priority | Responsible | Answer | Recommendation |
|------|-----------------------|--------------|------------|----------------|
| 190 | Inside Parameters: | Temp 73.4 | RH 48.0 | CO2 922 |

2 Site Live plants in room. Plant soil is a source of microbial growth. Site based administration to advise staff to remove live plants.

| Room | Priority | Responsible | Answer | Recommendation |
|------|-----------------------|-------------|----------|----------------|
| 191B | Inside Parameters: | Temp 00 | RH 00 | CO2 00 |

1 Site Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment. Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.

| Room | Priority | Responsible | Answer | Recommendation |
|------|-----------------------|--------------|------------|----------------|
| 192 | Inside Parameters: | Temp 72.5 | RH 51.2 | CO2 1004 |

2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.

2 Site Dust and dirt accumulation on floor. Facilities serviceperson to thoroughly clean and sanitize.

| Room | Priority | Responsible | Answer | Recommendation |
|------|-----------------------|--------------|------------|----------------|
| 193 | Inside Parameters: | Temp 71.1 | RH 52.1 | CO2 903 |

2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.

2 Site Dust and dirt accumulation on floor. Facilities serviceperson to thoroughly clean and sanitize.

2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

| Room | Priority | Responsible | Answer | Recommendation |
|------|----------|-------------|--------|----------------|
|------|----------|-------------|--------|----------------|

| | | | | |
|-----|--------------------|------|------|-----|
| 195 | Inside Parameters: | Temp | RH | CO2 |
| | | 71.6 | 50.7 | 899 |

| | | | |
|---|------|--|--|
| 2 | Site | Slight dust accumulation was observed on environmental surfaces at the time of assessment. | Site based administration should address general cleanliness with facility serviceperson staff. |
| 2 | Site | Temperature was low at the time of assessment. | Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. |
| 1 | Site | No odor identified. However, Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment. | Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room. |

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|--------|----------------|
| 850 | Inside Parameters: | Temp | RH | CO2 |
| | | 73.5 | 52.1 | 1237 |

| | | | |
|---|------|---|--|
| 2 | Site | Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment. | Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts |
| 2 | Site | Dust observed on return register at the time of assessment. | Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. |
| 3 | Site | This is a general issue requiring approved communication among all stakeholders. | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. |
| 3 | Site | This is a general issue requiring approved communication among all stakeholders. | Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. |

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|--------|----------------|
| 852 | Inside Parameters: | Temp | RH | CO2 |
| | | 73.4 | 56.3 | 805 |

| | | | |
|---|------|---|--|
| 2 | Site | Dust observed on return register at the time of assessment. | Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. |
|---|------|---|--|

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|--------|----------------|
| 852A | Inside Parameters: | Temp | RH | CO2 |

| | | | | |
|--|--|----|----|----|
| | | 00 | 00 | 00 |
|--|--|----|----|----|

2 Site Dust observed on supply and return registers at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|--------|----------------|
| 853 | Inside Parameters: | Temp | RH | CO2 |
| | | 72.9 | 52.1 | 1284 |

2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.

2 Site Dust observed on return register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|--------|----------------|
| 854 | Inside Parameters: | Temp | RH | CO2 |
| | | 72.9 | 52.6 | 790 |

2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.

2 Site Dust observed on supply register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

| Room | Priority | Responsible | Answer | Recommendation |
|------|--------------------|-------------|--------|----------------|
| 857 | Inside Parameters: | Temp | RH | CO2 |
| | | 73.4 | 49.7 | 1320 |

2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.

2 Site There appears to be a problem with spill clean up practices. To address all spills in a timely manner, all moisture effected materials must be dried within a 24-hour timeframe. Site based administration should address general cleanliness with facility serviceperson staff.

3 Site This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

3 Site This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.