

Fox Trail Elementary

IAQ Walkthrough 5/6/2005

3531

Outside Temp RH% CO2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
<i>001</i>	Temp	<input type="text" value="76.9"/>	RH% <input type="text" value="41.5"/>	CO2 <input type="text" value="949"/>	Occupants: <input type="text" value="4"/>		
AIR CONDITIONING							
Room is free of smell of mold or mildew?	I am in a portable and we do get some musky smells.			Odor detected at the time of assessment.	Physical Plant Operations to evaluate cause of odor.	Physical Plant Operations	2
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	Waterfountain/faucet probably need tightening again. there is a discoloration on the corner of one of the ceiling tiles.1			Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
Classroom lavatories/water fountains free of leaks?	Waterfountain/faucet probably need tightening again. there is a discoloration on the corner of one of the ceiling tiles.1			No lavatories/water fountains in room.	None		
GENERAL CLEANLINESS							
Room is free of pests?	I am in a portable and occasionally will be visited by ants.			No pests observed at the time of assessment.	None		
<i>007</i>	Temp	<input type="text" value="75.9"/>	RH% <input type="text" value="46.2"/>	CO2 <input type="text" value="704"/>	Occupants: <input type="text" value="4"/>		
AIR CONDITIONING							
Air is flowing without obstruction?				Supply vents closed at the time of assessment.	Facilities serviceperson to open supply vents.	Site Based	2
<i>101G</i>	Temp	<input type="text" value="77.4"/>	RH% <input type="text" value="49.0"/>	CO2 <input type="text" value="1166"/>	Occupants: <input type="text"/>		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
101R	Temp	<input type="text" value="76.2"/>	RH% <input type="text" value="47.6"/>	CO2 <input type="text" value="1118"/>	Occupants: <input type="text"/>		
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?			Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Room is free of pests?			No pests observed at the time of assessment.	None		
103	Temp	<input type="text" value="73.7"/>	RH% <input type="text" value="54.0"/>	CO2 <input type="text" value="920"/>	Occupants: <input type="text"/>		
AIR CONDITIONING							
	Air is flowing without obstruction?		The temperature changes on and off.	Air flowing without obstruction at the time of assessments.	None		
	Room is free of smell of kitchen/food?		The temperature changes on and off.	No odor detected at the time of assessment.	None		
EXCESS MOISTURE IN CLASSROOMS							
	Classroom lavatories/water fountains free of leaks?			No lavatories/water fountains in room.	None		
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.	None		
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None		
	Floor is cleaned on a regular basis?			Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Food, if any, is stored in tightly sealed containers?			No unsealed food items were observed at the time of assessment.	None		
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?			Bathroom exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
	Other exhaust fans that may exist in the classroom are functioning properly?			Exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
THERMAL COMFORT							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
103	Temp	<input type="text" value="73.7"/>	RH%	<input type="text" value="54.0"/>	CO2	<input type="text" value="920"/>	Occupants:	<input type="text"/>
Classroom is free of significant temperature shifts?	After the hurricane I wore my winter jacket for weeks. That must be expensive to run the air that high., Room is sometimes too hot or too cold., The temperature changes on and off., There are some rooms that are freezing, while other rooms are very hot.			Temperature was acceptable at the time of assessment.	None			
Room is usually comfortable? (If no, please explain in the notes below.)	After the hurricane I wore my winter jacket for weeks. That must be expensive to run the air that high., Room is sometimes too hot or too cold., The temperature changes on and off., There are some rooms that are freezing, while other rooms are very hot.			Temperature was acceptable at the time of assessment.	None			
Temperature in my classroom is generally comfortable (72F-76F)?	After the hurricane I wore my winter jacket for weeks. That must be expensive to run the air that high., Room is sometimes too hot or too cold., The temperature changes on and off., There are some rooms that are freezing, while other rooms are very hot.			Temperature was acceptable at the time of assessment.	None			
103D	Temp	<input type="text" value="73.3"/>	RH%	<input type="text" value="53.8"/>	CO2	<input type="text" value="921"/>	Occupants:	<input type="text"/>
LOCAL EXHAUST FANS								
Bathroom exhaust fan is functioning properly?				Bathroom exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations		2
Other exhaust fans that may exist in the classroom are functioning properly?				Exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations		2
104	Temp	<input type="text" value="72.6"/>	RH%	<input type="text" value="47.5"/>	CO2	<input type="text" value="980"/>	Occupants:	<input type="text" value="20"/>
GENERAL CLEANLINESS								
Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None			
THERMAL COMFORT								
Classroom is free of significant temperature shifts?	Too cold			Temperature was acceptable at the time of assessment.	None			
Room is usually comfortable? (If no, please explain in the notes below.)	Too cold			Temperature was acceptable at the time of assessment.	None			
Temperature in my classroom is generally comfortable (72F-76F)?	Too cold			Temperature was acceptable at the time of assessment.	None			

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
109	Temp	72.6	RH% 52.9	CO2 906	Occupants: 24			
AIR CONDITIONING								
Room is free of smell of kitchen/food?					No odor detected at the time of assessment.	None		
GENERAL CLEANLINESS								
Classroom is dusted/vacuumed thoroughly and regularly?					Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
112C	Temp	72.5	RH% 47.3	CO2 1426	Occupants:			
DRAIN TRAPS IN THE CLASSROOM								
Water poured down floor drains once per week (approx. 1 quart of water).					Water is not poured down floor drain at least once a week.	None		
GENERAL CLEANLINESS								
Classroom is dusted/vacuumed thoroughly and regularly?					Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Room is free of the use of scented cleaners and air fresheners?					No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.	None		
LOCAL EXHAUST FANS								
My classroom has sufficient exhaust systems based on the activities/functionality of the room?					It appears that the ventilation system is adequate based on room activities.	None		
THERMAL COMFORT								
Classroom is free of significant temperature shifts?					Temperature was acceptable at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)					Temperature was acceptable at the time of assessment.	None		
Temperature in my classroom is generally comfortable (72F-76F)?					Temperature was acceptable at the time of assessment.	None		
Walkthrough								
					Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
113	Temp	72.5	RH% 50.6	CO2 885	Occupants:		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		
Walkthrough							
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	2
126	Temp	72.2	RH% 52.8	CO2 638	Occupants:	3	
THERMAL COMFORT							
Classroom is free of significant temperature shifts?			It is usually too cold in this classroom.	Temperature was acceptable at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)			It is usually too cold in this classroom.	Temperature was acceptable at the time of assessment.	None		
Temperature in my classroom is generally comfortable (72F-76F)?			It is usually too cold in this classroom.	Temperature was acceptable at the time of assessment.	None		
127	Temp	72.3	RH% 53.6	CO2 785	Occupants:	21	
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
Walkthrough							
				Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
130	Temp	72.3	RH% 52.7	CO2 953	Occupants:	24	
THERMAL COMFORT							
Classroom is free of significant temperature shifts?			Our classroom is always quite cold.	Temperature was acceptable at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)			Our classroom is always quite cold.	Temperature was acceptable at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
131	Temp	72.4	RH% 52.1	CO2 1002	Occupants:		
AIR CONDITIONING							
Room is free of smell of kitchen/food?				No odor detected at the time of assessment.	None		
DRAIN TRAPS IN THE CLASSROOM							
If not regularly used, toilets flushed once each week.				It appears as though toilet is utilized regularly. No sewer gas odor detected. By flushing toilet regularly it eliminates the potential for sewer gas odors.	None		
EXCESS MOISTURE IN CLASSROOMS							
Windows, windowsills and window frames free of continuous condensation?				No condensation on windows at the time of assessment.	None		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		
Room is free of pests?				No pests observed at the time of assessment.	None		
Room is free of the use of scented cleaners and air fresheners?				No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.	None		
THERMAL COMFORT							
Classroom is free of significant temperature shifts?				Temperature was acceptable at the time of assessment.	None		
133	Temp	72.3	RH% 51.6	CO2 989	Occupants:		
THERMAL COMFORT							
Classroom is free of significant temperature shifts?			THE TEMP. IS USUALLY VERY COLD. WHEN IT WAS CORRECTED, IT WAS TOO WARM.	Temperature was acceptable at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)			THE TEMP. IS USUALLY VERY COLD. WHEN IT WAS CORRECTED, IT WAS TOO WARM.	Temperature was acceptable at the time of assessment.	None		
Temperature in my classroom is generally comfortable (72F-76F)?			THE TEMP. IS USUALLY VERY COLD. WHEN IT WAS CORRECTED, IT WAS TOO WARM.	Temperature was acceptable at the time of assessment.	None		
Walkthrough							
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
137	Temp	<input type="text" value="71.9"/>	RH% <input type="text" value="53.6"/>	CO2 <input type="text" value="1011"/>	Occupants: <input type="text"/>		
THERMAL COMFORT							
Classroom is free of significant temperature shifts?				Temperature was acceptable at the time of assessment.	None		
138	Temp	<input type="text" value="72.0"/>	RH% <input type="text" value="47.4"/>	CO2 <input type="text" value="1091"/>	Occupants: <input type="text"/>		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		
140	Temp	<input type="text" value="72.3"/>	RH% <input type="text" value="52.5"/>	CO2 <input type="text" value="1163"/>	Occupants: <input type="text"/>		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				I am trying to mark no for question 2, about the room being dusted and vacuumed thoroughly and regularly, however the review is not marking the correct line. It is marking a no for trash bags. Just a note...	There does not appear to be a dusting issue within this room.	None	
Walkthrough							
				Unsealed food items were observed at the time of assessment. Unsealed food items may attract pests.	Site based administration should encourage all staff to maintain food items within sealable plastic storage containers.	Site Based	2
149	Temp	<input type="text" value="72.2"/>	RH% <input type="text" value="51.2"/>	CO2 <input type="text" value="1052"/>	Occupants: <input type="text" value="21"/>		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		
Walkthrough							
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	2
155	Temp	<input type="text" value="72.6"/>	RH% <input type="text" value="54.8"/>	CO2 <input type="text" value="967"/>	Occupants: <input type="text"/>		
EXCESS MOISTURE IN CLASSROOMS							
Windows, windowsills and window frames free of continuous condensation?				No condensation on windows at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
155	Temp	72.6	RH% 54.8	CO2 967	Occupants:		
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.		None		
Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.		None		
Room is free of pests?			No pests observed at the time of assessment.		None		
Walkthrough							
			Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.		Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.		2
157	Temp	72.9	RH% 53.7	CO2 973	Occupants:	20	
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			The ant problem has been taken care of.		None		
Classroom is dusted/vacuumed thoroughly and regularly?			The ant problem has been taken care of.		Site based administration should address general cleanliness with facility serviceperson staff.		2
Walkthrough							
			Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.		Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.		2
158	Temp	72.9	RH% 50.7	CO2 992	Occupants:	12	
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.		2
161	Temp	72.7	RH% 53.8	CO2 1151	Occupants:	27	
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			rooms are not mopped on a regular basis		None		
Classroom is dusted/vacuumed thoroughly and regularly?			rooms are not mopped on a regular basis		None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
161	Temp	72.7	RH% 53.8	CO2 1151	Occupants: 27		
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?	Rooms are comfortable when the A/C is working properly.		Temperature was acceptable at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)	Rooms are comfortable when the A/C is working properly.		Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?	Rooms are comfortable when the A/C is working properly.		Temperature was acceptable at the time of assessment.	None		
Walkthrough							
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	2
162	Temp	71.6	RH% 52.1	CO2 887	Occupants: 4		
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	waiting on cabinet to be fixed since the 10th. told it will be fixed this week		No dust observed on supply/return registers at the time of assessment.	None		
THERMAL COMFORT							
	Room is usually comfortable? (If no, please explain in the notes below.)	very cold usually		Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?	very cold usually		Temperature was acceptable at the time of assessment.	None		
164	Temp	72.1	RH% 53.6	CO2 902	Occupants: 4		
AIR CONDITIONING							
	Air flowing from air supply?			Air flowing without obstruction at the time of assessments.	None		
	Air is flowing without obstruction?			Air flowing without obstruction at the time of assessments.	None		
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
DRAIN TRAPS IN THE CLASSROOM							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
164	Temp	72.1	RH% 53.6	CO2 902	Occupants: 4		
	Water poured down floor drains once per week (approx. 1 quart of water).				It appears as though water is poured down the floor drain at least once a week.	None	
	Water run in sinks at least once per week (about 2 cups of water).				It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	None	
EXCESS MOISTURE IN CLASSROOMS							
	Windows, windowsills and window frames free of continuous condensation?				No condensation on windows at the time of assessment.	None	
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address locker room and shower maintenance/general cleanliness with facility serviceperson staff.	Site Based 2
	Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Room is free of pests?				No pests observed at the time of assessment.	None	
LOCAL EXHAUST FANS							
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?				It appears that classroom/functions are not consistent with educational specifications for room use.	Site based administration to discuss with facility Project Manager.	Site Based 2
	Other exhaust fans that may exist in the classroom are functioning properly?				Exhaust fan is functioning properly.	None	
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?		My room has been too hot the whole seven years that I;ve been here.		Temperature was acceptable at the time of assessment.	None	
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		My room has been too hot the whole seven years that I;ve been here.		Humidity was acceptable at the time of assessment.	None	
	Room is usually comfortable? (If no, please explain in the notes below.)		My room has been too hot the whole seven years that I;ve been here.		Temperature was acceptable at the time of assessment.	None	
	Temperature in my classroom is generally comfortable (72F-76F)?		My room has been too hot the whole seven years that I;ve been here.		Temperature was acceptable at the time of assessment.	None	

Walkthrough

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
164	Temp	<input type="text" value="72.1"/>	RH% <input type="text" value="53.6"/>	CO2 <input type="text" value="902"/>	Occupants: <input type="text" value="4"/>		
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	2
202	Temp	<input type="text" value="71.9"/>	RH% <input type="text" value="65.1"/>	CO2 <input type="text" value="954"/>	Occupants: <input type="text" value="4"/>		
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None		
	Walkthrough						
				Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
204	Temp	<input type="text" value="71.9"/>	RH% <input type="text" value="63.3"/>	CO2 <input type="text" value="884"/>	Occupants: <input type="text"/>		
	ANIMALS IN THE CLASSROOM						
	Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Physical Plant Operations	3
	EXCESS MOISTURE IN CLASSROOMS						
	Windows, windowsills and window frames free of continuous condensation?			No condensation on windows at the time of assessment.	None		
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?			Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	LOCAL EXHAUST FANS						
	Bathroom exhaust fan is functioning properly?		No exhaust fans within the room or bathroom.	Bathroom exhaust fan is functioning properly.	None		
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?		No exhaust fans within the room or bathroom.	Exhaust fan is functioning properly.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
204	Temp	71.9	RH% 63.3	CO2 884	Occupants:			
	Other exhaust fans that may exist in the classroom are functioning properly?	No exhaust fans within the room or bathroom.			Exhaust fan is functioning properly.	None		
	THERMAL COMFORT							
	Classroom is free of significant temperature shifts?	Extreme variance in temperature within the classrooms. Upstairs rooms are often hotter than the rest of the school. Temperature within classrooms vary from one room to the next. (Seem to have a pattern of one cold room, one hot room, etc.) Humidity fe			Temperature was acceptable at the time of assessment.	None		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Extreme variance in temperature within the classrooms. Upstairs rooms are often hotter than the rest of the school. Temperature within classrooms vary from one room to the next. (Seem to have a pattern of one cold room, one hot room, etc.) Humidity fe			Humidity was acceptable at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)	Extreme variance in temperature within the classrooms. Upstairs rooms are often hotter than the rest of the school. Temperature within classrooms vary from one room to the next. (Seem to have a pattern of one cold room, one hot room, etc.) Humidity fe			Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?	Extreme variance in temperature within the classrooms. Upstairs rooms are often hotter than the rest of the school. Temperature within classrooms vary from one room to the next. (Seem to have a pattern of one cold room, one hot room, etc.) Humidity fe			Temperature was acceptable at the time of assessment.	None		
205	Temp	72.0	RH% 66.1	CO2 813	Occupants:			
	EXCESS MOISTURE IN CLASSROOMS							
	Area around and under classroom sinks free of leaks?				No leaks or signs of water intrusion identified.	None		
	Classroom lavatories/water fountains free of leaks?				No lavatories/water fountains in room.	None		
	GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
205	Temp	<input type="text" value="72.0"/>	RH% <input type="text" value="66.1"/>	CO2 <input type="text" value="813"/>	Occupants: <input type="text"/>		
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?	Room is way to hot. I am sweating by 10:00.		Temperature was acceptable at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)	Room is way to hot. I am sweating by 10:00.		Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?	Room is way to hot. I am sweating by 10:00.		Temperature was acceptable at the time of assessment.	None		
209	Temp	<input type="text" value="71.8"/>	RH% <input type="text" value="51.8"/>	CO2 <input type="text" value="661"/>	Occupants: <input type="text"/>		
EXCESS MOISTURE IN CLASSROOMS							
	Classroom lavatories/water fountains free of leaks?			Signs of water intrusion. Leak identified.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
	Walkthrough			Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	2
210	Temp	<input type="text" value="72.0"/>	RH% <input type="text" value="53.7"/>	CO2 <input type="text" value="616"/>	Occupants: <input type="text" value="4"/>		
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?			Temperature was acceptable at the time of assessment.	None		
	Walkthrough			Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
212	Temp	<input type="text" value="70.4"/>	RH% <input type="text" value="56.0"/>	CO2 <input type="text" value="575"/>	Occupants: <input type="text"/>		
DRAIN TRAPS IN THE CLASSROOM							
	Water poured down floor drains once per week (approx. 1 quart of water).			It appears as though water is poured down the floor drain at least once a week.	None		
	Water run in sinks at least once per week (about 2 cups of water).			It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	None		
GENERAL CLEANLINESS							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
212	Temp	70.4	RH% 56.0	CO2 575	Occupants: <input type="text"/>		
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Room is free of pests?			No pests observed at the time of assessment.	None		
	Walkthrough						
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	2
213	Temp	70.7	RH% 49.8	CO2 617	Occupants: <input type="text"/>		
	EXCESS MOISTURE IN CLASSROOMS						
	Classroom lavatories/water fountains free of leaks?			No lavatories/water fountains in room.	None		
214	Temp	70.4	RH% 56.4	CO2 577	Occupants: <input type="text"/>		
	ANIMALS IN THE CLASSROOM						
	Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	GENERAL CLEANLINESS						
	Room is free of pests?			No pests observed at the time of assessment.	None		
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?			Temperature was acceptable at the time of assessment.	None		
	Walkthrough						
				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
215	Temp	70.9	RH% 51.0	CO2 613	Occupants:		
DRAIN TRAPS IN THE CLASSROOM							
If not regularly used, toilets flushed once each week.				It appears as though toilet is utilized regularly. No sewer gas odor detected. By flushing toilet regularly it eliminates the potential for sewer gas odors.	None		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Physical Plant Operations	2
THERMAL COMFORT							
Classroom is free of significant temperature shifts?				Temperature was low at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based	2
Room is usually comfortable? (If no, please explain in the notes below.)				Temperature was low at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based	2
Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was elevated at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based	2
216	Temp	71.6	RH% 54.1	CO2 534	Occupants:		
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks or signs of water intrusion identified.	None		
LOCAL EXHAUST FANS							
Bathroom exhaust fan is functioning properly?				Bathroom exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
THERMAL COMFORT							
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		OUR CLASSROOM GOES FROM HOT TO COLD PERIODICALLY... AFTER THE WEEKEND, IT IS GENERALLY HUMID AND STICKY IN THE ROOM. THE PAPERS ON THE WALLS INDICATE THAT THE AIR MAY HAVE BEEN OFF.		Humidity was acceptable at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)		OUR CLASSROOM GOES FROM HOT TO COLD PERIODICALLY... AFTER THE WEEKEND, IT IS GENERALLY HUMID AND STICKY IN THE ROOM. THE PAPERS ON THE WALLS INDICATE THAT THE AIR MAY HAVE BEEN OFF.		Temperature was low at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
217	Temp	71.4	RH% 51.2	CO2 607	Occupants:		
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based		2
223	Temp	71.3	RH% 52.8	CO2 688	Occupants:	20	
AIR CONDITIONING							
Room is free of smell of vehicle exhaust?			D) In the afternoons, the exhaust from the buses is very strong.	No odor detected at the time of assessment.	None		
ANIMALS IN THE CLASSROOM							
You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based		3
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations		1
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based		2
THERMAL COMFORT							
Classroom is free of significant temperature shifts?			Temperature was low at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based		2
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)			Humidity was acceptable at the time of assessment.	None			
Walkthrough							
			Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based		2
224	Temp	71.6	RH% 51.9	CO2 603	Occupants:		
GENERAL CLEANLINESS							
Room is free of pests?			No pests observed at the time of assessment.	None			

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
224	Temp	71.6	RH%	51.9	CO2	603	Occupants:				
	Room is free of the use of scented cleaners and air fresheners?			Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based					1
227	Temp	71.7	RH%	50.0	CO2	681	Occupants:				
	GENERAL CLEANLINESS										
	Classroom is dusted/vacuumed thoroughly and regularly?			rooms are not swept on a regular basis and dust is building on the computer tables and window sills	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based				2
	Classrooms general appearance is clean and acceptable?			rooms are not swept on a regular basis and dust is building on the computer tables and window sills	General cleanliness of the room at the time of assessment was acceptable.	None					
	Floor is cleaned on a regular basis?			rooms are not swept on a regular basis and dust is building on the computer tables and window sills	Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based				2
	THERMAL COMFORT										
	Classroom is free of significant temperature shifts?			Rooms are comfortable when air conditioning is working properly	Temperature was low at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based				2
	Room is usually comfortable? (If no, please explain in the notes below.)			Rooms are comfortable when air conditioning is working properly	Temperature was low at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based				2
	Temperature in my classroom is generally comfortable (72F-76F)?			Rooms are comfortable when air conditioning is working properly	Temperature was low at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based				2
	Walkthrough										
					Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based				2
230	Temp	72.0	RH%	51.2	CO2	590	Occupants:				
	GENERAL CLEANLINESS										
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based				2
	Walkthrough										
					Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based				2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

232

Temp RH% CO2 Occupants:

THERMAL COMFORT

Room is usually comfortable? (If no, please explain in the notes below.)

It is very cold in my room.

Temperature was low at the time of assessment.

Facilities serviceperson should monitor this room.

Site Based

2

Temperature in my classroom is generally comfortable (72F-76F)?

It is very cold in my room.

Temperature was low at the time of assessment.

Facilities serviceperson should monitor this room.

Site Based

2

Walkthrough

Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.

Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.

Site Based

2

301

Temp RH% CO2 Occupants:

GENERAL CLEANLINESS

Classroom is dusted/vacuumed thoroughly and regularly?

There does not appear to be a dusting issue within this room.

None

Trash is removed daily and trash bags are changed as appropriate?

No issues identified regarding trash removal practices.

None