

Tools for Schools Phase II - Indoor Air Quality

Follow-up Action Plan for Site Based



Gator Run Elementary

3642

74.5 68.5 498

Principal: Ms. Susan Sasse

Walkthrough Date: 4/21/2005

Temp RH Co2
Outside Measurements

Room	Priority	Responsible	Response	Recommendation
101G	3	Site Based	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
101W	2	Site Based	Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.
101W	3	Site Based	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
101W	3	Site Based	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
101Y	2	Site Based	Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.
101Y	2	Site Based	Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.
101Y	2	Site Based	Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.
103	2	Site Based	Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.
103	2	Site Based	Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
103	2	Site Based	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
103	3	Site Based	This is a general issue requiring approved communication among all stakeholders.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.
103	3	Site Based	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
112F	2	Site Based	Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.

Room	Priority	Responsible	Response	Recommendation
129	2	Site Based	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
129	2	Site Based	Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.
130	2	Site Based	Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.
132	2	Site Based	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
133	2	Site Based	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
134	2	Site Based	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
134	2	Site Based	Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.
134	2	Site Based	Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
135	2	Site Based	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
1376C	2	Site Based	Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.
1378C	2	Site Based	Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
1378C	2	Site Based	Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.
1396C	2	Site Based	Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.
1396C	2	Site Based	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
1396C	2	Site Based	Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
1397C	2	Site Based	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
142	3	Site Based	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
143	3	Site Based	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Response	Recommendation
151	2	Site Based	Unsealed food items were observed at the time of assessment. Unsealed food items may attract pests.	Site based administration should encourage all staff to maintain food items within sealable plastic storage containers.
154	3	Site Based	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
156	3	Site Based	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
208	2	Site Based	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
208	2	Site Based	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
212	2	Site Based	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
212	2	Site Based	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
212	2	Site Based	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
212	2	Site Based	Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.
213	2	Site Based	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Response	Recommendation
213	2	Site Based	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
215	2	Site Based	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
215	2	Site Based	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
218	2	Site Based	Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.
218	3	Site Based	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
221	2	Site Based	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
221	2	Site Based	Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.
221	2	Site Based	Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.
230	2	Site Based	Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
232	2	Site Based	It appears that classroom/functions are not consistent with educational specifications for room use.	Site based administration to discuss with facility Project Manager.
234	2	Site Based	Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
234	2	Site Based	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
234	3	Site Based	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
235	2	Site Based	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.

Room	Priority	Responsible	Response	Recommendation
236	2	Site Based	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
236	2	Site Based	Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
236	3	Site Based	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
237	2	Site Based	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
237	2	Site Based	Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
237	2	Site Based	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
237	3	Site Based	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.