Gator Run Elementary IAQ Walkthrough 4/21/2005

3642

Outside Temp 74.5 **RH%** 68.5 **CO2** 498

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
<i>101G</i> Temp	75.5 RH% 46.9 CO2 1043	Occupants:			
ANIMALS IN THE CLASSROOM					
Activities and/or room conditions are modified to address student allergies?		This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS					
Classroom is dusted/vacuumed thoroughly and regularly?		There does not appear to be a dusting issue within this room.	None		
THERMAL COMFORT					
Classroom is free of significant temperature shifts?	my office is usually a little too warm.	Temperature was acceptable at the time of assessment.	None		
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	my office is usually a little too warm.	Humidity was acceptable at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)	my office is usually a little too warm.	Temperature was acceptable at the time of assessment.	None		
Temperature in my classroom is generally comfortable (72F-76F)?	my office is usually a little too warm.	Temperature was acceptable at the time of assessment.	None		
101W Тетр	75.7 RH% 47.1 CO2 952	Occupants: 4			
ANIMALS IN THE CLASSROOM					
Activities and/or room conditions are modified to address student allergies?		This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
You are informed about the potential allergies of your students?		This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3

GENERAL CLEANLINESS

FISH/Room		Participant	Comment	S	Response	Recommendation	Responsible	Priority
101W Temp	75.7	RH% 47.1	CO2	952	Occupants: 4			
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?					No dust observed on supply/return registers at the time of assessment.	None		
Classroom is dusted/vacuumed thoroughly and regularly?					There does not appear to be a dusting issue within this room.	None		
Classrooms general appearance is clean and acceptable?					General cleanliness of the room at the time of assessment was acceptable.	None		
Floor is cleaned on a regular basis?					Floor was clean at the time of assessment.	None		
Spills and other such issues requiring custodial assistance are addressed in a timely manner?					No issues identified relating to spill clean up practices at the time of assessment.	None		
LOCAL EXHAUST FANS								
Bathroom exhaust fan is functioning properly?					Bathroom exhaust fan is functioning properly.	None		
Walkthrough					Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
<i>101Y</i> Тетр	72.3	RH% 49.6	CO2	780	Occupants: 2			
THERMAL COMFORT								
Classroom is free of significant temperature shifts?		It is very cold.			Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based	2
Room is usually comfortable? (If no, please explain in the notes below.)		It is very cold.			Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based	2
Temperature in my classroom is generally comfortable (72F-76F)?		It is very cold.			Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based	2
103 Тетр	74.7	RH% 51.5	CO2	901	Occupants: 26			
AIR CONDITIONING								
Air is flowing without obstruction?		Sometimes a moldy, r noticeable	nildewy smel	l is	Air flowing without obstruction at the time of assessments.	None		
Room is free of smell of mold or mildew?		Sometimes a moldy, r noticeable	nildewy smel	l is	No odor detected at the time of assessment.	None		

ANIMALS IN THE CLASSROOM

I/Room	Participant Comments	Response	Recommendation	Responsible	Priorit
Temp	74.7 RH% 51.5 CO2 901	Occupants: 26			
Activities and/or room conditions are modified to address student allergies?		This is a general issue requiring approved communication among all stakeholders.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Site Based	3
You are informed about the potential allergies of your students?		This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS					
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Classroom is dusted/vacuumed thoroughly and regularly?		Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Classrooms general appearance is clean and acceptable?		General cleanliness of the room at the time of assessment was acceptable.	None		
Floor is cleaned on a regular basis?		Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Room is free of pests?		No pests observed at the time of assessment.	None		
Spills and other such issues requiring custodial assistance are addressed in a timely manner?		No issues identified relating to spill clean up practices at the time of assessment	None		
LOCAL EXHAUST FANS					
Bathroom exhaust fan is functioning properly?		Bathroom exhaust fan is functioning properly.	None		
My classroom has sufficient exhaust systems based on the activities/functionality of the room?		It appears that the ventilation system is adequate based on room activities.	None		
THERMAL COMFORT					
Classroom is free of significant temperature shifts?	After 11:00 AM room usually gets very cold and many have stated so., It is generally very cold or very warm in the media center	Temperature was acceptable at the time of assessment.	None		
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	After 11:00 AM room usually gets very cold and many have stated so., It is generally very cold or very warm in the media center	Humidity was acceptable at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)	After 11:00 AM room usually gets very cold and many have stated so., It is generally very cold or very warm in the media center	Temperature was acceptable at the time of assessment.	None		

FISH/R	oom	Participant Comments	Response	Recommendation	Responsible	Priority
103	Temperature in my classroom is generally comfortable (72F-	74.7 RH% 51.5 CO2 901 After 11:00 AM room usually gets very cold	Occupants: 26 Temperature was acceptable at the time of	None		
	76F)?	and many have stated so., It is generally very cold or very warm in the media center	assessment.			
103G	Temp	73.7 RH% 47.8 CO2 864	Occupants: 5			
	GENERAL CLEANLINESS					
	Classroom is dusted/vacuumed thoroughly and regularly?		There does not appear to be a dusting issue within this room.	None		
103H	Temp	72.0 RH% 52.7 CO2 810	Occupants: 3			
	GENERAL CLEANLINESS					
	Classroom is dusted/vacuumed thoroughly and regularly?	have more allergies this year than before	There does not appear to be a dusting issue within this room.	None		
	THERMAL COMFORT					
	Room is usually comfortable? (If no, please explain in the notes below.)	too cold- need to dress for winter everyday- lots of layers	Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?	too cold- need to dress for winter everyday- lots of layers	Temperature was acceptable at the time of assessment.	None		
109C	Temp	73.3 RH% 51.1 CO2 827	Occupants: 13			
	AIR CONDITIONING					
	Room is free of smell of kitchen/food?		No odor detected at the time of assessment.	None		
	GENERAL CLEANLINESS					
	Trash is removed daily and trash bags are changed as appropriate?		No issues identified regarding trash removal practices.	None		
112F	Temp	RH% CO2	Occupants:			
	AIR CONDITIONING					
	Room is free of smell of chemicals?	Cooking and chemical, (bleach), smells are carried in from the kitchen via the ventilation system.	No odor detected at the time of assessment.	None		
	Room is free of smell of kitchen/food?	Cooking and chemical, (bleach), smells are carried in from the kitchen via the ventilation system.	No odor detected at the time of assessment.	None		

FISH/I	Room	Participant Comments	Response	Recommendation	Responsible	Priority
112F	Temp	RH% CO2	Occupants:			
	EXCESS MOISTURE IN CLASSROOMS					
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?		No leaks or signs of water intrusion identified.	None		
	GENERAL CLEANLINESS					
	Classroom is dusted/vacuumed thoroughly and regularly?		There does not appear to be a dusting issue within this room.	None		
	Classrooms general appearance is clean and acceptable?		General cleanliness of the room at the time of assessment was acceptable.	None		
	Floor is cleaned on a regular basis?		Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Room is free of pests?		No pests observed at the time of assessment.	None		
	Trash is removed daily and trash bags are changed as appropriate?		No issues identified regarding trash removal practices.	None		
128	Temp	75.4 RH% 47.4 CO2 1777	Occupants: 3			
	THERMAL COMFORT					
	Room is usually comfortable? (If no, please explain in the notes below.)	Sometimes it is very hot in this room.	Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?	Sometimes it is very hot in this room.	Temperature was acceptable at the time of assessment.	None		
129	Тетр	75.7 RH% 47.5 CO2 1715	Occupants: 18			
	GENERAL CLEANLINESS					
	Classroom is dusted/vacuumed thoroughly and regularly?	Middle of floor is cleaned regularly. Perimeter of room is rarely touched.	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Room is free of pests?	Middle of floor is cleaned regularly. Perimeter of room is rarely touched.	Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operation	ns 2
	Walkthrough					
	-		Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2

FISH/Room			Participant Comments	Response	Recommendation	Responsible	Priority
130	Тетр	74.6	RH% 48.0 CO2 1929	Occupants: 27			
GENERAL CI Floor is clear	LEANLINESS ned on a regular basis?			Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
132	Тетр	73.5	RH% 51.1 CO2 897	Occupants:			
GENERAL CI Classroom is	LEANLINESS dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
133	Тетр	73.9	RH% 52.0 CO2 1004	Occupants:			
GENERAL CI Classroom is	LEANLINESS dusted/vacuumed thoroughly and regularly?		floor is swept, but not mopped.	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
134	Тетр	73.3	RH% 52.2 CO2 963	Occupants: 3			
GENERAL CI	LEANLINESS						
	turn registers are cleaned regularly and free of ris accumulation?		Room is not mopped or dusted on a regular basis. The counters and cabinets are also not cleaned regularly.	Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Classroom is	dusted/vacuumed thoroughly and regularly?		Room is not mopped or dusted on a regular basis. The counters and cabinets are also not cleaned regularly.	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Floor is clear	ned on a regular basis?		Room is not mopped or dusted on a regular basis. The counters and cabinets are also not cleaned regularly.	Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
135	Temp	72.2	RH% 52.0 CO2 691	Occupants: 2			
GENERAL CI Classroom is	LEANLINESS dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
THERMAL C	OMFORT						

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
135 Temp 72.2	RH% 52.0 CO2 691	Occupants: 2			
Room is usually comfortable? (If no, please explain in the notes below.)	The room is always very cold. Myself, students, and parents often comment about the cold temperature of the room. Students often have to bring a sweater or sweatshirt to be confortable.	Temperature was acceptable at the time of assessment.	None		
Temperature in my classroom is generally comfortable (72F-76F)?	The room is always very cold. Myself, students, and parents often comment about the cold temperature of the room. Students often have to bring a sweater or sweatshirt to be confortable.	Temperature was acceptable at the time of assessment.	None		
<i>1375C</i> Temp 73.4	RH% 60.3 CO2 2184	Occupants: 2			
LOCAL EXHAUST FANS					
Bathroom exhaust fan is functioning properly?		Bathroom exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	s 2
THERMAL COMFORT					
Classroom is free of significant temperature shifts?		Temperature was acceptable at the time of assessment.	None		
<i>1376C</i> Temp 74.6	RH% 63.5 CO2 2404	Occupants: 22			
ANIMALS IN THE CLASSROOM					
Classroom is free of animals and pets?	I have a pet hamster in the classroom as permitted by administration. No students in the class have allergies.	No animals identified at the time of assessment.	None		
EXCESS MOISTURE IN CLASSROOMS					
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?		Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
GENERAL CLEANLINESS					
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		No dust observed on supply/return registers at the time of assessment.	None		
Room is free of pests?		Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	s 2

THERMAL COMFORT

FISH/Room	m	Participant Comments	Response	Recommendation	Responsible	Priority
1376C	Temp 74	4.6 RH% 63.5 CO2 2404	Occupants: 22			
	Classroom is free of significant temperature shifts?	We are unable to control temperature in the portable individually and must call custodian to adjust. It gets too cold when the a/c is on and on cold mornings my room does not get to a comfortable temp until about 10:30.	Temperature was acceptable at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)	We are unable to control temperature in the portable individually and must call custodian to adjust. It gets too cold when the a/c is on and on cold mornings my room does not get to a comfortable temp until about 10:30.	Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was acceptable at the time of assessment.	None			
1377C	Temp 74	4.6 RH% 59.7 CO2 1789	Occupants: 18			
Gl	ENERAL CLEANLINESS					
	Room is free of pests?		No pests observed at the time of assessment.	None		
LO	OCAL EXHAUST FANS					
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?		It appears that the ventilation system is adequate based on room activities.	None		
TI	HERMAL COMFORT					
	Classroom is free of significant temperature shifts?	No, it is a portable and the air temperature varies a lot.	Temperature was acceptable at the time of assessment.	None		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	No, it is a portable and the air temperature varies a lot.	Humidity was acceptable at the time of assessment.	None		
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	No, it is a portable and the air temperature varies a lot.	Temperature was acceptable at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)	No, it is a portable and the air temperature varies a lot.	Temperature was acceptable at the time of assessment.	None		
1378C	Temp 72	2.7 RH% 64.1 CO2 1857	Occupants: 21			
EX	XCESS MOISTURE IN CLASSROOMS					
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?		Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
<i>1378C</i> Temp	72.7 RH% 64.1 CO2 1857	Occupants: 21			
GENERAL CLEANLINESS					
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Cleaners that are used have an awful odor. I would like to know why air fresheners that are not electric may not be used.	Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
THERMAL COMFORT					
Classroom is free of significant temperature shifts?	Maintance has been out and put a lock on my air. It is unbearable. If I am responsible enough to teach first graders I would think the school board would give me the benefit to control my air system.	Temperature was acceptable at the time of assessment.	None		
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Maintance has been out and put a lock on my air. It is unbearable. If I am responsible enough to teach first graders I would think the school board would give me the benefit to control my air system.	Humidity was slightly elevated at the time of assessment - 10% greater than outdoors.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operation:	s 2
Room is usually comfortable? (If no, please explain in the notes below.)	Maintance has been out and put a lock on my air. It is unbearable. If I am responsible enough to teach first graders I would think the school board would give me the benefit to control my air system.	Temperature was acceptable at the time of assessment.	None		
Temperature in my classroom is generally comfortable (72F-76F)?	Maintance has been out and put a lock on my air. It is unbearable. If I am responsible enough to teach first graders I would think the school board would give me the benefit to control my air system.	Temperature was acceptable at the time of assessment.	None		
<i>1396C</i> Temp	76.2 RH% 63.3 CO2 2458	Occupants: 18			
GENERAL CLEANLINESS					
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Floor is swept, but not mopped	Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Classroom is dusted/vacuumed thoroughly and regularly?	Floor is swept, but not mopped	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Floor is cleaned on a regular basis?	Floor is swept, but not mopped	Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
THERMAL COMFORT					
Room is usually comfortable? (If no, please explain in the notes below.)	The lock box placed on the thermostat prevents the temperature from being comfortable.	Temperature was acceptable at the time of assessment.	None		

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
1396С тетр	76.2 RH% 63.3 CO2 2458	Occupants: 18			
Temperature in my classroom is generally comfortable (72F-76F)?	The lock box placed on the thermostat prevents the temperature from being comfortable.	Temperature was acceptable at the time of assessment.	None		
1397С Тетр	75.6 RH% 56.3 CO2 2812	Occupants: 24			
GENERAL CLEANLINESS					
Classroom is dusted/vacuumed thoroughly and regularly?		Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
THERMAL COMFORT					
Room is usually comfortable? (If no, please explain in the notes below.)	I am in a portable and while the air is set at 72 degrees, which is said to be a comfortable temperature, it gets extremely hot with a classroom full of students.	Temperature was acceptable at the time of assessment.	None		
142 Temp	73.1 RH% 53.6 CO2 808	Occupants: 2			
ANIMALS IN THE CLASSROOM					
Activities and/or room conditions are modified to address student allergies?		This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
143 Temp	73.8 RH% 51.8 CO2 841	Occupants: 18			
ANIMALS IN THE CLASSROOM					
Activities and/or room conditions are modified to address student allergies?		This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS					
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		No dust observed on supply/return registers at the time of assessment.	None		
Classroom is dusted/vacuumed thoroughly and regularly?		There does not appear to be a dusting issue within this room.	None		
Classrooms general appearance is clean and acceptable?		General cleanliness of the room at the time of assessment was acceptable.	None		
Floor is cleaned on a regular basis?		Floor was clean at the time of assessment.	None		

FISH/I	Room		Participant	Comments		Response	Recommendation	Responsible	Priority
143	Temp Spills and other such issues requiring custodial assistance are addressed in a timely manner?	73.8	RH% 51.8	CO2	841	Occupants: 18 No issues identified relating to spill clean up practices at the time of assessment	None		
145	Temp	73.3	RH% 51.9	CO2	864	Occupants: 19			
	EXCESS MOISTURE IN CLASSROOMS								
	Area around and under classroom sinks free of leaks?					No leaks or signs of water intrusion identified.	None		
	GENERAL CLEANLINESS								
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?					No dust observed on supply/return registers at the time of assessment.	None		
	Classroom is dusted/vacuumed thoroughly and regularly?					There does not appear to be a dusting issue within this room.	None		
	Floor is cleaned on a regular basis?					Floor was clean at the time of assessment.	None		
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?					No issues identified relating to spill clean up practices at the time of assessment	None		
150	Тетр	74.5	RH% 54.1	CO2	828	Occupants: 13			
	GENERAL CLEANLINESS Room is free of pests?		Survey completed by paraprofessionals.	teacher and		No pests observed at the time of assessment.	None		
151	Temp	73.2	RH% 51.9	CO2	726	Occupants: 4			
	DRAIN TRAPS IN THE CLASSROOM Water poured down floor drains once per week (approx. 1 quart of water).					It appears as though water is poured down the floor drain at least once a week.	None		
	GENERAL CLEANLINESS								
	Room is free of pests?	a	ants			No pests observed at the time of assessment.	None		
	Walkthrough								
	-					Unsealed food items were observed at the time of assessment. Unsealed food items may attract pests.	Site based administration should encourage all staff to maintain food items within sealable plastic storage containers.	Site Based	2

FISH/	Room		Participan	t Comme	nts	Response	Recommendation	Responsible	Priority
152	Тетр	72.4	RH% 52.8	CO2	688	Occupants: 2			
	AIR CONDITIONING								
	Room is free of smell of vehicle exhaust?		Room does not smel when any work with cleaner) the fumes a	other maching	nes (pressure	No odor detected at the time of assessment.	None		
	EXCESS MOISTURE IN CLASSROOMS								
	Windows, windowsills and window frames free of continuous condensation?					Condensation on windows at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
	THERMAL COMFORT								
	Classroom is free of significant temperature shifts?		The room can be wa	rm/humid at	times	Temperature was acceptable at the time of assessment.	None		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		The room can be wa	rm/humid at	times	Humidity was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?		The room can be wa	rm/humid at	times	Temperature was acceptable at the time of assessment.	None		
153	Тетр	75.9	RH% 50.5	CO2	874	Occupants:			
	ANIMALS IN THE CLASSROOM								
	Classroom is free of animals and pets?					No animals identified at the time of assessment.	None		
	EXCESS MOISTURE IN CLASSROOMS								
	Area around and under classroom sinks free of leaks?					Signs of water intrusion.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
	GENERAL CLEANLINESS								
	Classroom is dusted/vacuumed thoroughly and regularly?					There does not appear to be a dusting issue within this room.	None		
	Room is free of pests?					No pests observed at the time of assessment.	None		
	THERMAL COMFORT								
	Classroom is free of significant temperature shifts?					Temperature was acceptable at the time of assessment.	None		

FISH/Room		Partici	pant Co	omments		Response	Recommendation	Responsible	Priority
154	Гетр 74.9	RH%	52.8	CO2	794	Occupants:			
ANIMALS IN THE CLASSROOM									
Activities and/or room conditions are modified to a student allergies?	ddress					This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
Classroom is free of animals and pets?						No animals identified at the time of assessment.	None		
GENERAL CLEANLINESS									
Classroom is dusted/vacuumed thoroughly and regu	ılarly?					There does not appear to be a dusting issue within this room.	None		
Floor is cleaned on a regular basis?						Floor was clean at the time of assessment.	None		
Room is free of pests?						No pests observed at the time of assessment.	None		
155	Гетр 73.0	RH%	54.3	CO2	586	Occupants:			
AIR CONDITIONING									
Room is free of smell of vehicle exhaust?		Anytime that w grass, painting, seep into my ro recently. I felt Earlier in the y evacuated to a	pressure com. This nautious ar ear my clas	eleaningthe happened aga nd got a head ass had to be	fumes ain lache.	No odor detected at the time of assessment.	None		
GENERAL CLEANLINESS									
Air supply/return registers are cleaned regularly and dust and debris accumulation?	d free of					No dust observed on supply/return registers at the time of assessment.	None		
LOCAL EXHAUST FANS									
Other exhaust fans that may exist in the classroom a functioning properly?	are					Exhaust fan is functioning properly.	None		
THERMAL COMFORT									
Room is free of the introduction of outdoor air? (Ga window/door frames.)	aps in					No gaps in windows or doors identified at the time of assessment.	None		

FISH/	Room	Participant Comments	Response	Recommendation	Responsible	Priority
156	Temp 73.4	RH% 52.0 CO2 675	Occupants: 19			
	ANIMALS IN THE CLASSROOM Activities and/or room conditions are modified to address student allergies?		This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	GENERAL CLEANLINESS					
	Floor is cleaned on a regular basis?		Floor was clean at the time of assessment.	None		
	Room is free of pests?		No pests observed at the time of assessment.	None		
157	Temp 73.8	RH% 52.7 CO2 802	Occupants: 21			
	AIR CONDITIONING					
	Air flowing from air supply?		Air flowing without obstruction at the time of assessments.	None		
	Air is flowing without obstruction?		Air flowing without obstruction at the time of assessments.	None		
	GENERAL CLEANLINESS					
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?		No issues identified relating to spill clean up practices at the time of assessment	None		
	THERMAL COMFORT					
	Classroom is free of significant temperature shifts?		Temperature was acceptable at the time of assessment.	None		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		Humidity was acceptable at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)		Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?		Temperature was acceptable at the time of assessment.	None		
158	Temp 73.1	RH% 46.8 CO2 671	Occupants:			
	AIR CONDITIONING					
	Room is free of smell of vehicle exhaust?	gas smell comes in	No odor detected at the time of assessment.	None		

-

FISH/Room		Participant Comments	Response	Recommendation	Responsible	Priority
159	Temp	73.8 RH% 62.5 CO2 6	Occupants: 2			
AIR CONDITIONING Room is free of smell of vehicle exhaust?			No odor detected at the time of assessment.	None		
GENERAL CLEANLINESS Room is free of pests?			No pests observed at the time of assessment.	None		
208	Temp	67.2 RH% 56.2 CO2 1	080 Occupants: 23			
GENERAL CLEANLINESS						
Room is free of pests?			No pests observed at the time of assessment.	None		
THERMAL COMFORT						
Room is usually comfortable? (If no, please notes below.)	e explain in the	VERY cold!!!	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
Temperature in my classroom is generally co 76F)?	omfortable (72F-	VERY cold!!!	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
211	Temp	68.8 RH% 55.5 CO2 1	088 Occupants:			
EXCESS MOISTURE IN CLASSROO	MS					
Ceiling tiles or walls free of leaks and/or dise (discoloration may indicate periodic leaks)?	scoloration		Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operatio	ns 1
212	Temp	69.3 RH% 58.1 CO2 9	Occupants: 26			
GENERAL CLEANLINESS						
Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None		
THERMAL COMFORT						

FISH/I	Room	Participant Comments	Response	Recommendation	Responsible	Priority
212	Тетр	69.3 RH% 58.1 CO2 990	Occupants: 26			
	Classroom is free of significant temperature shifts?	It is alwaYs cold	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Room is usually comfortable? (If no, please explain in the notes below.)	It is alwaYs cold	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Temperature in my classroom is generally comfortable (72F-76F)?	It is alwaYs cold	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Walkthrough					
			Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
213	Тетр	71.2 RH% 56.8 CO2 1169	Occupants: 48			
	THERMAL COMFORT					
	Room is usually comfortable? (If no, please explain in the notes below.)	Room is usually very cold.	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Temperature in my classroom is generally comfortable (72F-76F)?	Room is usually very cold.	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2

FISH/	Room		Par	ticipant	Comment	S	Response	Recommendation	Responsible	Priority
214	Temp	70.6	RH%	57.3	CO2	975	Occupants:			
	DRAIN TRAPS IN THE CLASSROOM Water run in sinks at least once per week (about 2 cups of water).						It appears as though water is poured down the floor drain at least once a week.	None		
	GENERAL CLEANLINESS									
	Classroom is dusted/vacuumed thoroughly and regularly?						There does not appear to be a dusting issue within this room.	None		
215	Temp	70.7	RH%	56.1	CO2	983	Occupants:			
	GENERAL CLEANLINESS									
	Classroom is dusted/vacuumed thoroughly and regularly?						Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	THERMAL COMFORT									
	Classroom is free of significant temperature shifts?						Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
218	Temp	72.1	RH%	56.8	CO2	1033	Occupants: 11			
	ANIMALS IN THE CLASSROOM									
	Activities and/or room conditions are modified to address student allergies?						This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	GENERAL CLEANLINESS									
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?						No dust observed on supply/return registers at the time of assessment.	None		
	Classroom is dusted/vacuumed thoroughly and regularly?						There does not appear to be a dusting issue within this room.	None		
	Room is free of pests?						No pests observed at the time of assessment.	None		
	Trash is removed daily and trash bags are changed as appropriate?						No issues identified regarding trash removal practices.	None		
	Wall-through									

Walkthrough

FISH/F	Room	Participant Comments	Response	Recommendation	Responsible	Priority
218	Temp 72.1	RH% 56.8 CO2 1033	Occupants: 11 Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
221	Temp 72.2	RH% 58.1 CO2 904	Occupants: 20			
	DRAIN TRAPS IN THE CLASSROOM					
	Water poured down floor drains once per week (approx. 1 quart of water).		It appears as though water is poured down the floor drain at least once a week.	None		
	GENERAL CLEANLINESS					
	Classroom is dusted/vacuumed thoroughly and regularly?		Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?		Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Room is free of pests?		No pests observed at the time of assessment.	None		
	THERMAL COMFORT					
	Classroom is free of significant temperature shifts?	Mostly, my room temperature varies from warm to very hot. It sometimes is cool to cold when the students are not present.	Temperature was acceptable at the time of assessment.	None		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Mostly, my room temperature varies from warm to very hot. It sometimes is cool to cold when the students are not present.	Humidity was acceptable at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)	Mostly, my room temperature varies from warm to very hot. It sometimes is cool to cold when the students are not present.	Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?	Mostly, my room temperature varies from warm to very hot. It sometimes is cool to cold when the students are not present.	Temperature was acceptable at the time of assessment.	None		
	Walkthrough					
			Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	2
228	Temp 72.1	RH% 56.5 CO2 1017	Occupants:			
	GENERAL CLEANLINESS					
	Classroom is dusted/vacuumed thoroughly and regularly?		There does not appear to be a dusting issue within this room.	None		

FISH/	Room		Par	ticipant	Comment	s	Response	Recommendation	Responsible	Priority
228	Temp	72.1	RH%	56.5	CO2	1017	Occupants:]		
	THERMAL COMFORT									
	Room is usually comfortable? (If no, please explain in the notes below.)		sometimes	cold			Temperature was acceptable at the time assessment.	of None		
	Temperature in my classroom is generally comfortable (72F-76F)?		sometimes	cold			Temperature was acceptable at the time assessment.	of None		
230	Тетр	72.6	RH%	64.1	CO2	1148	Occupants:]		
	GENERAL CLEANLINESS									
	Classroom is dusted/vacuumed thoroughly and regularly?						Dust observed on supply/return registers the time of assessment.	s at Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
232	Temp	71.7	RH%	59.7	CO2	1108	Occupants: 28]		
	EXCESS MOISTURE IN CLASSROOMS									
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?						No leaks or signs of water intrusion identified.	None		
	GENERAL CLEANLINESS									
	Classroom is dusted/vacuumed thoroughly and regularly?						There does not appear to be a dusting iss within this room.	sue None		
	LOCAL EXHAUST FANS									
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)						It appears that classroom/functions are n consistent with educational specification for room use.		Site Based	2
233	Тетр	71.3	RH%	59.4	CO2	881	Occupants: 19]		
	GENERAL CLEANLINESS									
	Classroom is dusted/vacuumed thoroughly and regularly?		Dusting do	bes not appe	ar to be done		There does not appear to be a dusting iss within this room.	sue None		
	THERMAL COMFORT									
	Classroom is free of significant temperature shifts?			umid in Aug not months (/Sept. Fine s to come.	ince but	Temperature was acceptable at the time assessment.	of None		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)			umid in Aug not months (/Sept. Fine s to come.	ince but	Humidity was acceptable at the time of assessment.	None		

FISH/H	Room	Participant Comments	Response	Recommendation	Responsible	Priority
233	Temp 71	.3 RH% 59.4 CO2 881	Occupants: 19			
	Room is usually comfortable? (If no, please explain in the notes below.)	Hot and humid in Aug/Sept. Fine since but unsure of hot months to come.	Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?	Hot and humid in Aug/Sept. Fine since but unsure of hot months to come.	Temperature was acceptable at the time of assessment.	None		
234	Temp 72	.3 RH% 57.1 CO2 1260	Occupants: 27			
	ANIMALS IN THE CLASSROOM					
	Activities and/or room conditions are modified to address student allergies?		This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	GENERAL CLEANLINESS					
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Floor is swept everyday but not washed.	Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?	Floor is swept everyday but not washed.	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?	Floor is swept everyday but not washed.	Floor was clean at the time of assessment.	None		
	Room is free of pests?	Floor is swept everyday but not washed.	No pests observed at the time of assessment.	None		
	THERMAL COMFORT					
	Classroom is free of significant temperature shifts?		Temperature was acceptable at the time of assessment.	None		
235	Temp 72	.0 RH% 57.9 CO2 1004	Occupants: 1			
	GENERAL CLEANLINESS					
	Classroom is dusted/vacuumed thoroughly and regularly?	The sink and counter around the sink does not seem to be cleaned/wiped regularly.	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	THERMAL COMFORT					
	Classroom is free of significant temperature shifts?	At the beginning of the school or when the temperature is hotter outside the classroom temp is warm. During the cooler months the temp in the classroom is comfortable.	Temperature was acceptable at the time of assessment.	None		

FISH/F	Room	Participant Comments	Response	Recommendation	Responsible	Priority
236	Тетр	71.7 RH% 55.9 CO2 1205	Occupants: 17			
	ANIMALS IN THE CLASSROOM					
	Activities and/or room conditions are modified to address student allergies?		This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	EXCESS MOISTURE IN CLASSROOMS					
	Windows, windowsills and window frames free of continuous condensation?		Condensation on windows at the time of assessment. Temperature was not within acceptable range and no leaks were identified.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	5 1
	GENERAL CLEANLINESS					
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Floor is swept every day, but not washed.	Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?	Floor is swept every day, but not washed.	There does not appear to be a dusting issue within this room.	None		
	Floor is cleaned on a regular basis?	Floor is swept every day, but not washed.	Floor was clean at the time of assessment.	None		
	Room is free of pests?	Floor is swept every day, but not washed.	No pests observed at the time of assessment.	None		
	THERMAL COMFORT					
	Classroom is free of significant temperature shifts?		Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
237	Тетр	71.2 RH% 58.3 CO2 848	Occupants: 27			
	ANIMALS IN THE CLASSROOM					
	Activities and/or room conditions are modified to address student allergies?		This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	GENERAL CLEANLINESS					
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
237 Тетр	71.2 RH% 58.3 CO2 848	Occupants: 27			
Classroom is dusted/vacuumed thoroughly and regularly?		There does not appear to be a dusting issue within this room.	None		
Floor is cleaned on a regular basis?		Floor was clean at the time of assessment.	None		
Room is free of pests?		No pests observed at the time of assessment.	None		
THERMAL COMFORT					
Classroom is free of significant temperature shifts?	My room is hot all the time.	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
Temperature in my classroom is generally comfortable (72F-76F)?	- My room is hot all the time.	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
261 Тетр	72.1 RH% 50.0 CO2 582	Occupants:			
GENERAL CLEANLINESS					
Classroom is dusted/vacuumed thoroughly and regularly?		There does not appear to be a dusting issue within this room.	None		
Floor is cleaned on a regular basis?		Floor was clean at the time of assessment.	None		