

# Tools for Schools Phase IX - Indoor Air Quality

## Follow-up Action Plan for Site

Harbordale Elementary

0491

79.3 82.6 421

Walkthrough Date: 5/17/2012

Temp RH Co2  
Outside Measurements



Room	Priority	Concern	Response	Recommendation
505A	2	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust and debris on HVAC supply and/or return grills.	Clean HVAC supply and/or return grills with District approved germicidal cleaner
804	3	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
833	2	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust and debris on HVAC supply and/or return grills.	Clean HVAC supply and/or return grills with District approved germicidal cleaner
840	2	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust and debris on HVAC supply and/or return grills.	Clean HVAC supply and/or return grills with District approved germicidal cleaner