

Hawkes Bluff Elementary

IAQ Walkthrough 5/26/2005

Outside Temp RH% CO2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
108	Temp	<input type="text" value="76.9"/>	RH% <input type="text" value="52.6"/>	CO2 <input type="text" value="847"/>	Occupants: <input type="text"/>		
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	
	Room is free of pests?				No pests observed at the time of assessment.	None	None
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None	None
LOCAL EXHAUST FANS							
	Other exhaust fans that may exist in the classroom are functioning properly?				No exhaust fans in room. Identified in error.	None	None
	Bathroom exhaust fan is functioning properly?				No exhaust fans in room. Identified in error.	None	None
THERMAL COMFORT							
	Room is usually comfortable? (If no, please explain in the notes below.)		too cold		Temperature was elevated at the time of assessment.	None	None
	Classroom is free of significant temperature shifts?		too cold		Temperature was elevated at the time of assessment.	None	None
	Temperature in my classroom is generally comfortable (72F-76F)?		too cold		Temperature was elevated at the time of assessment.	None	None
Walkthrough							
					Signs of water intrusion.	Facilities serviceperson to replace stained ceiling tiles.	Site Based 2
					Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
132	Temp	<input type="text" value="70.9"/>	RH% <input type="text" value="43.5"/>	CO2 <input type="text" value="1968"/>	Occupants: <input type="text" value="24"/>		
AIR CONDITIONING							
	Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None	None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
132	Temp	70.9	RH% 43.5	CO2 1968	Occupants: 24		
	DRAIN TRAPS IN THE CLASSROOM						
	Water poured down floor drains once per week (approx. 1 quart of water).			No floor drain in room.	None	None	
	Water run in sinks at least once per week (about 2 cups of water).			No sink in room.	None	None	
	EXCESS MOISTURE IN CLASSROOMS						
	Windows, windowsills and window frames free of continuous condensation?			No condensation on windows at the time of assessment.	None	None	
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations	1
	Walkthrough						
				Signs of water intrusion. Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
137	Temp	71.8	RH% 42.3	CO2 1628	Occupants: 15		
	EXCESS MOISTURE IN CLASSROOMS						
	Windows, windowsills and window frames free of continuous condensation?			No condensation on windows at the time of assessment.	None	None	
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
138	Temp	71.6	RH% 57.1	CO2 1291	Occupants:		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?			Room has a musty or moldy smell. Air quality is uncomfortable often resulting in red, uncomfortable eyes by the end of the day.	No microbial growth identified. No odor identified at the time of assessment.	None	None
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?			Floor is washed but not thoroughly. The main area of the floor is swept and washed however no attention is given to the edges and corners; these areas of very dusty and dirty.	There does not appear to be a dusting issue within this room.	None	None
	THERMAL COMFORT						

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
138	Temp	71.6	RH%	57.1	CO2	1291	Occupants:				
	Room is usually comfortable? (If no, please explain in the notes below.)	Room temperature fluctuates from too warm in the morning and sometimes too cold in the afternoon. Room often feels humid., The room is either too warm or too cold.			Temperature was low at the time of assessment.	None	None				
	Classroom is free of significant temperature shifts?	Room temperature fluctuates from too warm in the morning and sometimes too cold in the afternoon. Room often feels humid., The room is either too warm or too cold.			Temperature was acceptable at the time of assessment.	None	None				
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Room temperature fluctuates from too warm in the morning and sometimes too cold in the afternoon. Room often feels humid., The room is either too warm or too cold.			Humidity was acceptable at the time of assessment.	None	None				
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	Room temperature fluctuates from too warm in the morning and sometimes too cold in the afternoon. Room often feels humid., The room is either too warm or too cold.			No gaps in windows or doors identified at the time of assessment.	None	None				
173N	Temp		RH%		CO2		Occupants:				
	Walkthrough				Odor detected at the time of assessment. Cause not found.	Physical Plant Operations to evaluate cause of odor.	Physical Plant Operations				2
202	Temp	70.4	RH%	64.9	CO2	940	Occupants:	32			
	GENERAL CLEANLINESS										
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based				2
	Room is free of pests?				No pests observed at the time of assessment.	None	None				
	Walkthrough				Repair deteriorating wall at window corners.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations				1
	Walkthrough				Dust and debris on ceiling tiles.	Facilities serviceperson to replace soiled ceiling tiles.	Site Based				2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
215	Temp	70.5	RH% 53.1	CO2 1250	Occupants: 18		
AIR CONDITIONING							
	Room is free of smell of kitchen/food?	My room is sued for a cooking class everyday after school.		No odor detected at the time of assessment.	None	None	
EXCESS MOISTURE IN CLASSROOMS							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Dust and debris on ceiling tiles.	Facilities serviceperson to replace soiled ceiling tiles.	Site Based	2
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None	None	
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None	None	
	Room is free of pests?			No pests observed at the time of assessment.	None	None	
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?	There is no bathroom in my room, so Idont know the answer to question C.		No bathroom. Identified in error.	None	None	
THERMAL COMFORT							
	Room is usually comfortable? (If no, please explain in the notes below.)	The room is either freezing and I have to open the windows to warm up, or if they alter ir, it gets super warm, and the room fills with condensation.		Environmental parameters were within acceptable range at the time of assessment..	None	None	
	Temperature in my classroom is generally comfortable (72F-76F)?	The room is either freezing and I have to open the windows to warm up, or if they alter ir, it gets super warm, and the room fills with condensation.		Temperature was acceptable at the time of assessment.	None	None	
	Classroom is free of significant temperature shifts?	The room is either freezing and I have to open the windows to warm up, or if they alter ir, it gets super warm, and the room fills with condensation.		Temperature was acceptable at the time of assessment.	None	None	
Walkthrough							
				Dust and debris on ceiling tiles.	Facilities serviceperson to replace soiled ceiling tiles.	Site Based	2
Wlakthrough							
				Repair wall at floor in kitchen area.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	1

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
249	Temp	70.4	RH%	38.8	CO2	1002	Occupants:	
AIR CONDITIONING								
	Room is free of smell of mold or mildew?	My room is a portable.		Odor detected and no microbial growth identified.	Physical Plant operations to evaluate cause of odor.	Physical Plant Operations		2
LOCAL EXHAUST FANS								
	Bathroom exhaust fan is functioning properly?	There is no bathroom in my portable.		No bathroom. Identified in error.	None	None		2
Walkthrough								
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based		1
301D	Temp	69.2	RH%	52.2	CO2	786	Occupants:	
EXCESS MOISTURE IN CLASSROOMS								
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations		1
GENERAL CLEANLINESS								
	Room is free of pests?			No pests observed at the time of assessment.	None	None		
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None	None		
301E	Temp	70.1	RH%	57.2	CO2	874	Occupants:	2
GENERAL CLEANLINESS								
	Floor is cleaned on a regular basis?			Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based		2
Walkthrough								
				Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations		1
301G	Temp	70.6	RH%	55.7	CO2	974	Occupants:	18
THERMAL COMFORT								
	Room is usually comfortable? (If no, please explain in the notes below.)	The room is too cold.		Environmental parameters were within acceptable range at the time of assessment..	None	None		
	Temperature in my classroom is generally comfortable (72F-76F)?	The room is too cold.		Temperature was acceptable at the time of assessment.	None	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
301G	Temp	70.6	RH% 55.7	CO2 974	Occupants:	18	
Walkthrough							
				Dust and debris on ceiling tiles.	Facilities serviceperson to replace soiled ceiling tiles.	Site Based	2
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	2
401	Temp	71.0	RH% 58.6	CO2 752	Occupants:		
AIR CONDITIONING							
Room is free of smell of mold or mildew?				No microbial growth identified. No odor identified at the time of assessment.	None	None	
EXCESS MOISTURE IN CLASSROOMS							
Classroom lavatories/water fountains free of leaks?			In the past, over the TV I have had a leak when it rains...	No leaks or signs of water intrusion identified.	None	None	
			My sink faucet will drip and run if it is not turned correctly by the students				
Windows, windowsills and window frames free of continuous condensation?			In the past, over the TV I have had a leak when it rains...	Condensation on windows at the time of assessment. Temperature was not within acceptable range and no leaks were identified.	None	None	
			My sink faucet will drip and run if it is not turned correctly by the students				
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			In the past, over the TV I have had a leak when it rains...	No leaks or signs of water intrusion identified.	None	None	
			My sink faucet will drip and run if it is not turned correctly by the students				
GENERAL CLEANLINESS							
Room is free of pests?			Many times the rooms are not cleaned well when a custodian is out. We rarely receive subs to replace absent custodians.	No pests observed at the time of assessment.	None	None	
Floor is cleaned on a regular basis?			Many times the rooms are not cleaned well when a custodian is out. We rarely receive subs to replace absent custodians.	Floor was clean at the time of assessment.	None	None	
Classroom is dusted/vacuumed thoroughly and regularly?			Many times the rooms are not cleaned well when a custodian is out. We rarely receive subs to replace absent custodians.	There does not appear to be a dusting issue within this room.	None	None	
LOCAL EXHAUST FANS							
Bathroom exhaust fan is functioning properly?				No bathroom. Identified in error.	None	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
401	Temp	71.0	RH% 58.6	CO2 752	Occupants:		
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?	I am freezing all the time		Temperature was acceptable at the time of assessment.	None	None	
	Room is usually comfortable? (If no, please explain in the notes below.)	I am freezing all the time		Environmental parameters were within acceptable range at the time of assessment..	None	None	
	Temperature in my classroom is generally comfortable (72F-76F)?	I am freezing all the time		Temperature was acceptable at the time of assessment.	None	None	
403	Temp	68.0	RH% 66.6	CO2 511	Occupants:		
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?	For question b, if students have allergies to dust, this allergy is not being addressed.			None	None	
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?	Classroom is not dusted, air vents are changed but not dusted in the meantime. Most trash bags are reused (only the large garbage bags are removed each day).		Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Trash is removed daily and trash bags are changed as appropriate?	Classroom is not dusted, air vents are changed but not dusted in the meantime. Most trash bags are reused (only the large garbage bags are removed each day).		No issues identified regarding trash removal practices.	None	None	
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Classroom is not dusted, air vents are changed but not dusted in the meantime. Most trash bags are reused (only the large garbage bags are removed each day).		Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?			No bathroom. Identified in error.	None	None	
Walkthrough							
				Dust and debris on ceiling tiles.	Facilities serviceperson to replace soiled ceiling tiles.	Site Based	2
404	Temp	72.0	RH% 45.8	CO2 722	Occupants:		
AIR CONDITIONING							
	Room is free of smell of mold or mildew?			No microbial growth identified. No odor identified at the time of assessment.	None	None	
EXCESS MOISTURE IN CLASSROOMS							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
404	Temp	72.0	RH% 45.8	CO2 722	Occupants:		
	Windows, windowsills and window frames free of continuous condensation?				No condensation on windows at the time of assessment.	None	None
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	None
406	Temp	71.8	RH% 72.4	CO2 590	Occupants:		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?				Odor detected and no microbial growth identified.	Physical Plant operations to evaluate cause of odor.	Physical Plant Operations 2
	ANIMALS IN THE CLASSROOM						
	You are informed about the potential allergies of your students?		We have had rats in our building.			None	None
	EXCESS MOISTURE IN CLASSROOMS						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks or signs of water intrusion identified.	None	None
	Indoor surfaces of exterior walls free of continuous condensation?				No visible condensation at the time of assessment. Signs of previous water intrusion as evidenced by stains on walls.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations 1
	Windows, windowsills and window frames free of continuous condensation?				No condensation on windows at the time of assessment.	None	None
	GENERAL CLEANLINESS						
	Floor is cleaned on a regular basis?		Very often we are without custodians and a substitute custodian are not hired. All that is done on those days is a trash out. This happens at least once a week.		Floor was clean at the time of assessment.	None	None
	Classroom is dusted/vacuumed thoroughly and regularly?		Very often we are without custodians and a substitute custodian are not hired. All that is done on those days is a trash out. This happens at least once a week.		There does not appear to be a dusting issue within this room.	None	None
	Room is free of pests?		Very often we are without custodians and a substitute custodian are not hired. All that is done on those days is a trash out. This happens at least once a week.		No pests observed at the time of assessment.	None	None
	LOCAL EXHAUST FANS						
	Other exhaust fans that may exist in the classroom are functioning properly?				No exhaust fans in room. Identified in error.	None	None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
406	Temp	71.8	RH%	72.4	CO2	590	Occupants:				
	Bathroom exhaust fan is functioning properly?			No bathroom. Identified in error.	None	None					
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)			It appears that the ventilation system is adequate based on room activities.	None	None					
THERMAL COMFORT											
	Temperature in my classroom is generally comfortable (72F-76F)?			temperature is too cold, when custodian shifts temperature it gets too warm. No middle ground.	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based				2
	Room is usually comfortable? (If no, please explain in the notes below.)			temperature is too cold, when custodian shifts temperature it gets too warm. No middle ground.	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate need for test and balance.	Physical Plant Operations				2
	Classroom is free of significant temperature shifts?			temperature is too cold, when custodian shifts temperature it gets too warm. No middle ground.	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based				2
Walkthrough											
					Humidity was slightly elevated at the time of assessment - 10% greater than outdoors.	Facilities serviceperson should monitor this room.	Site Based				3
407	Temp	69.8	RH%	45.9	CO2	662	Occupants:				
EXCESS MOISTURE IN CLASSROOMS											
	Classroom lavatories/water fountains free of leaks?				No lavatories/water fountains in room.	None	None				
GENERAL CLEANLINESS											
	Floor is cleaned on a regular basis?			I had termites in storage closet and big rat running through.	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based				2
	Classroom is dusted/vacuumed thoroughly and regularly?			I had termites in storage closet and big rat running through.	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based				2
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			I had termites in storage closet and big rat running through.	Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based				2
THERMAL COMFORT											

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
407	Temp	69.8	RH%	45.9	CO2	662	Occupants:				
	Room is usually comfortable? (If no, please explain in the notes below.)		Sometimes too cold, sometimes too hot	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate need for test and balance.	Physical Plant Operations	2				
	Temperature in my classroom is generally comfortable (72F-76F)?		Sometimes too cold, sometimes too hot	Temperature was acceptable at the time of assessment.	None	None					
	Classroom is free of significant temperature shifts?		Sometimes too cold, sometimes too hot	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2				
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		Sometimes too cold, sometimes too hot	Humidity was acceptable at the time of assessment.	None	None					
409	Temp	70.6	RH%	43.6	CO2	727	Occupants:				
	EXCESS MOISTURE IN CLASSROOMS										
	Area around and under classroom sinks free of leaks?			No leaks or signs of water intrusion identified.	None	None					
	Classroom lavatories/water fountains free of leaks?			No leaks or signs of water intrusion identified.	None	None					
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2				
	GENERAL CLEANLINESS										
	Room is free of pests?		f) Big rat in classroom.	No pests observed at the time of assessment.	None	None					
	Classroom is dusted/vacuumed thoroughly and regularly?		f) Big rat in classroom.	There does not appear to be a dusting issue within this room.	None	None					
	Walkthrough										
				Dust and debris on ceiling tiles.	Facilities serviceperson to replace soiled ceiling tiles.	Site Based	2				
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	2				
40N	Temp	75.3	RH%	39.4	CO2	2909	Occupants:	17			
	LOCAL EXHAUST FANS										
	Bathroom exhaust fan is functioning properly?		no bathroom in the classroom	No bathroom. Identified in error.	None	None					

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
40N	Temp	<input type="text" value="75.3"/>	RH% <input type="text" value="39.4"/>	CO2 <input type="text" value="2909"/>	Occupants: <input type="text" value="17"/>		
Walkthrough				Clean FINS for A/C units.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
410	Temp	<input type="text" value="68.3"/>	RH% <input type="text" value="49.6"/>	CO2 <input type="text" value="576"/>	Occupants: <input type="text"/>		
EXCESS MOISTURE IN CLASSROOMS							
Classroom lavatories/water fountains free of leaks?				No lavatories/water fountains in room.	None	None	
Area around and under classroom sinks free of leaks?				No leaks or signs of water intrusion identified.	None	None	
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	None	
Room is free of pests?				No pests observed at the time of assessment.	None	None	
412	Temp	<input type="text" value="67.5"/>	RH% <input type="text" value="48.4"/>	CO2 <input type="text" value="591"/>	Occupants: <input type="text"/>		
ANIMALS IN THE CLASSROOM					None	None	
Activities and/or room conditions are modified to address student allergies?							
THERMAL COMFORT							
Room is usually comfortable? (If no, please explain in the notes below.)			Usually the room is pretty cold!!	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate need for test and balance.	Physical Plant Operations	2
Temperature in my classroom is generally comfortable (72F-76F)?			Usually the room is pretty cold!!	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
460C	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
AIR CONDITIONING							
Room is free of smell of mold or mildew?			There is no visual mold or mildew...just a smell.	No odor detected at the time of assessment.	None	None	
GENERAL CLEANLINESS							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
460C	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
Room is free of pests?				No pests observed at the time of assessment.	None	None	
Walkthrough				Signs of water intrusion. Replace tackable wall surface next to A/C unit.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	1
501	Temp	<input type="text" value="71.1"/>	RH% <input type="text" value="51.1"/>	CO2 <input type="text" value="685"/>	Occupants: <input type="text"/>		
ART SUPPLIES							
Art supplies okay?				No art supplies in room. Room not being used as an art room.	None	None	
Science supplies okay?				No science supplies in room. Room not being used as a science room.	None	None	
502	Temp	<input type="text" value="70.2"/>	RH% <input type="text" value="53.0"/>	CO2 <input type="text" value="761"/>	Occupants: <input type="text"/>		
AIR CONDITIONING							
Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None	None	
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?					None	None	
THERMAL COMFORT							
Temperature in my classroom is generally comfortable (72F-76F)?				It is absolutely freezing at all times in my room. The air has been adjusted many times and it is still freezing.	Temperature was acceptable at the time of assessment.	None	None
Room is usually comfortable? (If no, please explain in the notes below.)				It is absolutely freezing at all times in my room. The air has been adjusted many times and it is still freezing.	Environmental parameters were within acceptable range at the time of assessment..	None	None
504	Temp	<input type="text" value="71.7"/>	RH% <input type="text" value="55.8"/>	CO2 <input type="text" value="1156"/>	Occupants: <input type="text" value="23"/>		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?					None	None	
EXCESS MOISTURE IN CLASSROOMS							
Indoor surfaces of exterior walls free of continuous condensation?				No visible condensation or signs of water intrusion identified at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
504	Temp	71.7	RH%	55.8	CO2	1156	Occupants:	23			
	Area around and under classroom sinks free of leaks?			No leaks or signs of water intrusion identified.	None	None					
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace soiled ceiling tiles.	Site Based					2
	Classroom lavatories/water fountains free of leaks?			No lavatories/water fountains in room.	None	None					
GENERAL CLEANLINESS											
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based					2
	Room is free of pests?			No pests observed at the time of assessment.	None	None					
Walkthrough											
				Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based					2
				Dust and debris on ceiling tiles.	Facilities serviceperson to replace soiled ceiling tiles.	Site Based					2
				Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based					2
505	Temp	72.4	RH%	49.6	CO2	1038	Occupants:	26			
AIR CONDITIONING											
	Room is free of smell of mold or mildew?			One corner of room - possible mold	Odor detected and no microbial growth identified.	Physical Plant operations to evaluate cause of odor.	Physical Plant Operations				2
Walkthrough											
					Unsealed food items were observed at the time of assessment. Unsealed food items may attract pests.	Site based administration should encourage all staff to maintain food items within sealable plastic storage containers.	Site Based				2
506	Temp	68.8	RH%	46.7	CO2	1392	Occupants:	25			
GENERAL CLEANLINESS											
	Classroom is dusted/vacuumed thoroughly and regularly?			The room is not dusted regularly. Sink area was not being cleaned daily so I now have a student do it at the end of the day.	There does not appear to be a dusting issue within this room.	None	None				
LOCAL EXHAUST FANS											

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
506	Temp	68.8	RH% 46.7	CO2 1392	Occupants: 25		
	Other exhaust fans that may exist in the classroom are functioning properly?	No fan in bathroom		No exhaust fans in room. Identified in error.	None	None	
	Bathroom exhaust fan is functioning properly?	No fan in bathroom		No exhaust fans in room. Identified in error.	None	None	
507	Temp	70.3	RH% 52.7	CO2 1365	Occupants: 22		
THERMAL COMFORT							
	Room is usually comfortable? (If no, please explain in the notes below.)	Too cold		Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate need for test and balance.	Physical Plant Operations	2
	Temperature in my classroom is generally comfortable (72F-76F)?	Too cold		Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
Walkthrough							
				Dust observed on supply register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	2
509	Temp	69	RH% 45.4	CO2 1541	Occupants:		
ART SUPPLIES							
	Science supplies okay?			No science supplies in room. Room not being used as a science room.	None	None	
	Art supplies okay?			No art supplies in room. Room not being used as an art room.	None	None	
EXCESS MOISTURE IN CLASSROOMS							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks or signs of water intrusion identified.	None	None	
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?			Bathroom exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
512	Temp	69.9	RH% 49.3	CO2 1226	Occupants: 21		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?		The floor is cleaned daily, however, there is often a lot of dust on the counters and computers.		Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
LOCAL EXHAUST FANS							
Bathroom exhaust fan is functioning properly?		The exhaust fan is very loud.		Bathroom exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
THERMAL COMFORT							
Classroom is free of significant temperature shifts?				Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
Walkthrough							
				Dust and debris on ceiling tiles.	Facilities serviceperson to replace soiled ceiling tiles.	Site Based	2
513	Temp	67.1	RH% 52.9	CO2 923	Occupants: 22		
LOCAL EXHAUST FANS							
Bathroom exhaust fan is functioning properly?				Bathroom exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
608	Temp	73.3	RH% 55.1	CO2 1125	Occupants:		
THERMAL COMFORT							
Room is usually comfortable? (If no, please explain in the notes below.)		My room is much colder than the other rooms in the building.		Temperature was acceptable at the time of assessment.	None	None	
Temperature in my classroom is generally comfortable (72F-76F)?		My room is much colder than the other rooms in the building.		Temperature was acceptable at the time of assessment.	None	None	
Walkthrough							
				Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
				Dust and debris on ceiling tiles.	Facilities serviceperson to replace soiled ceiling tiles.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
752	Temp	71.3	RH%	53.7	CO2	727	Occupants:				
EXCESS MOISTURE IN CLASSROOMS											
Windows, windowsills and window frames free of continuous condensation?					No condensation on windows at the time of assessment.	None	None				
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?					Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2			
GENERAL CLEANLINESS											
Room is free of pests?					No pests observed at the time of assessment.	None	None				
Classroom is dusted/vacuumed thoroughly and regularly?					Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2			
753	Temp	73.5	RH%	43.1	CO2	1012	Occupants:	18			
ANIMALS IN THE CLASSROOM											
Activities and/or room conditions are modified to address student allergies?						None	None				
EXCESS MOISTURE IN CLASSROOMS											
Windows, windowsills and window frames free of continuous condensation?					No condensation on windows at the time of assessment.	None	None				
GENERAL CLEANLINESS											
Room is free of pests?					No pests observed at the time of assessment.	None	None				
Classroom is dusted/vacuumed thoroughly and regularly?					Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2			
Walkthrough											
					Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2			
756	Temp	73	RH%	58.6	CO2	672	Occupants:				
GENERAL CLEANLINESS											
Room is free of pests?					Pests observed at the time of assessment.						

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
801	Temp	74.8	RH% 42.6	CO2 649	Occupants:		
AIR CONDITIONING							
	Air is flowing without obstruction?			Air flowing without obstruction at the time of assessments.	None	None	
	Windows/doors are operable and are kept closed?			Windows and doors are operable and are kept closed.	None	None	
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None		
	Air flowing from air supply?			Smoke testing confirmed that air supply/return ventilation is functioning qualitatively.	None	None	
ANIMALS IN THE CLASSROOM							
	You are informed about the potential allergies of your students?				None	None	
	Classroom is free of animals and pets?			No animals identified at the time of assessment.	None	None	
DRAIN TRAPS IN THE CLASSROOM							
	Water poured down floor drains once per week (approx. 1 quart of water).			No floor drain in room.	None	None	
EXCESS MOISTURE IN CLASSROOMS							
	Indoor surfaces of exterior walls free of continuous condensation?			No visible condensation or signs of water intrusion identified at the time of assessment.	None	None	
	Classroom lavatories/water fountains free of leaks?			No lavatories/water fountains in room.	None	None	
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations	1
	Windows, windowsills and window frames free of continuous condensation?			No condensation on windows at the time of assessment.	None	None	
	Cold water pipes free of continuous condensation?			Condensation on pipes at the time of assessment. Missing or damaged insulation identified.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	1
GENERAL CLEANLINESS							
	Room is free of pests?			No pests observed at the time of assessment.	None	None	
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classrooms general appearance is clean and acceptable?			General cleanliness of the room at the time of assessment was acceptable.	None	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

801

Temp RH% CO2

Occupants:

Classroom is dusted/vacuumed thoroughly and regularly?

Slight dust accumulation was observed on environmental surfaces at the time of assessment.

Site based administration should address general cleanliness with facility serviceperson staff.

Site Based

2

Floor is cleaned on a regular basis?

Dust and dirt accumulation on floor.

Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Site Based

2

Spills and other such issues requiring custodial assistance are addressed in a timely manner?

No issues identified relating to spill clean up practices at the time of assessment.

None

None

LOCAL EXHAUST FANS

Other exhaust fans that may exist in the classroom are functioning properly?

Exhaust fan is not functioning properly.

Physical Plant Operations to evaluate and repair as appropriate.

Physical Plant Operations

2

Bathroom exhaust fan is functioning properly?

Bathroom exhaust fan is not functioning properly.

Physical Plant Operations to evaluate and repair as appropriate.

Physical Plant Operations

2

LOCKER ROOM

Locker room and showers cleaned regularly and properly?

Issues not applicable. Room is not a locker room.

None

None

THERMAL COMFORT

Room is free of the introduction of outdoor air? (Gaps in window/door frames.)

No gaps in windows or doors identified at the time of assessment.

None

None

Classroom is free of significant temperature shifts?

Temperature was acceptable at the time of assessment.

None

None

901

Temp RH% CO2

Occupants:

GENERAL CLEANLINESS

Room is free of pests?

No pests observed at the time of assessment.

None

None