

**THE SCHOOL BOARD OF BROWARD COUNTY, FLORIDA**

**ENVIRONMENTAL HEALTH & SAFETY DEPARTMENT**

**TELEPHONE (754) 321-4200**

**FACSIMILE: (754) 321-4285**

January 26, 2018

Signature on File

TO: Delicia Joyce Decembert, Principal  
**Hollywood Central Elementary**

FROM: Alison Witoshynsky, Project Manager  
Environmental Health & Safety Department

SUBJECT: Indoor Air Quality (IAQ) Assessment

<u>For Custodial Supervisor Use Only</u>	
<input type="checkbox"/>	Custodial Issues Addressed
<input type="checkbox"/>	Custodial Issues Not Addressed
<hr/>	
<hr/>	

On January 15, 2018, I conducted an assessment at **Hollywood Central Elementary School**. Attached are findings and recommendations for further assessment, remediation, or corrective actions needed.

The IAQ assessment did identify one or more existing conditions impacting IAQ and has generated appropriate work orders to correct deficiencies in systems and maintenance that could contribute to decreased indoor air quality. At the time of the assessment, these concerns were not an immediate health or safety concern to building occupants. However, due to individual sensitivities and predisposing health factors, it is possible that some building occupants may elicit a health response to agents and / or conditions identified during the evaluation. Therefore, to further improve IAQ, prevent development of future IAQ-related problems, and to reduce the potential for IAQ-related complaints by building occupants, the IAQ Assessment Team recommends appropriate follow up of each item identified and listed in the attached evaluation.

*Please ensure that your Head Facilities Serviceperson receives a copy of this correspondence so that the recommendations requiring their attention can be addressed. In an attempt to separate IAQ issues from general maintenance items, the attached assessment may contain direction for site based staff to generate a work order through COMPASS. Within two weeks a representative from the Custodial/Grounds Department will conduct a follow-up visit to ensure that all site based custodial issues have been appropriately addressed.*

Should any questions arise, or if the current concerns continue after the attached recommendations have been addressed, please feel free to contact us at 754-321-4200.

AW:smn  
Enc.

- cc: Sam Bays, Director, Maintenance Operations
- Shelley Meloni, Director, Pre-Construction
- Mark Dorsett, Manager, Zone 1, Physical Plant Operations Division
- Greg Neiman, Area Supervisor, Zone 1
- Kurt Wirz, Area Manager Trades
- Gerald Devio, Supervisor II Custodial
- Benjamin Osborne, Supervisor II Custodial
- Mark Murray, Supervisor II Custodial
- Broward Teachers Union
- Federation of Public Employees

# IAQ Assessment

Hollywood Central Elementary

Evaluation Date January 15, 2018

Time of Day 11:40 AM

Outdoor Conditions    Temperature 84.5    Relative Humidity 59.6    Ambient CO2 433

Fish	Temperature	Range	Relative Humidity	Range	CO <sup>2</sup>	Range	# Occupants
<span style="border: 1px solid black; padding: 2px;">133</span>	<span style="border: 1px solid black; padding: 2px;">74.8</span>	<span style="border: 1px solid black; padding: 2px;">72 - 78</span>	<span style="border: 1px solid black; padding: 2px;">85.2</span>	<span style="border: 1px solid black; padding: 2px;">30% - 60%</span>	<span style="border: 1px solid black; padding: 2px;">767</span>	<b>MAX 700 &gt; Ambient</b>	<span style="border: 1px solid black; padding: 2px;">1</span>
Noticeable Odor		Visible water damage / staining?		Visible microbial growth?		Amount of material affected	
<span style="border: 1px solid black; padding: 2px;">No</span>		<span style="border: 1px solid black; padding: 2px;">No</span>		<span style="border: 1px solid black; padding: 2px;">No</span>		<span style="border: 1px solid black; padding: 2px;"></span>	
Ceiling	<span style="border: 1px solid black; padding: 2px;">2' X 4' Lay in</span>		<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;"></span>		
Walls	<span style="border: 1px solid black; padding: 2px;">Homasote / Tackboard</span>		<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;"></span>		
Floor	<span style="border: 1px solid black; padding: 2px;">12" x 12" Vinyl</span>		<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;">No</span>	<span style="border: 1px solid black; padding: 2px;"></span>		

Ceiling Clean	<span style="border: 1px solid black; padding: 2px;">Yes</span>	HVAC Supply Grills Clean	<span style="border: 1px solid black; padding: 2px;">Yes</span>	HVAC Return Grills Clean	<span style="border: 1px solid black; padding: 2px;">No</span>
Walls Clean	<span style="border: 1px solid black; padding: 2px;">Yes</span>	Inside of Supply Duct Clean	<span style="border: 1px solid black; padding: 2px;">Yes</span>	Inside of Return Duct Clean	<span style="border: 1px solid black; padding: 2px;">No</span>
Flooring Clean	<span style="border: 1px solid black; padding: 2px;">Yes</span>	Ceiling at Supply Grills Clean	<span style="border: 1px solid black; padding: 2px;">Yes</span>		
Room Surfaces Clean	<span style="border: 1px solid black; padding: 2px;">No</span>				

Trash Removed	<span style="border: 1px solid black; padding: 2px;">Yes</span>	Exhaust Fans Working	<span style="border: 1px solid black; padding: 2px;">Yes</span>	Unapproved Chemicals / Cleaners in Room	<span style="border: 1px solid black; padding: 2px;">No</span>
Signs of Pests	<span style="border: 1px solid black; padding: 2px;">No</span>	Drain Traps Wet	<span style="border: 1px solid black; padding: 2px;">Yes</span>	Air Fresheners in Room	<span style="border: 1px solid black; padding: 2px;">No</span>
Room Cluttered	<span style="border: 1px solid black; padding: 2px;">No</span>	Food if Stored in Room is in Sealed Containers	<span style="border: 1px solid black; padding: 2px;">N/A</span>		

Mechanical Equipment Location	<span style="border: 1px solid black; padding: 2px;">FISH 132</span>	Mechanical Room Clean	<span style="border: 1px solid black; padding: 2px;">Yes</span>
Filters Installed Properly	<span style="border: 1px solid black; padding: 2px;">Yes</span>	Filters Clean	<span style="border: 1px solid black; padding: 2px;">Yes</span>
Condensate Pan Clean	<span style="border: 1px solid black; padding: 2px;">N/A</span>	Cooling Coil Clean	<span style="border: 1px solid black; padding: 2px;">N/A</span>
		Inside of HVAC Unit Clean	<span style="border: 1px solid black; padding: 2px;">N/A</span>

Fresh Air Intake Location	<span style="border: 1px solid black; padding: 2px;">Exterior corridor</span> ▼	Fresh Air Intake Free of Obstruction	<span style="border: 1px solid black; padding: 2px;">Yes</span>
Pollutant Sources Near Air Intake	<span style="border: 1px solid black; padding: 2px;">No</span> ▼		

**Observations**

Classroom. Occupant reports high humidity in room. Existing work orders, J839056 & J844412, for AC not cooling. Temp appears to be okay, but humidity was very high during assessment. HFSP reports that one of the EMS sensors/controls turns off on its own. EMS representative was onsite last week and reportedly working on the issue. Light dust layer in lower cubbies, counter top, and closet (133B) shelving.

**Corrective Actions to be Completed by Site Based Staff**

Thoroughly clean horizontal surfaces with Wexside	▼
including cubbies, counters, and both sides	▼
of shelves in closet (133B)	▼
	▼
	▼
	▼
	▼
	▼

**Corrective Actions to be Completed by PPO**

Evaluate/Repair HVAC dampers, sensors, controls	▼
(J839056 & J844412)	▼
Repair HVAC to Reduce Humidity Levels	▼
Clean HVAC return grills and drops	▼
Clean Restroom Exhaust grills and drops	▼
	▼
	▼
	▼