

Report: Site

HOLLYWOOD HILLS ELEMENTARY

Walkthrough Date: 03/23/2007 Temp RH CO2

Outdoor Parameters: 75.8 55.3 474

Room	Priority	Responsible	Answer	Recommendation
001	Inside Parameters:	Temp	RH	CO2
		73.7	41.7	861

2 Site Dust observed on supply register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Room	Priority	Responsible	Answer	Recommendation
101	Inside Parameters:	Temp	RH	CO2
		73.7	40.9	949

2 Site Dust observed on supply and return registers at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Room	Priority	Responsible	Answer	Recommendation
101A	Inside Parameters:	Temp	RH	CO2
		73.7	40.9	949

2 Site Dust observed on supply and return registers at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Room	Priority	Responsible	Answer	Recommendation
108	Inside Parameters:	Temp	RH	CO2
		69.3	43.8	890

2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

3 Site Science supplies in room. Curriculum supervisor meet with appropriate staff to address issues of concern and ensure that all supplies are approved for use and handled/stored in a manner consistent with District procedures.

Room	Priority	Responsible	Answer	Recommendation

109	Inside Parameters:	Temp	RH	CO2
		67.7	45.8	93

- 2 Site Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment. Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts
- 2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
111	Inside Parameters:	Temp	RH	CO2
		70.4	47.2	972

- 3 Site This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
- 3 Site This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
- 2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
113	Inside Parameters:	Temp	RH	CO2
		71.6	45.9	1053

- 2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.
- 2 Site Dust observed on supply and return registers at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Room	Priority	Responsible	Answer	Recommendation
114	Inside Parameters:	Temp	RH	CO2

		70.1	47.	947
--	--	------	-----	-----

2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
119	Inside Parameters:	Temp	RH	CO2
		73.2	47.5	995

2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.

Room	Priority	Responsible	Answer	Recommendation
129	Inside Parameters:	Temp	RH	CO2
		74.9	45.8	1229

2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.

2 Site Animals were identified at the time of assessment. Animal/pet dander is a major allergen source that could impact occupant allergies. Location to ensure that housing of animal or pet is in conjunction with approved curriculum. If not the animal must be removed.

Room	Priority	Responsible	Answer	Recommendation
209P	Inside Parameters:	Temp	RH	CO2
		72	38.5	980

2 Site Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment. Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts

Room	Priority	Responsible	Answer	Recommendation
210P	Inside Parameters:	Temp	RH	CO2
		72	38.5	980

Slight dust accumulation was observed on Site based administration should work with room occupant to encourage

- 2 Site environmental surfaces due to clutter at the time of assessment. occupant to reduce clutter to assist facility serviceperson with their dusting efforts
- 2 Site Dust observed on supply and return registers at the time of assessment. filters very dirty Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Room	Priority	Responsible	Answer	Recommendation
226C	Inside Parameters:	Temp	RH	CO2
		78.1	47.2	1132

- 2 Site Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment. Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts
- 2 Site Dust and dirt accumulation on floor. Facilities serviceperson to thoroughly clean and sanitize.
- 2 Site Temperature was elevated at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
301	Inside Parameters:	Temp	RH	CO2
		71.8	51.5	511

- 2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.

Room	Priority	Responsible	Answer	Recommendation
482C	Inside Parameters:	Temp	RH	CO2
		78.4	49	543

- 2 Site Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment. Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts

Room	Priority	Responsible	Answer	Recommendation
501	Inside Parameters:	Temp	RH	CO2
		72.7	44.6	744

Slight dust accumulation was observed on Site based administration should address general cleanliness with facility

2	Site	environmental surfaces at the time of assessment.	serviceperson staff.
2	Site	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
2	Site	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.

Room	Priority	Responsible	Answer	Recommendation
502	Inside Parameters:	Temp	RH	CO2
		74.4	55.1	827

2	Site	Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts
2	Site	Dust observed on supply register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Room	Priority	Responsible	Answer	Recommendation
503	Inside Parameters:	Temp	RH	CO2
		75.9	53.8	1118

2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
---	------	--	---

Room	Priority	Responsible	Answer	Recommendation
505	Inside Parameters:	Temp	RH	CO2
		75.7	47	1344

2	Site	Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts
2	Site	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
2	Site	Live plants in room. Plant soil is a source of microbial growth.	Site based administration to advise staff to remove live plants.

Room	Priority	Responsible	Answer	Recommendation
986P	Inside Parameters:	Temp	RH	CO2

	74.6	45.4	1146
2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
2	Site	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.