

Hollywood Park Elementary

IAQ Walkthrough 4/20/2005

1761

Outside Temp RH% CO2

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
101A	Temp <input type="text" value="72.6"/> RH% <input type="text" value="52.0"/> CO2 <input type="text" value="806"/>	Occupants: <input type="text"/>			
AIR CONDITIONING	Windows/doors are operable and are kept closed?	Windows and doors are operable and are kept closed.	None		
LOCAL EXHAUST FANS	Bathroom exhaust fan is functioning properly?	Bathroom exhaust fan is functioning properly.	None		
	Other exhaust fans that may exist in the classroom are functioning properly?	Exhaust fan is functioning properly.	None		
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.	None		
104	Temp <input type="text"/> RH% <input type="text"/> CO2 <input type="text"/>	Occupants: <input type="text"/>			
AIR CONDITIONING	Room is free of smell of chemicals?	No odor detected at the time of assessment.	None		
105	Temp <input type="text" value="71.0"/> RH% <input type="text" value="54.4"/> CO2 <input type="text" value="1218"/>	Occupants: <input type="text" value="16"/>			
LOCAL EXHAUST FANS	My classroom has sufficient exhaust systems based on the activities/functionality of the room?	Bathroom exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
107	Temp <input type="text" value="70.7"/> RH% <input type="text" value="54.5"/> CO2 <input type="text" value="1248"/>	Occupants: <input type="text"/>			
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
107	Temp	70.7	RH% 54.5	CO2 1248	Occupants:		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		
THERMAL COMFORT							
Classroom is free of significant temperature shifts?				Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	3
108	Temp	70.6	RH% 55.3	CO2 1243	Occupants:		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Signs of water intrusion.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
GENERAL CLEANLINESS							
Room is free of pests?			We have ants.	Unsealed food items were observed at the time of assessment. Pests identified.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	2
THERMAL COMFORT							
Classroom is free of significant temperature shifts?			Warm during the A.M. hours, cold in the afternoons. I would rather be cold than hot as I can put a sweater on.	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
Room is usually comfortable? (If no, please explain in the notes below.)			Warm during the A.M. hours, cold in the afternoons. I would rather be cold than hot as I can put a sweater on.	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority					
108	Temp	70.6	RH%	55.3	CO2	1243	Occupants:					
	Temperature in my classroom is generally comfortable (72F-76F)?			Warm during the A.M. hours, cold in the afternoons. I would rather be cold than hot as I can put a sweater on.			Temperature was low at the time of assessment.		Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.		Site Based	2
108C	Temp	75.0	RH%	48.0	CO2	889	Occupants:					
	AIR CONDITIONING Room is free of smell of mold or mildew?			Odor detected and microbial growth identified.			Physical Plant Operations to evaluate cause of microbial growth and repair and remediate as appropriate.		Physical Plant Operations		1	
	EXCESS MOISTURE IN CLASSROOMS Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Signs of water intrusion. Stained ceiling tiles.			Physical Plant Operations to evaluate for roof leaks and repair as appropriate.		Physical Plant Operations		1	
111	Temp		RH%		CO2		Occupants:					
	AIR CONDITIONING Room is free of smell of mold or mildew?			Odor detected and microbial growth identified.			Physical Plant Operations to evaluate cause of microbial growth and repair and remediate as appropriate.		Physical Plant Operations			
114	Temp	74.0	RH%	49.7	CO2	1301	Occupants:					
	GENERAL CLEANLINESS Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.			None					
	LOCAL EXHAUST FANS Bathroom exhaust fan is functioning properly?			Bathroom exhaust fan is functioning properly.			None					
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)			It appears that the ventilation system is adequate based on room activities.			None					
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?			It appears that the ventilation system is adequate based on room activities.			None					
	Other exhaust fans that may exist in the classroom are functioning properly?			Exhaust fan is functioning properly.			None					

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
115	Temp	<input type="text" value="71.9"/>	RH% <input type="text" value="51.0"/>	CO2 <input type="text" value="1297"/>	Occupants: <input type="text"/>			
ANIMALS IN THE CLASSROOM								
You are informed about the potential allergies of your students?					This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
EXCESS MOISTURE IN CLASSROOMS								
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?					Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Physical Plant Operations	2
LOCAL EXHAUST FANS								
Bathroom exhaust fan is functioning properly?					No bathroom. Identified in error.	None		
116	Temp	<input type="text" value="71.0"/>	RH% <input type="text" value="52.3"/>	CO2 <input type="text" value="1348"/>	Occupants: <input type="text"/>			
AIR CONDITIONING								
Room is free of smell of kitchen/food?					No odor detected at the time of assessment.	None		
Room is free of smell of mold or mildew?					No odor detected at the time of assessment.	None		
GENERAL CLEANLINESS								
Room is free of pests?					No pests observed at the time of assessment.	None		
119	Temp	<input type="text" value="72.7"/>	RH% <input type="text" value="54.8"/>	CO2 <input type="text" value="930"/>	Occupants: <input type="text"/>			
AIR CONDITIONING								
Room is free of smell of mold or mildew?					No odor detected at the time of assessment.	None		
ANIMALS IN THE CLASSROOM								
Activities and/or room conditions are modified to address student allergies?					This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
You are informed about the potential allergies of your students?					This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS								

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

119

Temp RH% CO2

Occupants:

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

Dust observed on supply/return registers at the time of assessment.

Site based administration should address general cleanliness with facility serviceperson staff.

Site Based

2

Classroom is dusted/vacuumed thoroughly and regularly?

Slight dust accumulation was observed on environmental surfaces at the time of assessment.

Site based administration should address general cleanliness with facility serviceperson staff.

Site Based

2

Floor is cleaned on a regular basis?

Floor was clean at the time of assessment.

None

Spills and other such issues requiring custodial assistance are addressed in a timely manner?

There appears to be a problem with spill clean up practices. To address all spills in a timely manner, all moisture effected materials must be dried within a 24-hour timeframe.

Site based administration should address general cleanliness with facility serviceperson staff.

Site Based

2

Trash is removed daily and trash bags are changed as appropriate?

No issues identified regarding trash removal practices.

None

THERMAL COMFORT

Room is usually comfortable? (If no, please explain in the notes below.)

It is cold in here! My hands are always freezing. I have to go outside to defrost myself.

Temperature was acceptable at the time of assessment.

None

Temperature in my classroom is generally comfortable (72F-76F)?

It is cold in here! My hands are always freezing. I have to go outside to defrost myself.

Temperature was acceptable at the time of assessment.

None

Walkthrough

Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.

Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.

Site Based

2

119A

Temp RH% CO2

Occupants:

EXCESS MOISTURE IN CLASSROOMS

Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?

No leaks or signs of water intrusion identified.

None

GENERAL CLEANLINESS

Classroom is dusted/vacuumed thoroughly and regularly?

I think that mold may be around the A/C vent in the front of the classroom. The ceiling around the vent is discolored. I have an allergy attack every day when I walk into the room. Sneezing!!!!!!

Dust observed on supply register at the time of assessment.

Site based administration should address general cleanliness with facility serviceperson staff.

Site Based

2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
119A	Temp	68.0	RH%	57.9	CO2	913	Occupants:	
Classrooms general appearance is clean and acceptable?	I think that mold may be around the A/C vent in the front of the classroom. The ceiling around the vent is discolored. I have an allergy attack every day when I walk into the room. Sneezing!!!!!!			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2	
Floor is cleaned on a regular basis?	I think that mold may be around the A/C vent in the front of the classroom. The ceiling around the vent is discolored. I have an allergy attack every day when I walk into the room. Sneezing!!!!!!			Floor was clean at the time of assessment.	None			
THERMAL COMFORT								
Classroom is free of significant temperature shifts?	When it is cold outside, it is hot in my classroom. When it is hot outside, my classroom is freezing.			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2	
Room is usually comfortable? (If no, please explain in the notes below.)	When it is cold outside, it is hot in my classroom. When it is hot outside, my classroom is freezing.			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2	
Temperature in my classroom is generally comfortable (72F-76F)?	When it is cold outside, it is hot in my classroom. When it is hot outside, my classroom is freezing.			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2	
Walkthrough								
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	2	

119B

Temp 68.5 **RH%** 60.1 **CO2** 997 **Occupants:**

AIR CONDITIONING

Room is free of smell of kitchen/food?

Lounge Area

No issues

ANIMALS IN THE CLASSROOM

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
119B	Temp	68.5	RH% 60.1	CO2 997	Occupants: <input type="text"/>		
	Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	GENERAL CLEANLINESS						
	Trash is removed daily and trash bags are changed as appropriate?				No issues identified regarding trash removal practices.	None	
	Walkthrough						
					Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
119E	Temp	74.3	RH% 50.6	CO2 1034	Occupants: <input type="text"/>		
	ANIMALS IN THE CLASSROOM						
	You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Physical Plant Operations 3
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None	
	THERMAL COMFORT						
	Room is usually comfortable? (If no, please explain in the notes below.)		As the day progresses, the colder it gets		Temperature was acceptable at the time of assessment.	None	
	Temperature in my classroom is generally comfortable (72F-76F)?		As the day progresses, the colder it gets		Temperature was acceptable at the time of assessment.	None	
119F	Temp	72.0	RH% 53.0	CO2 970	Occupants: <input type="text"/>		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None	
	ANIMALS IN THE CLASSROOM						

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
119F	Temp	<input type="text" value="72.0"/>	RH%	<input type="text" value="53.0"/>	CO2	<input type="text" value="970"/>	Occupants:	<input type="text"/>			
	Activities and/or room conditions are modified to address student allergies?						This is a general issue requiring approved communication among all stakeholders.		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?						This is a general issue requiring approved communication among all stakeholders.		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS											
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?						No dust observed on supply/return registers at the time of assessment.		None		
	Classroom is dusted/vacuumed thoroughly and regularly?						There does not appear to be a dusting issue within this room.		None		
	Floor is cleaned on a regular basis?						Floor was clean at the time of assessment.		None		
	Trash is removed daily and trash bags are changed as appropriate?						No issues identified regarding trash removal practices.		None		
THERMAL COMFORT											
	Room is usually comfortable? (If no, please explain in the notes below.)		It is cold in here. My hands are always freezing. I have to go outside to defrost myself.				Temperature was acceptable at the time of assessment.		None		
	Temperature in my classroom is generally comfortable (72F-76F)?		It is cold in here. My hands are always freezing. I have to go outside to defrost myself.				Temperature was acceptable at the time of assessment.		None		
134A	Temp	<input type="text" value="69.6"/>	RH%	<input type="text" value="59.0"/>	CO2	<input type="text" value="964"/>	Occupants:	<input type="text"/>			
GENERAL CLEANLINESS											
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?						Dust observed on supply/return registers at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
134C	Temp	<input type="text" value="72.0"/>	RH%	<input type="text" value="56.0"/>	CO2	<input type="text" value="999"/>	Occupants:	<input type="text"/>			
GENERAL CLEANLINESS											
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?						No dust observed on supply/return registers at the time of assessment.		None		
	Classroom is dusted/vacuumed thoroughly and regularly?						Slight dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
134C	Temp	<input type="text" value="72.0"/>	RH% <input type="text" value="56.0"/>	CO2 <input type="text" value="999"/>	Occupants: <input type="text"/>			
134D	Temp	<input type="text" value="72.2"/>	RH% <input type="text" value="56.1"/>	CO2 <input type="text" value="980"/>	Occupants: <input type="text"/>			
GENERAL CLEANLINESS								
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		
	Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was acceptable.	None		
134E	Temp	<input type="text" value="73.4"/>	RH% <input type="text" value="53.2"/>	CO2 <input type="text" value="983"/>	Occupants: <input type="text"/>			
EXCESS MOISTURE IN CLASSROOMS								
	Cold water pipes free of continuous condensation?				No pipes in room.	None		
	Indoor surfaces of exterior walls free of continuous condensation?				No issues identified at the time of assessment.	None		
	Windows, windowsills and window frames free of continuous condensation?				No windows in room.	None		
134F	Temp	<input type="text" value="72.8"/>	RH% <input type="text" value="55.4"/>	CO2 <input type="text" value="985"/>	Occupants: <input type="text"/>			
AIR CONDITIONING								
	Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None		
ANIMALS IN THE CLASSROOM								
	Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
EXCESS MOISTURE IN CLASSROOMS								
	Indoor surfaces of exterior walls free of continuous condensation?				No condensation at the time of assessment.	None		
GENERAL CLEANLINESS								
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None		
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		
	Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was acceptable.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
134F	Temp	<input type="text" value="72.8"/>	RH%	<input type="text" value="55.4"/>	CO2	<input type="text" value="985"/>	Occupants:	<input type="text"/>
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None		
	Trash is removed daily and trash bags are changed as appropriate?				No issues identified regarding trash removal practices.	None		
	LOCAL EXHAUST FANS							
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)				It appears that the ventilation system is adequate based on room activities.	None		
135	Temp	<input type="text" value="72.8"/>	RH%	<input type="text" value="56.0"/>	CO2	<input type="text" value="1160"/>	Occupants:	<input type="text"/>
	AIR CONDITIONING							
	Air flowing from air supply?				Air flowing without obstruction at the time of assessments.	None		
	Air is flowing without obstruction?				Air flowing without obstruction at the time of assessments.	None		
	Room is free of smell of chemicals?				No odor detected at the time of assessment.	None		
	Room is free of smell of kitchen/food?				No odor detected at the time of assessment.	None		
	Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None		
	Room is free of smell of vehicle exhaust?				No odor detected at the time of assessment.	None		
	Windows/doors are operable and are kept closed?				Windows and doors are operable and are kept closed.	None		
	ART SUPPLIES							
	Exposure minimized for art supplies?				No issues identified at the time of assessment.	None		
	EXCESS MOISTURE IN CLASSROOMS							
	Area around and under classroom sinks free of leaks?				No leaks or signs of water intrusion identified.	None		
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks or signs of water intrusion identified.	None		
	GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
					Room is rarely swept, no dusting of countertops and shelves, stins on floor are not cleaned off, air vents are black with dust, weare forced to dust and sweep because the custodian only empties the trash and vacuums the rugs and we cant stand to be in a f			

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
135	Temp	72.8	RH% 56.0	CO2 1160	Occupants:		
	Classroom is dusted/vacuumed thoroughly and regularly?	Room is rarely swept, no dusting of countertops and shelves, stins on floor are not cleaned off, air vents are black with dust, weare forced to dust and sweep because the custodian only empties the trash and vacuums the rugs and we cant stand to be in a f			There does not appear to be a dusting issue within this room.	None	
	Classrooms general appearance is clean and acceptable?	Room is rarely swept, no dusting of countertops and shelves, stins on floor are not cleaned off, air vents are black with dust, weare forced to dust and sweep because the custodian only empties the trash and vacuums the rugs and we cant stand to be in a f			General cleanliness of the room at the time of assessment was acceptable.	None	
	Floor is cleaned on a regular basis?	Room is rarely swept, no dusting of countertops and shelves, stins on floor are not cleaned off, air vents are black with dust, weare forced to dust and sweep because the custodian only empties the trash and vacuums the rugs and we cant stand to be in a f			Floor was clean at the time of assessment.	None	
	Trash is removed daily and trash bags are changed as appropriate?	Room is rarely swept, no dusting of countertops and shelves, stins on floor are not cleaned off, air vents are black with dust, weare forced to dust and sweep because the custodian only empties the trash and vacuums the rugs and we cant stand to be in a f			No issues identified regarding trash removal practices.	None	
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?				No bathroom. Identified in error.	None	
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)				It appears that the ventilation system is adequate based on room activities.	None	
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?				It appears that the ventilation system is adequate based on room activities.	None	
	Other exhaust fans that may exist in the classroom are functioning properly?				Exhaust fan is functioning properly.	None	
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?	Mornings very cold, then becomes warm and then gets cold again., very cold			Temperature was acceptable at the time of assessment.	None	
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Mornings very cold, then becomes warm and then gets cold again., very cold			Humidity was acceptable at the time of assessment.	None	
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	Mornings very cold, then becomes warm and then gets cold again., very cold			Temperature was acceptable at the time of assessment.	None	
	Room is usually comfortable? (If no, please explain in the notes below.)	Mornings very cold, then becomes warm and then gets cold again., very cold			Temperature was acceptable at the time of assessment.	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
<i>135</i>	Temp	72.8	RH% 56.0	CO2 1160	Occupants: <input type="text"/>		
	Temperature in my classroom is generally comfortable (72F-76F)?		Mornings very cold, then becomes warm and then gets cold again., very cold	Temperature was acceptable at the time of assessment.		None	
<i>135B</i>	Temp	72.0	RH% 56.5	CO2 1047	Occupants: <input type="text"/>		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.		None	
	ANIMALS IN THE CLASSROOM						
	Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Physical Plant Operations	3
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.		None	
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.		None	
	Classrooms general appearance is clean and acceptable?			General cleanliness of the room at the time of assessment was acceptable.		None	
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.		None	
	Room is free of pests?			No pests observed at the time of assessment.		None	
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?			Temperature was acceptable at the time of assessment.		None	
	Temperature in my classroom is generally comfortable (72F-76F)?			Temperature was acceptable at the time of assessment.		None	
	Walkthrough						
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
140	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
AIR CONDITIONING							
Room is free of smell of mold or mildew?				Odor detected and no microbial growth identified.	Physical Plant Operations to evaluate cause of microbial growth and repair and remediate as appropriate.	Physical Plant Operations	1
142	Temp	<input type="text" value="76.1"/>	RH% <input type="text" value="49.6"/>	CO2 <input type="text" value="1153"/>	Occupants: <input type="text"/>		
AIR CONDITIONING							
Room is free of smell of mold or mildew?		Room and storeroom develop moldy signs and smells especially over the summer, and times when AC is not on for a period of time.		No odor detected at the time of assessment.	None		
ANIMALS IN THE CLASSROOM							
You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Physical Plant Operations	3
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		
Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None		
THERMAL COMFORT							
Room is usually comfortable? (If no, please explain in the notes below.)		It is usually on the cold side of comfortable, but I would rather have it that way.		Temperature was acceptable at the time of assessment.	None		
143	Temp	<input type="text" value="72.6"/>	RH% <input type="text" value="50.0"/>	CO2 <input type="text" value="1144"/>	Occupants: <input type="text"/>		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
143	Temp	72.6	RH% 50.0	CO2 1144	Occupants: <input type="text"/>		
	Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Physical Plant Operations 2
	LOCAL EXHAUST FANS						
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)				It appears that the ventilation system is adequate based on room activities.	None	
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?				It appears that the ventilation system is adequate based on room activities.	None	
	THERMAL COMFORT						
	Room is usually comfortable? (If no, please explain in the notes below.)	Too cold.			Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based 2
	Temperature in my classroom is generally comfortable (72F-76F)?	Too cold.			Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based 2
144	Temp	73.0	RH% 56.0	CO2 1237	Occupants: <input type="text"/>		
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?	My room temperature is very very cold. It is uncomfortable for the teacher and the students.			Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based 2
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	My room temperature is very very cold. It is uncomfortable for the teacher and the students.			Humidity was acceptable at the time of assessment.	None	
	Room is usually comfortable? (If no, please explain in the notes below.)	My room temperature is very very cold. It is uncomfortable for the teacher and the students.			Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based 2
	Temperature in my classroom is generally comfortable (72F-76F)?	My room temperature is very very cold. It is uncomfortable for the teacher and the students.			Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based 2
144A	Temp	72.6	RH% 54.7	CO2 1128	Occupants: <input type="text"/>		
	THERMAL COMFORT						
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	The room is extremely cold. Very uncomfortable to work in.			Humidity was slightly elevated at the time of assessment - 10% greater than outdoors.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations 2
	Room is usually comfortable? (If no, please explain in the notes below.)	The room is extremely cold. Very uncomfortable to work in.			Temperature was acceptable at the time of assessment.	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
144A	Temp	72.6	RH% 54.7	CO2 1128	Occupants:		
	Temperature in my classroom is generally comfortable (72F-76F)?		The room is extremely cold. Very uncomfortable to work in.		Temperature was acceptable at the time of assessment.	None	
145	Temp	72.3	RH% 54.7	CO2 998	Occupants:		
	AIR CONDITIONING						
	Room is free of smell of kitchen/food?				No odor detected at the time of assessment.	None	
	GENERAL CLEANLINESS						
	Room is free of pests?				No pests observed at the time of assessment.	None	
	LOCAL EXHAUST FANS						
	Bathroom exhaust fan is functioning properly?				Bathroom exhaust fan is functioning properly.	None	
	Other exhaust fans that may exist in the classroom are functioning properly?				Exhaust fan is functioning properly.	None	
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?		In the warmer months, (most of the school year) the mornings are extremely hot and stuffy in the rooms. We have a small fan we use just in the first couple of hours to keep the air circulating and a little cooler so we can breathe without sweating.)		Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based 2
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		In the warmer months, (most of the school year) the mornings are extremely hot and stuffy in the rooms. We have a small fan we use just in the first couple of hours to keep the air circulating and a little cooler so we can breathe without sweating.)		Humidity was acceptable at the time of assessment.	None	
	Room is usually comfortable? (If no, please explain in the notes below.)		In the warmer months, (most of the school year) the mornings are extremely hot and stuffy in the rooms. We have a small fan we use just in the first couple of hours to keep the air circulating and a little cooler so we can breathe without sweating.)		Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
201	Temp	71.2	RH% 66.6	CO2 711	Occupants:		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
EXCESS MOISTURE IN CLASSROOMS							
Windows, windowsills and window frames free of continuous condensation?				No condensation on windows at the time of assessment.	None		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		
Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was acceptable.	None		
Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor. Floor needs wax.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Trash is removed daily and trash bags are changed as appropriate?				No issues identified regarding trash removal practices.	None		
LOCAL EXHAUST FANS							
Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)				It appears that the ventilation system is adequate based on room activities.	None		
THERMAL COMFORT							
Classroom is free of significant temperature shifts?			very cold	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
Room is usually comfortable? (If no, please explain in the notes below.)			very cold	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
201	Temp	<input type="text" value="71.2"/>	RH% <input type="text" value="66.6"/>	CO2 <input type="text" value="711"/>	Occupants: <input type="text"/>		
	Temperature in my classroom is generally comfortable (72F-76F)?		very cold	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
202	Temp	<input type="text" value="72.3"/>	RH% <input type="text" value="61.7"/>	CO2 <input type="text" value="922"/>	Occupants: <input type="text"/>		
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Physical Plant Operations	2
	Room is free of pests?			No pests observed at the time of assessment.	None		
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?		Room has been very cold in the past.	Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based	2
	Room is usually comfortable? (If no, please explain in the notes below.)		Room has been very cold in the past.	Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based	2
	Temperature in my classroom is generally comfortable (72F-76F)?		Room has been very cold in the past.	Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based	2
203	Temp	<input type="text" value="72.0"/>	RH% <input type="text" value="65.0"/>	CO2 <input type="text" value="717"/>	Occupants: <input type="text"/>		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?			Odor detected at the time of assessment. Stuffed animals cluttered in room.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	Site Based	2
	ANIMALS IN THE CLASSROOM						
	Activities and/or room conditions are modified to address student allergies?			Unsealed food items were observed at the time of assessment. Unsealed food items may attract pests.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
203	Temp	72.0	RH% 65.0	CO2 717	Occupants: <input type="text"/>		
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
ART SUPPLIES							
	Art supplies okay?			No art supplies in room. Room not being used as an art room.	None		
	Industrial supplies okay?			No industrial supplies in room. Room not being used as an industrial room.	None		
	Science supplies okay?			No science supplies in room. Room not being used as a science room.	None		
DRAIN TRAPS IN THE CLASSROOM							
	Water run in sinks at least once per week (about 2 cups of water).			Water is not poured down floor drain at least once a week.	None		
EXCESS MOISTURE IN CLASSROOMS							
	Area around and under classroom sinks free of leaks?			No leaks or signs of water intrusion identified.	None		
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks or signs of water intrusion identified.	None		
	Classroom lavatories/water fountains free of leaks?			No lavatories/water fountains in room.	None		
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.	None		
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classrooms general appearance is clean and acceptable?			General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None		
	Food, if any, is stored in tightly sealed containers?			Unsealed food items were observed at the time of assessment. Unsealed food items may attract pests.	Site based administration should encourage all staff to maintain food items within sealable plastic storage containers.	Site Based	2
	Room is free of pests?			No pests observed at the time of assessment.	None		
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?			No issues identified relating to spill clean up practices at the time of assessment..	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
203	Temp	72.0	RH% 65.0	CO2 717	Occupants:		
	Trash is removed daily and trash bags are changed as appropriate?				No issues identified regarding trash removal practices.	None	
	LOCAL EXHAUST FANS						
	Bathroom exhaust fan is functioning properly?				Bathroom exhaust fan is functioning properly.	None	
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?				It appears that the ventilation system is adequate based on room activities.	None	
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?		IT IS TOO COLD OR TOO HOT		Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Physical Plant Operations 2
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		IT IS TOO COLD OR TOO HOT		Humidity was acceptable at the time of assessment.	None	
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)		IT IS TOO COLD OR TOO HOT		No gaps in windows or doors identified at the time of assessment.	None	
	Room is usually comfortable? (If no, please explain in the notes below.)		IT IS TOO COLD OR TOO HOT		Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based 2
	Temperature in my classroom is generally comfortable (72F-76F)?		IT IS TOO COLD OR TOO HOT		Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based 2
203A	Temp	72.9	RH% 66.2	CO2 797	Occupants:		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None	
	ANIMALS IN THE CLASSROOM						
	Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	DRAIN TRAPS IN THE CLASSROOM						

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
203A	Temp	72.9	RH% 66.2	CO2 797	Occupants:		
	If not regularly used, toilets flushed once each week.				It appears as though toilet is utilized regularly. No sewer gas odor detected. By flushing toilet regularly it eliminates the potential for sewer gas odors.	None	
	Water run in sinks at least once per week (about 2 cups of water).				It appears as though water is poured down the floor drain at least once a week.	None	
EXCESS MOISTURE IN CLASSROOMS							
	Area around and under classroom sinks free of leaks?				No leaks or signs of water intrusion identified.	None	
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations 1
	Classroom lavatories/water fountains free of leaks?				No lavatories/water fountains in room.	None	
	Cold water pipes free of continuous condensation?				No condensation on pipes at the time of assessment.	None	
	Indoor surfaces of exterior walls free of continuous condensation?				No condensation at the time of assessment.	None	
	Windows, windowsills and window frames free of continuous condensation?				No condensation on windows at the time of assessment.	None	
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None	
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was acceptable.	None	
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None	
	Food, if any, is stored in tightly sealed containers?				No unsealed food items were observed at the time of assessment.	None	
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?				No issues identified relating to spill clean up practices at the time of assessment..	None	
	Trash is removed daily and trash bags are changed as appropriate?				No issues identified regarding trash removal practices.	None	
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?				Bathroom exhaust fan is functioning properly.	None	
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?				It appears that the ventilation system is adequate based on room activities.	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
203A	Temp	<input type="text" value="72.9"/>	RH% <input type="text" value="66.2"/>	CO2 <input type="text" value="797"/>	Occupants: <input type="text"/>		
	Other exhaust fans that may exist in the classroom are functioning properly?			Exhaust fan is functioning properly.	None		
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?			TOO HOT OR TOO COLD	Temperature was acceptable at the time of assessment.	None	
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)			TOO HOT OR TOO COLD	Humidity was acceptable at the time of assessment.	None	
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)			TOO HOT OR TOO COLD	Temperature was acceptable at the time of assessment.	None	
	Room is usually comfortable? (If no, please explain in the notes below.)			TOO HOT OR TOO COLD	Temperature was acceptable at the time of assessment.	None	
	Temperature in my classroom is generally comfortable (72F-76F)?			TOO HOT OR TOO COLD	Temperature was acceptable at the time of assessment.	None	
204	Temp	<input type="text" value="72.0"/>	RH% <input type="text" value="56.1"/>	CO2 <input type="text" value="952"/>	Occupants: <input type="text"/>		
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None		
	Room is free of pests?			Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	1
205	Temp	<input type="text" value="71.8"/>	RH% <input type="text" value="66.7"/>	CO2 <input type="text" value="878"/>	Occupants: <input type="text"/>		
AIR CONDITIONING							
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None		
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Physical Plant Operations	3

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
205	Temp	71.8	RH% 66.7	CO2 878	Occupants: <input type="text"/>		
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Physical Plant Operations	3
EXCESS MOISTURE IN CLASSROOMS							
	Area around and under classroom sinks free of leaks?			No leaks or signs of water intrusion identified.	None		
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks or signs of water intrusion identified.	None		
	Classroom lavatories/water fountains free of leaks?			No lavatories/water fountains in room.	None		
	Cold water pipes free of continuous condensation?			No condensation on pipes at the time of assessment.	None		
	Indoor surfaces of exterior walls free of continuous condensation?			No issues identified at the time of assessment.	None		
	Windows, windowsills and window frames free of continuous condensation?			No condensation on windows at the time of assessment.	None		
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.	None		
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classrooms general appearance is clean and acceptable?			General cleanliness of the room at the time of assessment was acceptable.	None		
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None		
	Food, if any, is stored in tightly sealed containers?			No unsealed food items were observed at the time of assessment.	None		
	Room is free of pests?			No pests observed at the time of assessment.	None		
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?			No issues identified relating to spill clean up practices at the time of assessment..	None		
	Trash is removed daily and trash bags are changed as appropriate?			No issues identified regarding trash removal practices.	None		
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?			Bathroom exhaust fan is functioning properly.	None		
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)			It appears that the ventilation system is adequate based on room activities.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
205	Temp	<input type="text" value="71.8"/>	RH% <input type="text" value="66.7"/>	CO2 <input type="text" value="878"/>	Occupants: <input type="text"/>		
	Other exhaust fans that may exist in the classroom are functioning properly?			Exhaust fan is functioning properly.	None		
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?	it is too cold or too hot		Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	it is too cold or too hot		Humidity was acceptable at the time of assessment.	None		
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	it is too cold or too hot		Gaps in windows or doors identified at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
	Room is usually comfortable? (If no, please explain in the notes below.)	it is too cold or too hot		Temperature was low at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based	2
	Temperature in my classroom is generally comfortable (72F-76F)?	it is too cold or too hot		Temperature was low at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based	2
	Walkthrough						
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	2
205A	Temp	<input type="text" value="72.4"/>	RH% <input type="text" value="64.4"/>	CO2 <input type="text" value="967"/>	Occupants: <input type="text"/>		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?						
205B	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?						
210	Temp	<input type="text" value="73.6"/>	RH% <input type="text" value="60.4"/>	CO2 <input type="text" value="869"/>	Occupants: <input type="text"/>		
	AIR CONDITIONING						
	Air flowing from air supply?			Air flowing without obstruction at the time of assessments.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
210	Temp	73.6	RH% 60.4	CO2 869	Occupants: <input type="text"/>		
	Room is free of smell of mold or mildew?				Odor detected and microbial growth identified. Stained ceiling tiles.	Physical Plant Operations to evaluate cause of microbial growth and repair and remediate as appropriate.	Physical Plant Operations 1
	ANIMALS IN THE CLASSROOM						
	Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?				Temperature was acceptable at the time of assessment.	None	
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)				No gaps in windows or doors identified at the time of assessment.	None	
212	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None	
213	Temp	73.2	RH% 63.6	CO2 901	Occupants: <input type="text"/>		
	AIR CONDITIONING						
	Air is flowing without obstruction?				Air flowing without obstruction at the time of assessments.	None	
	Room is free of smell of mold or mildew?				Odor detected and microbial growth identified.	Physical Plant Operations to evaluate cause of microbial growth and repair and remediate as appropriate.	Physical Plant Operations 1
	ANIMALS IN THE CLASSROOM						
	Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	EXCESS MOISTURE IN CLASSROOMS						

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
213	Temp	73.2	RH% 63.6	CO2 901	Occupants: <input type="text"/>		
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Signs of water intrusion. Leak identified.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None		
	Classrooms general appearance is clean and acceptable?			General cleanliness of the room at the time of assessment was acceptable.	None		
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None		
	Room is free of pests?			No pests observed at the time of assessment.	None		
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?			No issues identified relating to spill clean up practices at the time of assessment..	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
213	Temp	73.2	RH% 63.6	CO2 901	Occupants:		
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?	My room is cold when it is cold outside and warm when it is warm outside.			Temperature was acceptable at the time of assessment.	None	
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	My room is cold when it is cold outside and warm when it is warm outside.			Humidity was acceptable at the time of assessment.	None	
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	My room is cold when it is cold outside and warm when it is warm outside.			Gaps in windows or doors identified at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations 2
	Room is usually comfortable? (If no, please explain in the notes below.)	My room is cold when it is cold outside and warm when it is warm outside.			Temperature was acceptable at the time of assessment.	None	
	Temperature in my classroom is generally comfortable (72F-76F)?	My room is cold when it is cold outside and warm when it is warm outside.			Temperature was acceptable at the time of assessment.	None	
Walkthrough							
					Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based 2
214	Temp	73.2	RH% 60.9	CO2 1013	Occupants:		
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Site Based 3
EXCESS MOISTURE IN CLASSROOMS							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Signs of water intrusion. Stained and broken ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations 1
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None	
	Room is free of pests?				No pests observed at the time of assessment.	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
214	Temp	73.2	RH% 60.9	CO2 1013	Occupants:			
THERMAL COMFORT								
Classroom is free of significant temperature shifts?					Temperature was acceptable at the time of assessment.	None		
Temperature in my classroom is generally comfortable (72F-76F)?					Temperature was acceptable at the time of assessment.	None		
217	Temp	74.0	RH% 64.1	CO2 1072	Occupants:			
GENERAL CLEANLINESS								
Classroom is dusted/vacuumed thoroughly and regularly?					Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Room is free of pests?					No pests observed at the time of assessment.	None		
Room is free of the use of scented cleaners and air fresheners?					No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.	None		
Trash is removed daily and trash bags are changed as appropriate?					No issues identified regarding trash removal practices.	None		
218	Temp	74.4	RH% 60.2	CO2 1185	Occupants:			
EXCESS MOISTURE IN CLASSROOMS								
Area around and under classroom sinks free of leaks?					No leaks or signs of water intrusion identified.	None		
Classroom lavatories/water fountains free of leaks?					No leaks or signs of water intrusion identified.	None		
GENERAL CLEANLINESS								
Classroom is dusted/vacuumed thoroughly and regularly?					Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Room is free of pests?					No pests observed at the time of assessment.	None		
THERMAL COMFORT								
Classroom is free of significant temperature shifts?					Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based	2
Temperature in my classroom is generally comfortable (72F-76F)?					Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
218	Temp	<input type="text" value="74.4"/>	RH% <input type="text" value="60.2"/>	CO2 <input type="text" value="1185"/>	Occupants: <input type="text"/>		
221	Temp	<input type="text" value="72.6"/>	RH% <input type="text" value="60.7"/>	CO2 <input type="text" value="1084"/>	Occupants: <input type="text"/>		
ANIMALS IN THE CLASSROOM							
Classroom is free of animals and pets?		c) animals are ants		No animals identified at the time of assessment.	None		
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None		
Room is free of pests?				No pests observed at the time of assessment.	None		
Spills and other such issues requiring custodial assistance are addressed in a timely manner?				No issues identified relating to spill clean up practices at the time of assessment..	None		
LOCAL EXHAUST FANS							
My classroom has sufficient exhaust systems based on the activities/functionality of the room?				It appears that the ventilation system is adequate based on room activities.	None		
222	Temp	<input type="text" value="71.4"/>	RH% <input type="text" value="51.0"/>	CO2 <input type="text" value="1191"/>	Occupants: <input type="text"/>		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		
THERMAL COMFORT							
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)				Humidity was acceptable at the time of assessment.	None		
223	Temp	<input type="text" value="69.7"/>	RH% <input type="text" value="54.7"/>	CO2 <input type="text" value="1122"/>	Occupants: <input type="text"/>		
THERMAL COMFORT							
Room is usually comfortable? (If no, please explain in the notes below.)				Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
223	<p>Temp <input type="text" value="69.7"/> RH% <input type="text" value="54.7"/> CO2 <input type="text" value="1122"/></p> <p>Temperature in my classroom is generally comfortable (72F-76F)?</p>	<p>Occupants: <input type="text"/></p> <p>Temperature was low at the time of assessment.</p>	<p>Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.</p>	Site Based	2
237	<p>Temp <input type="text"/> RH% <input type="text"/> CO2 <input type="text"/></p> <p>AIR CONDITIONING</p> <p>Room is free of smell of mold or mildew?</p> <p>EXCESS MOISTURE IN CLASSROOMS</p> <p>Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?</p> <p>Indoor surfaces of exterior walls free of continuous condensation?</p>	<p>Occupants: <input type="text"/></p> <p>No odor detected at the time of assessment.</p> <p>No leaks or signs of water intrusion identified.</p> <p>No condensation at the time of assessment.</p>	<p>None</p> <p>None</p> <p>None</p>		
240	<p>Temp <input type="text" value="69.7"/> RH% <input type="text" value="54.7"/> CO2 <input type="text" value="946"/></p> <p>GENERAL CLEANLINESS</p> <p>Air supply/return registers are cleaned regularly and free of dust and debris accumulation?</p> <p>Classroom is dusted/vacuumed thoroughly and regularly?</p> <p>Floor is cleaned on a regular basis?</p> <p>LOCAL EXHAUST FANS</p> <p>My classroom has sufficient exhaust systems based on the activities/functionality of the room?</p> <p>Walkthrough</p>	<p>Occupants: <input type="text"/></p> <p>No dust observed on supply/return registers at the time of assessment.</p> <p>There does not appear to be a dusting issue within this room.</p> <p>Floor was clean at the time of assessment.</p> <p>Exhaust fan is functioning properly.</p> <p>Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.</p>	<p>None</p> <p>None</p> <p>None</p> <p>None</p> <p>Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.</p>	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
241	Temp	68.8	RH% 53.4	CO2 1062	Occupants:		
AIR CONDITIONING							
	Room is free of smell of mold or mildew?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
EXCESS MOISTURE IN CLASSROOMS							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks or signs of water intrusion identified.	None		
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.	None		
	Room is free of pests?			No pests observed at the time of assessment.	None		
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?			Bathroom exhaust fan is functioning properly.	None		
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?		Too Cold!	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Room is usually comfortable? (If no, please explain in the notes below.)		Too Cold!	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
241	<p>Temp <input type="text" value="68.8"/> RH% <input type="text" value="53.4"/> CO2 <input type="text" value="1062"/></p> <p>Temperature in my classroom is generally comfortable (72F-76F)? Too Cold!</p> <p>Walkthrough</p>	<p>Occupants: <input type="text"/></p> <p>Temperature was low at the time of assessment.</p> <p>Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.</p>	<p>Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.</p> <p>Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.</p>	<p>Site Based</p> <p>Site Based</p>	<p>2</p> <p>2</p>
241A	<p>Temp <input type="text"/> RH% <input type="text"/> CO2 <input type="text"/></p> <p>AIR CONDITIONING</p> <p>Room is free of smell of mold or mildew?</p> <p>GENERAL CLEANLINESS</p> <p>Air supply/return registers are cleaned regularly and free of dust and debris accumulation?</p> <p>Classroom is dusted/vacuumed thoroughly and regularly?</p> <p>Classrooms general appearance is clean and acceptable?</p> <p>Floor is cleaned on a regular basis?</p>	<p>Occupants: <input type="text"/></p> <p>No odor detected at the time of assessment.</p> <p>No dust observed on supply/return registers at the time of assessment.</p> <p>There does not appear to be a dusting issue within this room.</p> <p>General cleanliness of the room at the time of assessment was acceptable.</p> <p>Floor was clean at the time of assessment.</p>	<p>None</p> <p>None</p> <p>None</p> <p>None</p> <p>None</p>		
241B	<p>Temp <input type="text" value="67.5"/> RH% <input type="text" value="53.5"/> CO2 <input type="text"/></p> <p>AIR CONDITIONING</p> <p>Room is free of smell of mold or mildew?</p>	<p>Occupants: <input type="text"/></p> <p>Odor detected and microbial growth identified.</p>	<p>Physical Plant Operations to evaluate cause of microbial growth and repair and remediate as appropriate.</p>	<p>Physical Plant Operations</p>	<p>1</p>
242	<p>Temp <input type="text" value="70.7"/> RH% <input type="text" value="62.2"/> CO2 <input type="text" value="996"/></p> <p>ANIMALS IN THE CLASSROOM</p> <p>Activities and/or room conditions are modified to address student allergies?</p>	<p>Occupants: <input type="text"/></p> <p>This is a general issue requiring approved communication among all stakeholders.</p>	<p>Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.</p>	<p>Site Based</p>	<p>3</p>

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

242

Temp RH% CO2 Occupants:

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

No dust observed on supply/return registers at the time of assessment. None

Classroom is dusted/vacuumed thoroughly and regularly?

There does not appear to be a dusting issue within this room. None

Floor is cleaned on a regular basis?

Floor was clean at the time of assessment. None

THERMAL COMFORT

Classroom is free of significant temperature shifts?

Temperature fluctuates throughout the day. Very humid first thing in the morning

Temperature was low at the time of assessment.

Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Site Based

2

Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)

Temperature fluctuates throughout the day. Very humid first thing in the morning

Humidity was slightly elevated at the time of assessment - 10% greater than outdoors.

Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.

Physical Plant Operations

2

Room is usually comfortable? (If no, please explain in the notes below.)

Temperature fluctuates throughout the day. Very humid first thing in the morning

Temperature was low at the time of assessment.

Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Site Based

2

Temperature in my classroom is generally comfortable (72F-76F)?

Temperature fluctuates throughout the day. Very humid first thing in the morning

Temperature was low at the time of assessment.

Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Site Based

2

242B

Temp RH% CO2 Occupants:

THERMAL COMFORT

Room is usually comfortable? (If no, please explain in the notes below.)

Temperature was low at the time of assessment.

Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Site Based

2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
242B	Temp	<input type="text" value="69.3"/>	RH% <input type="text" value="60.3"/>	CO2 <input type="text" value="962"/>	Occupants: <input type="text"/>		
	Temperature in my classroom is generally comfortable (72F-76F)?			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
243B	Temp	<input type="text" value="66.8"/>	RH% <input type="text" value="53.8"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
	EXCESS MOISTURE IN CLASSROOMS Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
244	Temp	<input type="text" value="70.7"/>	RH% <input type="text" value="59.6"/>	CO2 <input type="text" value="950"/>	Occupants: <input type="text"/>		
	EXCESS MOISTURE IN CLASSROOMS Classroom lavatories/water fountains free of leaks? Indoor surfaces of exterior walls free of continuous condensation?			No lavatories/water fountains in room. No condensation at the time of assessment.	None None		
	GENERAL CLEANLINESS Air supply/return registers are cleaned regularly and free of dust and debris accumulation? Classroom is dusted/vacuumed thoroughly and regularly? Room is free of pests? Room is free of the use of scented cleaners and air fresheners?			Dust observed on supply/return registers at the time of assessment. There does not appear to be a dusting issue within this room. No pests observed at the time of assessment. Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff. None None Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based Site Based	2 2
244A	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
	AIR CONDITIONING Room is free of smell of chemicals? Room is free of smell of mold or mildew?			No odor detected at the time of assessment. No odor detected at the time of assessment.	None None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
245	Temp	68.0	RH% 54.6	CO2 1017	Occupants:		
EXCESS MOISTURE IN CLASSROOMS							
	Cold water pipes free of continuous condensation?			Condensation on pipes at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
	Indoor surfaces of exterior walls free of continuous condensation?			No condensation at the time of assessment.	None		
	Windows, windowsills and window frames free of continuous condensation?			No condensation on windows at the time of assessment.	None		
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.	None		
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None		
	Classrooms general appearance is clean and acceptable?			General cleanliness of the room at the time of assessment was acceptable.	None		
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None		
	Room is free of pests?			Pests observed at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based	2
THERMAL COMFORT							
	Room is usually comfortable? (If no, please explain in the notes below.)		It is cold.	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Temperature in my classroom is generally comfortable (72F-76F)?		It is cold.	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
Walkthrough							
				Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
245B	Temp	<input type="text" value="68.2"/>	RH% <input type="text" value="53.3"/>	CO2 <input type="text" value="1013"/>	Occupants: <input type="text"/>		
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations		1
246	Temp	<input type="text" value="70.3"/>	RH% <input type="text" value="60.5"/>	CO2 <input type="text" value="920"/>	Occupants: <input type="text"/>		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?			Dust and debris on ceiling tiles.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based		2
THERMAL COMFORT							
Classroom is free of significant temperature shifts?			The room is too cold at times.	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
Room is usually comfortable? (If no, please explain in the notes below.)			The room is too cold at times.	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
Temperature in my classroom is generally comfortable (72F-76F)?			The room is too cold at times.	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
246B	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
Walkthrough							
			Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based		2

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
-----------	----------------------	----------	----------------	-------------	----------

<i>310B</i>	Temp <input type="text" value="69.7"/>	RH% <input type="text" value="64.0"/>	CO2 <input type="text" value="453"/>	Occupants: <input type="text"/>
-------------	--	---------------------------------------	--------------------------------------	---------------------------------

LOCAL EXHAUST FANS

My classroom has sufficient exhaust systems based on the activities/functionality of the room?