

# RISK MANAGEMENT...

managing risk with responsibility

Jeffrey S. Moquin, Director  
Risk Management Department

Telephone: 754-321-3200  
Facsimile: 754-321-3290

February 12, 2008

**Signature on File**

TO: Ms. Deborah Braly, Principal  
**Hunt Elementary School**

FROM: Edward See, Project Manager  
Risk Management Department

SUBJECT: Indoor Air Quality (IAQ) Assessment  
**FISH 858 and 859**

<u>For Custodial Supervisor Use Only</u>	
<input type="checkbox"/>	Custodial Issues Addressed
<input type="checkbox"/>	Custodial Issues Not Addressed
<hr/>	
<hr/>	

On February 8, 2008 I conducted an assessment of FISH 858 and 859 at **Hunt Elementary School**. This evaluation included observations of the flooring system, ceiling tiles, false ceiling plenum, environmental surfaces, interior and exterior walls, and the accessible ventilation equipment. Additionally, environmental parameter measurements were taken to include temperature, relative humidity, and carbon dioxide. The detailed findings, along with the recommended corrective action can be found on the attached IAQ Assessment Worksheets.

Generally, the IAQ Assessment did not identify any existing conditions significantly impacting IAQ and thereby presenting immediate health and safety concerns to building occupants. However, due to individual sensitivities and predisposing health factors, it is possible that some building occupants may elicit a health response to agents and / or conditions identified during the evaluation. Therefore, to further improve IAQ, prevent development of future IAQ-related problems, and to reduce the potential for IAQ-related complaints by building occupants, the IAQ Assessment Team recommends appropriate follow up of each item identified and listed in the attached evaluation.

*Please ensure that your Head Facilities Serviceperson receives a copy of this correspondence so that the recommendations requiring their attention can be addressed. Within two weeks a representative from the Custodial/Grounds Department will conduct a follow-up visit to ensure that all issues have been appropriately addressed.*

Should any questions arise, or if the current concerns continue after the attached recommendations have been addressed, please feel free to contact me at 754-321-3200.

cc: Dr. Joanne Harrison, Area Superintendent  
Jackie Haywood, Area Director  
Jeffrey S. Moquin, Director, Risk Management  
Gerry Devio, Project Manager, Facilities and Construction Management  
Gary Itzkowitz, Broward Teachers Union  
Roy Jarrett, National Federation of Public and Private Employees  
Mark Dorsett, Manager 1, Physical Plant Operations Division, Zone 1  
Roy Norton, Manager Custodial/Grounds, Physical Plant Operations Division  
Robert Krickovich, Coordinator, LEA, Facilities and Construction Management

ES/tc  
Enc.

# IAQ Assessment

Hunt Elementary School

Location Number   
 Evaluation Requested   
 Evaluation Date

Time of Day

Outdoor Conditions      Temperature       Relative Humidity       Ambient CO2

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
<input type="text" value="858"/>	<input type="text" value="72"/>	<input type="text" value="72 - 78"/>	<input type="text" value="72.2"/>	<input type="text" value="30% - 60%"/>	<input type="text" value="664"/>	<input type="text" value="Max 700 &gt; Ambient"/>	<input type="text" value="2"/>
Noticeable Odor		<input type="text" value="Yes"/>	Visible water damage / staining?		Visible microbial growth?		Amount of material affected
Ceiling Type	<input type="text" value="2 x 4 Lay In"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		
Wall Type	<input type="text" value="Drywall/Plaster"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		
Flooring	<input type="text" value="12 x 12 Vinyl"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Walls	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Flooring	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Return Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Ceiling at Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Surfaces in Room	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>

**Observations**

**Findings:**

- Humidity level was elevated
- Non-approved chemicals in room (air freshener)
- No signs of water intrusion or visible microbial growth

**Recommendations:**

**Site Based Maintenance:**

- Remove non-approved chemicals from room (air freshener)
- Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate

**Physical Plant Operations**

- Evaluate HVAC system for proper operation and repair as appropriate to lower humidity

# IAQ Assessment

Hunt Elementary School

Location Number   
 Evaluation Requested   
 Evaluation Date

Time of Day

Outdoor Conditions      Temperature       Relative Humidity       Ambient CO2

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
<input type="text" value="859"/>	<input type="text" value="71.1"/>	<input type="text" value="72 - 78"/>	<input type="text" value="45.9"/>	<input type="text" value="30% - 60%"/>	<input type="text" value="772"/>	<input type="text" value="Max 700 &gt; Ambient"/>	<input type="text" value="3"/>
Noticeable Odor		Visible water damage / staining?		Visible microbial growth?		Amount of material affected	
<input type="text" value="No"/>		<input type="text" value="Yes"/>		<input type="text" value="No"/>		<input type="text" value="1 ceiling tile"/>	
Ceiling Type	<input type="text" value="2 x 4 Lay In"/>		<input type="text" value="Yes"/>	<input type="text" value="No"/>		<input type="text" value="1 ceiling tile"/>	
Wall Type	<input type="text" value="Drywall/Plaster"/>		<input type="text" value="No"/>	<input type="text" value="No"/>		<input type="text" value="None"/>	
Flooring	<input type="text" value="12 x 12 Vinyl"/>		<input type="text" value="No"/>	<input type="text" value="No"/>		<input type="text" value="None"/>	

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	<input type="text" value="No"/>	<input type="text" value="Yes"/>	<input type="text" value="Yes"/>	<input type="text" value="Remove and replace ceiling tile"/>
Walls	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value=""/>
Flooring	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value=""/>
HVAC Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value=""/>
HVAC Return Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value=""/>
Ceiling at Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value=""/>
Surfaces in Room	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value=""/>

**Observations**

**Findings:**

- Minor musty odor in room
- No signs of water intrusion or visible microbial growth

**Recommendations:**

**Site Based Maintenance:**

- Remove and replace stained ceiling tile
- Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate