

**HUNT JAMES S ELEMENTARY**

Walkthrough Date: 03/30/2007 Temp RH CO2

Outdoor Parameters: 75.4 59.8 581

Room	Section	Question	Answer	Recommendation	Responsible
101	Inside Parameters:	Temp 72.6	RH 57.2	CO2 1039	
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
	GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
	ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks or signs of water intrusion identified.		

Room	Section	Question	Answer	Recommendation	Responsible
103	Inside Parameters:	Temp 74.0	RH 52.2	CO2 970	
	THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was acceptable at the time of assessment.		
	LOCAL EXHAUST FANS	Other exhaust fans that may exist in the classroom are functioning properly?	Exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.	PPO

Room	Section	Question	Answer	Recommendation	Responsible
108	Inside Parameters:	Temp 74.1	RH 55.6	CO2 9945	
	THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-	Temperature was acceptable at the time of assessment.		

76F)?  
 THERMAL COMFORT Room is usually comfortable? (If no, please explain in the notes below.) Environmental parameters were within acceptable range at the time of assessment..

Room	Section	Question	Answer	Recommendation	Responsible
113	Inside Parameters:	Temp 73.6	RH 56.4	CO2 916	

GENERAL CLEANLINESS Room is free of pests? No pests observed at the time of assessment.

GENERAL CLEANLINESS Room is free of the use of scented cleaners and air fresheners? Non-approved chemicals scented cleaners or air fresheners found at the time of assessment. Facilities serviceperson to remove all non-approved chemicals scented cleaners or air fresheners from the room. Site

THERMAL COMFORT Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.) Humidity was acceptable at the time of assessment.

THERMAL COMFORT Room is usually comfortable? (If no, please explain in the notes below.) Temperature was acceptable at the time of assessment.

AIR CONDITIONING Room is free of smell of mold or mildew? No microbial growth identified. No odor identified at the time of assessment.

LOCAL EXHAUST FANS Other exhaust fans that may exist in the classroom are functioning properly? No exhaust fans in room. Identified in error.

Room	Section	Question	Answer	Recommendation	Responsible
114	Inside Parameters:	Temp 72.8	RH 59.0	CO2 874	

GENERAL CLEANLINESS Air supply/return registers are cleaned regularly and free of dust and debris accumulation? Dust observed on supply register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. Site

GENERAL CLEANLINESS Room is free of pests? No pests observed at the time of assessment.

ANIMALS IN THE CLASSROOM Activities and/or room conditions are modified to address student allergies? This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in

order to modify classroom activities/conditions when necessary.

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

THERMAL COMFORT

Classroom is free of significant temperature shifts?

This is a general issue requiring approved communication among all stakeholders.

LOCAL EXHAUST FANS

Other exhaust fans that may exist in the classroom are functioning properly?

No exhaust fans in room. Identified in error.

Room	Section	Question	Answer	Recommendation	Responsible
115	Inside Parameters:	Temp 70.4	RH 60	CO2 892	

THERMAL COMFORT

Temperature in my classroom is generally comfortable (72F-76F)?

Temperature was low at the time of assessment.

Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Site

THERMAL COMFORT

Classroom is free of significant temperature shifts?

Temperature was low at the time of assessment.

THERMAL COMFORT

Room is usually comfortable? (If no, please explain in the notes below.)

Temperature was low at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
121	Inside Parameters:	Temp 70.9	RH 59.1	CO2 1006[	

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

Dust observed on supply register at the time of assessment.

Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Site

GENERAL CLEANLINESS

Room is free of pests?

No pests observed at the time of assessment.

ANIMALS IN THE CLASSROOM

You are informed about the potential allergies of your students?

This is a general issue requiring approved communication among all stakeholders.

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site

ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was low at the time of assessment.		
THERMAL COMFORT	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	Room is self contained with no access to outdoor untreated air.		
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.		
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Temperature was low at the time of assessment.		
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		
LOCAL EXHAUST FANS	My classroom has sufficient exhaust systems based on the activities/functionality of the room?	No exhaust system/ventilation in room. Identified in error.		
LOCAL EXHAUST FANS	Other exhaust fans that may exist in the classroom are functioning properly?	No exhaust fans in room. Identified in error.		

Room	Section	Question	Answer	Recommendation	Responsible
123	Inside Parameters:	Temp 71.3	RH 58.2	CO2 9904	

THERMAL Temperature in my classroom is Temperature was acceptable at the time

COMFORT	generally comfortable (72F-76F)?	of assessment.		
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.		
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Return vents closed at the time of assessment.	Facilities serviceperson to open return vents.	Site
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		

Room	Section	Question	Answer	Recommendation	Responsible
127	Inside Parameters:	Temp 72.7	RH 62.6	CO2 847	

GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room.		
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	PPO
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Temperature was acceptable at the time of assessment.		
AIR CONDITIONING	Room is free of smell of vehicle exhaust?	No odor detected at the time of assessment.		
AIR CONDITIONING	Room is free of smell of chemicals?	No odor detected at the time of assessment.		

AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.
LOCAL EXHAUST FANS	My classroom has sufficient exhaust systems based on the activities/functionality of the room?	No exhaust system/ventilation in room. Identified in error.
LOCAL EXHAUST FANS	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)	N/A - Copy Room
LOCAL EXHAUST FANS	Other exhaust fans that may exist in the classroom are functioning properly?	No exhaust fans in room. Identified in error.

Room	Section	Question	Answer	Recommendation	Responsible
129	Inside Parameters:	Temp 71.1	RH 67.3	CO2 885	
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
	GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
	ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	DRAIN TRAPS IN THE CLASSROOM	Water poured down floor drains once per week (approx. 1 quart of water).	No floor drain in room.		
	EXCESS MOISTURE IN CLASSROOMS	Windows, windowsills and window frames free of continuous condensation?	No windows in room.		
	EXCESS MOISTURE IN CLASSROOMS	Cold water pipes free of continuous condensation?	No condensation on pipes at the time of assessment.		
	EXCESS MOISTURE IN	Indoor surfaces of exterior walls free of continuous	No visible condensation or signs of water intrusion identified at the time of		

CLASSROOMS	condensation?	assessment.		
EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for PPO leaks and repair as appropriate and replace ceiling tiles as appropriate.	
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was slightly elevated at the time of assessment. Humidity slightly exceeded target range however indoor humidity was more than 10% lower than the outside reading which is evidence that the ventilation system is dehumidifying fresh air.	Site based facilities serviceperson should monitor this room.	Site
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..		
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		
LOCAL EXHAUST FANS	Other exhaust fans that may exist in the classroom are functioning properly?	No exhaust fans in room. Identified in error.		
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..		
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		

Room	Section	Question	Answer	Recommendation	Responsible
134	Inside Parameters:	Temp 70.2	RH 69.1	CO2 846	

GENERAL CLEANLINESS	Classrooms general appearance is clean and acceptable?	General cleanliness of the room at the time of assessment was acceptable.		
GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	Site
GENERAL CLEANLINESS	Trash is removed daily and trash bags are changed as appropriate?	No issues identified regarding trash removal practices.		
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
GENERAL CLEANLINESS	Room is free of the use of scented cleaners and air fresheners?	No scented cleaners air fresheners or non-approved chemicals found at the time of assessment.		
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was low at the time of assessment and humidity was elevated.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to increase temperature and lower humidity level.	PPO
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..		
AIR CONDITIONING	Room is free of smell of kitchen/food?	No odor detected at the time of assessment.		
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		
LOCAL EXHAUST FANS	Other exhaust fans that may exist in the classroom are functioning properly?	Exhaust fan is functioning properly.		

Room	Section	Question	Answer	Recommendation	Responsible
135	Inside Parameters:	Temp 71.1	RH 67.1	CO2 858	
	EXCESS MOISTURE IN	Ceiling tiles or walls free of leaks and/or discoloration	Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate and	PPO



CLASSROOMS	(discoloration may indicate periodic leaks)?		replace ceiling tiles as appropriate.
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.	
LOCAL EXHAUST FANS	Other exhaust fans that may exist in the classroom are functioning properly?	No exhaust fans in room.	

Room	Section	Question	Answer	Recommendation	Responsible
139	Inside Parameters:	Temp 72.4	RH 61.8	CO2 969	
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
	GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
	THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was acceptable at the time of assessment.		
	THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
	THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..		

Room	Section	Question	Answer	Recommendation	Responsible
142	Inside Parameters:	Temp 70.8	RH 60.9	CO2 951	
	EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for PPO leaks and repair as appropriate and replace ceiling tiles as appropriate.	
	THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does	Site

not improve.

THERMAL COMFORT Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.) Humidity was acceptable at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
144	Inside Parameters:	Temp 70.2	RH 64.9	CO2 946	

GENERAL CLEANLINESS Classrooms general appearance is clean and acceptable? General cleanliness of the room at the time of assessment was acceptable.

GENERAL CLEANLINESS Classroom is dusted/vacuumed thoroughly and regularly? Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment. Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts

GENERAL CLEANLINESS Spills and other such issues requiring custodial assistance are addressed in a timely manner? No issues identified relating to spill clean up practices at the time of assessment..

ANIMALS IN THE CLASSROOM Activities and/or room conditions are modified to address student allergies? This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. Site

EXCESS MOISTURE IN CLASSROOMS Windows, windowsills and window frames free of continuous condensation? No condensation on windows at the time of assessment.

THERMAL COMFORT Temperature in my classroom is generally comfortable (72F-76F)? Temperature was low at the time of assessment and humidity was elevated. Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to increase temperature and lower humidity level. PPO

THERMAL COMFORT Classroom is free of significant temperature shifts? Temperature was low at the time of assessment.

THERMAL COMFORT Room is free of the introduction of outdoor air? (Gaps in window/door frames.) No gaps in windows or doors identified at the time of assessment.

THERMAL COMFORT Humidity is generally acceptable? (Typically too high Humidity was slightly elevated at the time of assessment.

	if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..	
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.	
ART SUPPLIES	Art supplies okay?	Art supplies in room.	Curriculum supervisor meet with appropriate staff to address issues of concern and ensure that all supplies are approved for use and handled/stored in a manner consistent with District procedures. Site

Room	Section	Question	Answer	Recommendation	Responsible
158	Inside Parameters:	Temp 74.2	RH 66.4	CO2 747	
	GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
	AIR CONDITIONING	Room is free of smell of kitchen/food?	Room is adjacent to kitchen/cafeteria.		
	LOCAL EXHAUST FANS	Other exhaust fans that may exist in the classroom are functioning properly?	No exhaust fans.		

Room	Section	Question	Answer	Recommendation	Responsible
176	Inside Parameters:	Temp 74.6	RH 59.6	CO2 865	
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
	AIR CONDITIONING	Room is free of smell of kitchen/food?	Odor detected at the time of assessment. Room is adjacent to kitchen and/or home economics room.	Facilities serviceperson to evaluate cause of odor and inspect exhaust fans/fume hoods for proper operation.	Site
	LOCAL EXHAUST FANS	Bathroom exhaust fan is functioning properly?	Bathroom exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.	PPO

Room	Section	Question	Answer	Recommendation	Responsible
------	---------	----------	--------	----------------	-------------

502	Inside Parameters:	Temp 71.8	RH 56.6	CO2 918	
	THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
	LOCAL EXHAUST FANS	Other exhaust fans that may exist in the classroom are functioning properly?	No exhaust fans in room. Identified in error.		

Room	Section	Question	Answer	Recommendation	Responsible
503	Inside Parameters:	Temp 73.3	RH 55.9	CO2 812	
	GENERAL CLEANLINESS	Classrooms general appearance is clean and acceptable?	General cleanliness of the room at the time of assessment was acceptable.		
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address Site general cleanliness with facility serviceperson staff.	
	GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. Site	
	THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was acceptable at the time of assessment.		
	THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
	THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.		
	THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Temperature was acceptable at the time of assessment.		

Room	Section	Question	Answer	Recommendation	Responsible
504	Inside Parameters:	Temp 72.6	RH 54.4	CO2 936	
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address Site general cleanliness with facility serviceperson staff.	

GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
EXCESS MOISTURE IN CLASSROOMS	Indoor surfaces of exterior walls free of continuous condensation?	Condensation on walls or surfaces at the time of assessment. No leak identified.	Physical Plant Operations to evaluate and repair as appropriate.	PPO
EXCESS MOISTURE IN CLASSROOMS	Classroom lavatories/water fountains free of leaks?	No leaks or signs of water intrusion identified.		
EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks or signs of water intrusion identified.		
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.		
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..		

Room	Section	Question	Answer	Recommendation	Responsible
506	Inside Parameters:	Temp 72.8	RH 55.4	CO2 958	

GENERAL CLEANLINESS	Classrooms general appearance is clean and acceptable?	General cleanliness of the room at the time of assessment was acceptable.		
GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site

GENERAL CLEANLINESS	Trash is removed daily and trash bags are changed as appropriate?	No issues identified regarding trash removal practices.		
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.		
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
EXCESS MOISTURE IN CLASSROOMS	Windows, windowsills and window frames free of continuous condensation?	No condensation on windows at the time of assessment.		
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	No gaps in windows or doors identified at the time of assessment.		
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.		
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..		

Room	Section	Question	Answer	Recommendation	Responsible
508	Inside Parameters:	Temp 73.1	RH 56.5	CO2 945	
GENERAL		Classroom is dusted/vacuumed	Slight dust accumulation was observed	Site based administration should address	Site

CLEANLINESS	thoroughly and regularly?	on environmental surfaces at the time of assessment.	general cleanliness with facility serviceperson staff.
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. Site
GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.	
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.	
EXCESS MOISTURE IN CLASSROOMS	Windows, windowsills and window frames free of continuous condensation?	No condensation on windows at the time of assessment.	
EXCESS MOISTURE IN CLASSROOMS	Indoor surfaces of exterior walls free of continuous condensation?	No visible condensation at the time of assessment. Signs of previous water intrusion as evidenced by stains on walls.	Physical Plant Operations to evaluate and repair as appropriate. PPO
EXCESS MOISTURE IN CLASSROOMS	Area around and under classroom sinks free of leaks?	No leaks or signs of water intrusion identified.	
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was acceptable at the time of assessment.	
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.	
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.	
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..	

Room	Section	Question	Answer	Recommendation	Responsible
601	Inside Parameters:	Temp	RH	CO2	
		72.6	49.9	710	

THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was acceptable at the time of assessment.
-----------------	-----------------------------------------------------------------	-------------------------------------------------------

THERMAL COMFORT Room is usually comfortable? (If no, please explain in the notes below.) Temperature was acceptable at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
602	Inside Parameters:	Temp 73.1	RH 54.2	CO2 1013	
GENERAL CLEANLINESS		Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
GENERAL CLEANLINESS		Trash is removed daily and trash bags are changed as appropriate?	No issues identified regarding trash removal practices.		
GENERAL CLEANLINESS		Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
GENERAL CLEANLINESS		Room is free of pests?	No pests observed at the time of assessment.		
GENERAL CLEANLINESS		Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.		
ANIMALS IN THE CLASSROOM		Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
EXCESS MOISTURE IN CLASSROOMS		Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	Ceiling tiles broken, damaged or missing.	Facilities serviceperson to replace ceiling tiles.	Site
THERMAL COMFORT		Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT		Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT		Room is usually comfortable? (If no, please explain in the notes below.)	Temperature was acceptable at the time of assessment.		
LOCAL EXHAUST FANS		Bathroom exhaust fan is functioning properly?	Bathroom exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.	PPO



Room	Section	Question	Answer	Recommendation	Responsible
603	Inside Parameters:	Temp 72.2	RH 51.7	CO2 776	
	GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
	THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..		
	LOCAL EXHAUST FANS	Other exhaust fans that may exist in the classroom are functioning properly?	Bathroom exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.	PPO

Room	Section	Question	Answer	Recommendation	Responsible
604	Inside Parameters:	Temp 73.7	RH 55.9	CO2 1067	
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
	GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
	GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
	GENERAL CLEANLINESS	Room is free of the use of scented cleaners and air fresheners?	No scented cleaners air fresheners or non-approved chemicals found at the time of assessment.		
	ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	EXCESS MOISTURE IN CLASSROOMS	Windows, windowsills and window frames free of continuous condensation?	No condensation on windows at the time of assessment.		
	THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
	THERMAL COMFORT	Room is free of the introduction of outdoor air? (Gaps in	No gaps in windows or doors identified at the time of assessment.		

window/door frames.)

THERMAL COMFORT Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.) Humidity was acceptable at the time of assessment.

AIR CONDITIONING Room is free of smell of mold or mildew? No microbial growth identified. No odor identified at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
605	Inside Parameters:	Temp 71.5	RH 53.1	CO2 685	

GENERAL CLEANLINESS Room is free of pests? No pests observed at the time of assessment.

THERMAL COMFORT Temperature in my classroom is generally comfortable (72F-76F)? Temperature was acceptable at the time of assessment.

THERMAL COMFORT Room is usually comfortable? (If no, please explain in the notes below.) Temperature was acceptable at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
606	Inside Parameters:	Temp 74.0	RH 55.5	CO2 936	

GENERAL CLEANLINESS Room is free of pests? No pests observed at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
608	Inside Parameters:	Temp 73.6	RH 56.6	CO2 890	

GENERAL CLEANLINESS Room is free of pests? No pests observed at the time of assessment.

GENERAL CLEANLINESS Floor is cleaned on a regular basis? Floor was clean at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
701	Inside Parameters:	Temp 72.8	RH 49.8	CO2 1192	

GENERAL CLEANLINESS Room is free of pests? No pests observed at the time of assessment.

THERMAL COMFORT Temperature in my classroom is generally comfortable (72F-76F)? Temperature was acceptable at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
703	Inside Parameters:	Temp 74.1	RH 48.1	CO2 1188	

GENERAL CLEANLINESS Classroom is dusted/vacuumed thoroughly and regularly? Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.

GENERAL CLEANLINESS Air supply/return registers are cleaned regularly and free of dust and debris accumulation? Dust observed on supply register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. Site

THERMAL COMFORT Temperature in my classroom is generally comfortable (72F-76F)? Temperature was acceptable at the time of assessment.

THERMAL COMFORT Classroom is free of significant temperature shifts? Temperature was acceptable at the time of assessment.

THERMAL COMFORT Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.) Humidity was acceptable at the time of assessment.

THERMAL COMFORT Room is usually comfortable? (If no, please explain in the notes below.) Temperature was acceptable at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
704A	Inside Parameters:	Temp 74.3	RH 47.7	CO2 1184	

GENERAL CLEANLINESS Air supply/return registers are cleaned regularly and free of dust and debris accumulation? Dust observed on supply register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. Site

ANIMALS IN THE CLASSROOM You are informed about the potential allergies of your students? N/A - Storage Room

ANIMALS IN THE Activities and/or room N/A - Storage Room

CLASSROOM	conditions are modified to address student allergies?	
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.
LOCAL EXHAUST FANS	Other exhaust fans that may exist in the classroom are functioning properly?	Exhaust fan is functioning properly.

Room	Section	Question	Answer	Recommendation	Responsible
705	Inside Parameters:	Temp 74.4	RH 47.9	CO2 1232	
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
	GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
	GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
	EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks or signs of water intrusion identified.		
	THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was acceptable at the time of assessment.		
	THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
	THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Temperature was acceptable at the time of assessment.		

Room	Section	Question	Answer	Recommendation	Responsible
706	Inside Parameters:	Temp 75.1	RH 48.8	CO2 1296	
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
	GENERAL	Room is free of pests?	No pests observed at the time of		

CLEANLINESS assessment.  
 GENERAL CLEANLINESS Air supply/return registers are cleaned regularly and free of dust and debris accumulation? Dust observed on supply register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. Site  
 THERMAL COMFORT Temperature in my classroom is generally comfortable (72F-76F)? Temperature was acceptable at the time of assessment.  
 THERMAL COMFORT Room is usually comfortable? (If no, please explain in the notes below.) Environmental parameters were within acceptable range at the time of assessment..

Room	Section	Question	Answer	Recommendation	Responsible
707	Inside Parameters:	Temp 73.7	RH 48.7	CO2 1237	

GENERAL CLEANLINESS Air supply/return registers are cleaned regularly and free of dust and debris accumulation? Dust observed on supply register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. Site  
 GENERAL CLEANLINESS Floor is cleaned on a regular basis? Floor was clean at the time of assessment.  
 ANIMALS IN THE CLASSROOM Classroom is free of animals and pets? No animals identified at the time of assessment.  
 THERMAL COMFORT Temperature in my classroom is generally comfortable (72F-76F)? Temperature was acceptable at the time of assessment.  
 THERMAL COMFORT Classroom is free of significant temperature shifts? Temperature was acceptable at the time of assessment.  
 THERMAL COMFORT Room is free of the introduction of outdoor air? (Gaps in window/door frames.) No gaps in windows or doors identified at the time of assessment.  
 THERMAL COMFORT Room is usually comfortable? (If no, please explain in the notes below.) Environmental parameters were within acceptable range at the time of assessment..

Room	Section	Question	Answer	Recommendation	Responsible
852	Inside Parameters:	Temp 75.6	RH 62.2	CO2 746	

GENERAL CLEANLINESS Classroom is dusted/vacuumed thoroughly and regularly? Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff. Site

GENERAL CLEANLINESS Air supply/return registers are cleaned regularly and free of dust and debris accumulation? Dust observed on supply register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. Site

GENERAL CLEANLINESS Room is free of pests? No pests observed at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
855	Inside Parameters:	Temp 74.1	RH 58.3	CO2 752	

GENERAL CLEANLINESS Classroom is dusted/vacuumed thoroughly and regularly? Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff. Site

Room	Section	Question	Answer	Recommendation	Responsible
856	Inside Parameters:	Temp 74.6	RH 60.1	CO2 1030	

GENERAL CLEANLINESS Classroom is dusted/vacuumed thoroughly and regularly? Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff. Site

GENERAL CLEANLINESS Air supply/return registers are cleaned regularly and free of dust and debris accumulation? Dust observed on supply register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. Site

