

# Tools for Schools Phase II - Indoor Air Quality

## Follow-up Action Plan for Physical Plant Operations



Lakeside Elementary

82.7 67 757

Principal: Ms. Marion Fee

Walkthrough Date: 5/26/2005

Temp RH Co2  
**Outside Measurements**

Room	Priority	Responsible	Response	Recommendation
171	2	Physical Plant Operations	Temperature on one side of the room was as noted above and on the other end the reading was 76.3 temperature, 54.3 relative humidity and 1314 CO2.	Physical Plant Operations to evaluate HVAC system for proper operation.