

**LARKDALE ELEMENTARY**

Walkthrough Date: 05/02/2006 Temp RH CO2

Outdoor Parameters: 80 49 553

Room	Section	Question	Answer	Recommendation	Responsible
013	Inside Parameters:	Temp 72.1	RH 57.9	CO2 828	
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Boxes stored in corridor.	Remove boxes from corridor.	Site
	ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	EXCESS MOISTURE IN CLASSROOMS	Windows, windowsills and window frames free of continuous condensation?	No windows in room.		
	LOCAL EXHAUST FANS	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)	No exhaust system/ventilation in room. Identified in error.		
	LOCAL EXHAUST FANS	Bathroom exhaust fan is functioning properly?	No bathroom. Identified in error.		

Room	Section	Question	Answer	Recommendation	Responsible
1027K	Inside Parameters:	Temp 77.6	RH 44.8	CO2 999	
	DRAIN TRAPS IN THE CLASSROOM	Water poured down floor drains once per week (approx. 1 quart of water).	No floor drain in room.		

Room	Section	Question	Answer	Recommendation	Responsible
1028K	Inside Parameters:	Temp 75	RH 48.6	CO2 797	
	GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
	GENERAL	Floor is cleaned on a regular	Dust and dirt accumulation on	Facilities serviceperson to thoroughly clean	Site

CLEANLINESS basis? floor. and sanitize.

ANIMALS IN THE CLASSROOM Classroom is free of animals and pets? No animals identified at the time of assessment.

EXCESS MOISTURE IN CLASSROOMS Windows, windowsills and window frames free of continuous condensation? No condensation on windows at the time of assessment.

EXCESS MOISTURE IN CLASSROOMS Cold water pipes free of continuous condensation? No condensation on pipes at the time of assessment.

EXCESS MOISTURE IN CLASSROOMS Area around and under classroom sinks free of leaks? No leaks or signs of water intrusion identified.

THERMAL COMFORT Classroom is free of significant temperature shifts? Temperature was acceptable at the time of assessment.

THERMAL COMFORT Room is free of the introduction of outdoor air? (Gaps in window/door frames.) No gaps in windows or doors identified at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
113	Inside Parameters:	Temp 74.4	RH 54.9	CO2 847	

GENERAL CLEANLINESS Trash is removed daily and trash bags are changed as appropriate? No issues identified regarding trash removal practices.

DRAIN TRAPS IN THE CLASSROOM Water poured down floor drains once per week (approx. 1 quart of water). No floor drain in room.

EXCESS MOISTURE IN CLASSROOMS Windows, windowsills and window frames free of continuous condensation? No condensation on windows at the time of assessment.

THERMAL COMFORT Temperature in my classroom is generally comfortable (72F-78F)? Temperature was acceptable at the time of assessment.

THERMAL COMFORT Classroom is free of significant temperature shifts? Temperature was acceptable at the time of assessment.

THERMAL COMFORT Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too

THERMAL COMFORT	low if lower than 30% RH.) Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..		
AIR CONDITIONING	Room is free of smell of kitchen/food?	Odor detected at the time of assessment. Air freshener in room.	Remove air freshener from room.	Site
LOCAL EXHAUST FANS	Other exhaust fans that may exist in the classroom are functioning properly?	No exhaust fans in room. Identified in error.		

Room	Section	Question	Answer	Recommendation	Responsible
115	Inside Parameters:	Temp 72	RH 57.2	CO2 730	

GENERAL CLEANLINESS Food, if any, is stored in tightly sealed containers? No unsealed food items were observed at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
400P	Inside Parameters:	Temp 72	RH 55.8	CO2 1248	

GENERAL CLEANLINESS Classroom is dusted/vacuumed thoroughly and regularly? Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff. Site

GENERAL CLEANLINESS Air supply/return registers are cleaned regularly and free of dust and debris accumulation? Dust observed on supply and return registers at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. Site

EXCESS MOISTURE IN CLASSROOMS Windows, windowsills and window frames free of continuous condensation? Condensation on windows at the time of assessment. Temperature was within acceptable range and leaks were identified. Physical Plant Operations to evaluate and repair as appropriate. PPO

Room	Section	Question	Answer	Recommendation	Responsible
502	Inside Parameters:	Temp 72	RH 55.8	CO2 1248	

THERMAL COMFORT Temperature in my classroom is generally comfortable (72F-78F)? Temperature was acceptable at the time of assessment.

THERMAL COMFORT Classroom is free of significant temperature shifts? Temperature was acceptable at the time of assessment.

THERMAL COMFORT Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.) Humidity was acceptable at the time of assessment.

THERMAL COMFORT Room is usually comfortable? (If no, please explain in the notes below.) Environmental parameters were within acceptable range at the time of assessment..

LOCAL EXHAUST FANS Other exhaust fans that may exist in the classroom are functioning properly? Exhaust fan is not functioning properly. Physical Plant Operations to evaluate and repair as appropriate. PPO

Room	Section	Question	Answer	Recommendation	Responsible
504	Inside Parameters:	Temp 71.9	RH 55.5	CO2 1261	

THERMAL COMFORT Temperature in my classroom is generally comfortable (72F-78F)? Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

THERMAL COMFORT Room is usually comfortable? (If no, please explain in the notes below.) Environmental parameters were not within acceptable range at the time of assessment.. Physical Plant Operations to evaluate and repair as appropriate. PPO

Room	Section	Question	Answer	Recommendation	Responsible
505	Inside Parameters:	Temp 72.3	RH 56.1	CO2 1129	

THERMAL COMFORT Temperature in my classroom is generally comfortable (72F-78F)? Temperature was acceptable at the time of assessment.

THERMAL COMFORT Classroom is free of significant temperature shifts? Temperature was acceptable at the time of assessment.

THERMAL COMFORT Room is usually comfortable? (If no, please explain in the notes below.) Environmental parameters were within acceptable range at the time of assessment..

Room	Section	Question	Answer	Recommendation	Responsible

506	Inside Parameters:	Temp 72.8	RH 55.3	CO2 1153	
GENERAL CLEANLINESS	Room is free of pests?	Pests observed at the time of assessment.	Physical Plant Operation to initiate work order PPO to evaluate pest issue within location and take appropriate action.		
EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace ceiling tiles. Site		
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was acceptable at the time of assessment.			
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.			
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..			
ART SUPPLIES	Art supplies okay?	Art supplies in room.	Curriculum supervisor meet with appropriate staff to address issues of concern and ensure that all supplies are approved for use and handled/stored in a manner consistent with District procedures.	Site	
ART SUPPLIES	Exposure minimized for art supplies?	Art supplies in room.	Curriculum supervisor meet with appropriate staff to address issues of concern and ensure that all supplies are approved for use and handled/stored in a manner consistent with District procedures.	Site	
ART SUPPLIES	Exposure minimized for industrial supplies?	No industrial supplies in room. Room not being used as an industrial room.			

Room	Section	Question	Answer	Recommendation	Responsible
507A	Inside Parameters:	Temp 72	RH 55.7	CO2 1329	
GENERAL CLEANLINESS	Classrooms general appearance is clean and acceptable?	General cleanliness of the room at the time of assessment was acceptable.			
GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room.			

GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.	Site
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
EXCESS MOISTURE IN CLASSROOMS	Area around and under classroom sinks free of leaks?	No leaks or signs of water intrusion identified.		
EXCESS MOISTURE IN CLASSROOMS	Classroom lavatories/water fountains free of leaks?	No leaks or signs of water intrusion identified.		
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..		
AIR CONDITIONING	Air is flowing without obstruction?	Supply vents closed at the time of assessment.	Facilities serviceperson to open supply vents.	Site
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		
LOCAL EXHAUST FANS	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)	It appears that the ventilation system is adequate based on room activities.		

Room	Section	Question	Answer	Recommendation	Responsible
507B	Inside Parameters:	Temp	RH	CO2	
		72	55.2	1246	

GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
---------------------	---	---	--	------

AIR  
CONDITIONINGRoom is free of smell of mold  
or mildew?

Air freshener in room.

Remove air freshener.

Site

Room	Section	Question	Answer	Recommendation	Responsible
603	Inside Parameters:	Temp 70.6	RH 56.8	CO2 870	

GENERAL  
CLEANLINESSClassroom is dusted/vacuumed  
thoroughly and regularly?There does not appear to be a  
dusting issue within this room.GENERAL  
CLEANLINESSFloor is cleaned on a regular  
basis?Dust and dirt accumulation on  
floor.Facilities serviceperson to thoroughly clean  
and sanitize.

Site

ANIMALS IN THE  
CLASSROOMYou are informed about the  
potential allergies of your  
students?This is a general issue requiring  
approved communication among  
all stakeholders.Site based administration is encouraged to  
communicate all known student allergies to  
the appropriate personnel in order to modify  
classroom activities/conditions when  
necessary.

Site

THERMAL  
COMFORTTemperature in my classroom  
is generally comfortable (72F-  
78F)?Temperature was low at the time  
of assessment.Site based administration to encourage facility  
serviceperson staff to adjust the thermostat.  
Continue to monitor condition and initiate a  
work order for Physical Plant Operations to  
evaluate the HVAC system if temperature  
does not improve.

Site

THERMAL  
COMFORTClassroom is free of significant  
temperature shifts?Temperature was low at the time  
of assessment.Site based administration to encourage facility  
serviceperson staff to adjust the thermostat.  
Continue to monitor condition and initiate a  
work order for Physical Plant Operations to  
evaluate the HVAC system if temperature  
does not improve.

Site

THERMAL  
COMFORTHumidity is generally  
acceptable? (Typically too  
high if higher than 60%  
relative humidity [RH] or too  
low if lower than 30% RH.)Humidity was acceptable at the  
time of assessment.THERMAL  
COMFORTRoom is usually comfortable?  
(If no, please explain in the  
notes below.)Environmental parameters were  
within acceptable range at the  
time of assessment..

Room	Section	Question	Answer	Recommendation	Responsible
604	Inside Parameters:	Temp 69.4	RH 57.1	CO2 873	

ANIMALS IN THE You are informed about the

This is a general issue requiring

Site based administration is encouraged to

Site

CLASSROOM	potential allergies of your students?	approved communication among all stakeholders.	communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate and repair as appropriate. PPO

Room	Section	Question	Answer	Recommendation	Responsible
607	Inside Parameters:	Temp 70.4	RH 56.7	CO2 1157	

GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room.	
ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. Site
EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate and replace ceiling tiles as appropriate. PPO

Room	Section	Question	Answer	Recommendation	Responsible
608	Inside Parameters:	Temp 69.2	RH 57.5	CO2 894	

GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room.	
ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. Site
ANIMALS IN THE CLASSROOM	Activities and/or room	This is a general issue requiring	Site based administration is encouraged to Site

CLASSROOM conditions are modified to address student allergies? approved communication among all stakeholders. communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

LOCAL EXHAUST FANS Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section) No exhaust system/ventilation in room. Identified in error.

Room	Section	Question	Answer	Recommendation	Responsible
608P	Inside Parameters:	Temp 74.3	RH 48.9	CO2 755	

EXCESS MOISTURE IN CLASSROOMS

Classroom lavatories/water fountains free of leaks? No leaks or signs of water intrusion identified.

AIR CONDITIONING

Room is free of smell of mold or mildew? Live plants in room. Plant soil is a source of microbial growth.

LOCAL EXHAUST FANS

Bathroom exhaust fan is functioning properly? Bathroom exhaust fan is not functioning properly.

ART SUPPLIES

Art supplies okay? Art supplies in room.

ART SUPPLIES

Science supplies okay? Science supplies in room.

ART SUPPLIES

Industrial supplies okay? Industrial supplies in room.

Site based administration to advise staff to remove live plants. Site

Physical Plant Operations to evaluate and repair as appropriate. PPO

Curriculum supervisor meet with appropriate staff to address issues of concern and ensure that all supplies are approved for use and handled/stored in a manner consistent with District procedures. Site

Curriculum supervisor meet with appropriate staff to address issues of concern and ensure that all supplies are approved for use and handled/stored in a manner consistent with District procedures. Site

Curriculum supervisor meet with appropriate staff to address issues of concern and ensure that all supplies are approved for use and handled/stored in a manner consistent with District procedures. Site

Room	Section	Question	Answer	Recommendation	Responsible
702	Inside Parameters:	Temp 69.9	RH 55.2	CO2 856	

ANIMALS IN THE CLASSROOM

You are informed about the potential allergies of your approved communication among

Site based administration is encouraged to communicate all known student allergies to

Site

students? all stakeholders. the appropriate personnel in order to modify classroom activities/conditions when necessary.

ANIMALS IN THE CLASSROOM Activities and/or room conditions are modified to address student allergies? This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

LOCAL EXHAUST FANS Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section) It appears that the ventilation system is adequate based on room activities.

Room	Section	Question	Answer	Recommendation	Responsible
703	Inside Parameters:	Temp 69.8	RH 57.6	CO2 921	

DRAIN TRAPS IN THE CLASSROOM Water poured down floor drains once per week (approx. 1 quart of water). No floor drain in room.

DRAIN TRAPS IN THE CLASSROOM Water run in sinks at least once per week (about 2 cups of water). It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.

LOCAL EXHAUST FANS Other exhaust fans that may exist in the classroom are functioning properly? Exhaust fan is not functioning properly. Physical Plant Operations to evaluate and repair as appropriate. PPO

Room	Section	Question	Answer	Recommendation	Responsible
704	Inside Parameters:	Temp 69.6	RH 56.7	CO2 863	

GENERAL CLEANLINESS Air supply/return registers are cleaned regularly and free of dust and debris accumulation? No dust observed on supply/return registers at the time of assessment.

ANIMALS IN THE CLASSROOM You are informed about the potential allergies of your students? This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

EXCESS Windows, windowsills and No condensation on windows at

MOISTURE IN CLASSROOMS	window frames free of continuous condensation?	the time of assessment.		
EXCESS MOISTURE IN CLASSROOMS	Cold water pipes free of continuous condensation?	No condensation on pipes at the time of assessment.		
EXCESS MOISTURE IN CLASSROOMS	Indoor surfaces of exterior walls free of continuous condensation?	No visible condensation or signs of water intrusion identified at the time of assessment.		
EXCESS MOISTURE IN CLASSROOMS	Area around and under classroom sinks free of leaks?	No leaks or signs of water intrusion identified.		
EXCESS MOISTURE IN CLASSROOMS	Classroom lavatories/water fountains free of leaks?	No leaks or signs of water intrusion identified.		
EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	Ceiling tiles broken damaged or missing.	Facilities serviceperson to replace ceiling tiles.	Site
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
THERMAL COMFORT	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	No gaps in windows or doors identified at the time of assessment.		
THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.		
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the	Environmental parameters were not within acceptable range at the	Physical Plant Operations to evaluate and repair as appropriate.	PPO

notes below.)  
 AIR CONDITIONING Air flowing from air supply? Air supply/return ventilation is functioning.  
 AIR CONDITIONING Room is free of smell of vehicle exhaust? No odor detected at the time of assessment.  
 AIR CONDITIONING Room is free of smell of chemicals? No odor detected at the time of assessment.  
 AIR CONDITIONING Room is free of smell of mold or mildew? No microbial growth identified. No odor identified at the time of assessment.  
 ART SUPPLIES Art supplies okay? NA  
 ART SUPPLIES Science supplies okay? No science supplies in room. Room not being used as a science room.  
 ART SUPPLIES Following good handling and storage practices for art supplies? No art supplies in room. Room not being used as an art room.  
 ART SUPPLIES Following good handling and storage practices for science supplies? No science supplies in room. Room not being used as a science room.

Site

Room	Section	Question	Answer	Recommendation	Responsible
708	Inside Parameters:	Temp 70.1	RH 49.5	CO2 976	
	THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F-78F)?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
	THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate and repair as appropriate.	PPO
905	Inside Parameters:	Temp 73.9	RH 58.2	CO2 1181	

ART SUPPLIES Art supplies okay? No art supplies in room. Room not being used as an art room.

ART SUPPLIES Industrial supplies okay? No industrial supplies in room. Room not being used as an industrial room.

Room	Section	Question	Answer	Recommendation	Responsible
913	Inside Parameters:	Temp 74.6	RH 53.7	CO2 977	
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	Site
	THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..		
	AIR CONDITIONING	Room is free of smell of mold or mildew?	Live plants in room. Plant soil is a source of microbial growth.	Site based administration to advise staff to remove live plants.	Site

Room	Section	Question	Answer	Recommendation	Responsible
951	Inside Parameters:	Temp 71	RH 65	CO2 861	
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
	GENERAL CLEANLINESS	Room is free of pests?	Pests observed at the time of assessment.	Physical Plant Operation to initiate work order PPO to evaluate pest issue within location and take appropriate action.	
	GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.		
	ANIMALS IN THE CLASSROOM	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	ANIMALS IN THE CLASSROOM	Classroom is free of animals	No animals identified at the time		

CLASSROOM and pets? of assessment.

EXCESS Indoor surfaces of exterior No visible condensation or signs  
MOISTURE IN walls free of continuous of water intrusion identified at the  
CLASSROOMS condensation? time of assessment.

THERMAL Temperature in my classroom Temperature was acceptable at  
COMFORT is generally comfortable (72F- the time of assessment.  
78F)?

THERMAL Classroom is free of significant Temperature was acceptable at  
COMFORT temperature shifts? the time of assessment.

AIR Windows/doors are operable Windows and doors are operable  
CONDITIONING and are kept closed? and are not kept closed. Open  
doors and windows allow humid  
untreated air into occupied  
environment.

ART SUPPLIES Science supplies okay? No science supplies in room.  
Room not being used as a science  
room.

Site

Room	Section	Question	Answer	Recommendation	Responsible
952	Inside Parameters:	Temp	RH	CO2	
		72.5	65.3	905	

EXCESS Windows, windowsills and No condensation on windows at  
MOISTURE IN window frames free of the time of assessment.  
CLASSROOMS continuous condensation?

EXCESS Classroom lavatories/water No leaks or signs of water  
MOISTURE IN fountains free of leaks? intrusion identified.  
CLASSROOMS

LOCAL EXHAUST Bathroom exhaust fan is Bathroom exhaust fan is  
FANS functioning properly? functioning properly.

ART SUPPLIES Exposure minimized for art No art supplies in room. Room  
supplies? not being used as an art room.

ART SUPPLIES Exposure minimized for No science supplies in room.  
science supplies? Room not being used as a science  
room.

ART SUPPLIES Exposure minimized for No industrial supplies in room.  
industrial supplies? Room not being used as an  
industrial room.

Room	Section	Question	Answer	Recommendation	Responsible

954	Inside Parameters:	Temp 72.4	RH 65.7	CO2 909	
-----	--------------------	--------------	------------	------------	--

ANIMALS IN THE CLASSROOM

You are informed about the potential allergies of your students?

This is a general issue requiring approved communication among all stakeholders.

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site

Room	Section	Question	Answer	Recommendation	Responsible
959	Inside Parameters:	Temp 71.7	RH 61.2	CO2 758	

ANIMALS IN THE CLASSROOM

You are informed about the potential allergies of your students?

This is a general issue requiring approved communication among all stakeholders.

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site

ANIMALS IN THE CLASSROOM

Activities and/or room conditions are modified to address student allergies?

This is a general issue requiring approved communication among all stakeholders.

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site

AIR CONDITIONING

Room is free of smell of kitchen/food?

No odor detected at the time of assessment.

