

# Lauderdale Manors Elementary

## IAQ Walkthrough 5/5/2005

0431

Outside Temp  RH%  CO2

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
001	Temp <input type="text" value="73.8"/> RH% <input type="text" value="52.5"/> CO2 <input type="text" value="770"/>	Occupants: <input type="text"/>			
	<b>EXCESS MOISTURE IN CLASSROOMS</b>				
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	Condensation on windows at the time of assessment. Temperature was within acceptable range and leaks were identified.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	2
	Windows, windowsills and window frames free of continuous condensation?	No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	1
	<b>THERMAL COMFORT</b>				
	Classroom is free of significant temperature shifts?	thermostat for a/c units are on the roof, cannot control temp.	Temperature was acceptable at the time of assessment.	None	
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	thermostat for a/c units are on the roof, cannot control temp.	Gaps in windows or doors identified at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.	2
	Room is usually comfortable? (If no, please explain in the notes below.)	thermostat for a/c units are on the roof, cannot control temp.	Temperature was acceptable at the time of assessment.	None	
	Temperature in my classroom is generally comfortable (72F-76F)?	thermostat for a/c units are on the roof, cannot control temp.	Temperature was acceptable at the time of assessment.	None	
	Walkthrough				
		Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
029P	Temp <input type="text" value="73"/> RH% <input type="text" value="52.5"/> CO2 <input type="text" value="522"/>	Occupants: <input type="text"/>			
	<b>AIR CONDITIONING</b>				
	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.	None		
	<b>EXCESS MOISTURE IN CLASSROOMS</b>				
	Area around and under classroom sinks free of leaks?	No issues identified at the time of assessment.	None		
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	1

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
029P	Temp	73	RH%	52.5	CO2	522	Occupants:	
	Classroom lavatories/water fountains free of leaks?			No issues identified at the time of assessment.	None			
<b>GENERAL CLEANLINESS</b>								
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based		1
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based		1
	Trash is removed daily and trash bags are changed as appropriate?			No issues identified at the time of assessment.	None			
<b>LOCAL EXHAUST FANS</b>								
	Other exhaust fans that may exist in the classroom are functioning properly?			Exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations		3
<b>Walkthrough</b>								
				No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based		2
				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based		2
064	Temp	85.1	RH%	59.5	CO2	561	Occupants:	
<b>EXCESS MOISTURE IN CLASSROOMS</b>								
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Temperature was elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation. A/C unit not functioning at time of assessment.	Physical Plant Operations		1
<b>Walkthrough</b>								
				Temperature was elevated at the time of assessment. A/C unit was not working.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations		1
106	Temp	73.6	RH%	59.1	CO2	855	Occupants:	
<b>AIR CONDITIONING</b>								
	Room is free of smell of mold or mildew?		If air is off the smell of mold/mildew is evident		No microbial growth identified. No odor identified at the time of assessment.		None	
<b>GENERAL CLEANLINESS</b>								

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
106	Temp	73.6	RH% 59.1	CO2 855	Occupants:			
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2	
	<b>THERMAL COMFORT</b>							
	Classroom is free of significant temperature shifts?			The air is either too cold and blows very strong. I have to ask for it to be turned on. It is either on or off no in between.	No issues identified at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)			The air is either too cold and blows very strong. I have to ask for it to be turned on. It is either on or off no in between.	No issues identified at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?			The air is either too cold and blows very strong. I have to ask for it to be turned on. It is either on or off no in between.	No issues identified at the time of assessment.	None		
107	Temp	71.2	RH% 61.4	CO2 680	Occupants:			
	<b>AIR CONDITIONING</b>							
	Windows/doors are operable and are kept closed?			One panel of window does not seal tightly. The air escapes from under the window .	Gaps in windows or doors identified at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
	<b>ANIMALS IN THE CLASSROOM</b>							
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	<b>EXCESS MOISTURE IN CLASSROOMS</b>							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	1
	<b>THERMAL COMFORT</b>							
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)				Gaps in windows or doors identified at the time of assessment.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	2
	Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2

Walkthrough

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
107	Temp	<input type="text" value="71.2"/>	RH% <input type="text" value="61.4"/>	CO2 <input type="text" value="680"/>	Occupants: <input type="text"/>		
				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
108	Temp	<input type="text" value="68.4"/>	RH% <input type="text" value="64.1"/>	CO2 <input type="text" value="1021"/>	Occupants: <input type="text"/>		
<b>AIR CONDITIONING</b>							
	Air flowing from air supply?			No issues identified at the time of assessment.	None		
	Air is flowing without obstruction?			No issues identified at the time of assessment.	None		
	Room is free of smell of mold or mildew?			No microbial growth identified. No odor identified at the time of assessment.	None		
	Windows/doors are operable and are kept closed?			Windows are not operable. Open doors and windows allow humid untreated air into occupied environment.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
<b>DRAIN TRAPS IN THE CLASSROOM</b>							
	Water poured down floor drains once per week (approx. 1 quart of water).			No issues identified at the time of assessment.	None		
<b>EXCESS MOISTURE IN CLASSROOMS</b>							
	Windows, windowsills and window frames free of continuous condensation?			Condensation on windows at the time of assessment. Temperature was not within acceptable range and no leaks were identified.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
<b>THERMAL COMFORT</b>							
	Classroom is free of significant temperature shifts?			No issues identified at the time of assessment.	None		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)			No issues identified at the time of assessment.	None		
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)			Gaps in windows or doors identified at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
	Room is usually comfortable? (If no, please explain in the notes below.)			No issues identified at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?			No issues identified at the time of assessment.	None		
<b>Walkthrough</b>							
				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
108	Temp	68.4	RH% 64.1	CO2 1021	Occupants:			
115	Temp	69	RH% 59.7	CO2 679	Occupants:			
<b>ANIMALS IN THE CLASSROOM</b>								
You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
<b>GENERAL CLEANLINESS</b>								
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?					Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	1
Classroom is dusted/vacuumed thoroughly and regularly?					Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
<b>LOCAL EXHAUST FANS</b>								
Bathroom exhaust fan is functioning properly?					Exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
<b>THERMAL COMFORT</b>								
Classroom is free of significant temperature shifts?			The temperature in my room constantly varies. It seems like on cold days it is extremely cold (with air conditioning) and on hot days extremely hot (without air conditioning).		No issues identified at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)			The temperature in my room constantly varies. It seems like on cold days it is extremely cold (with air conditioning) and on hot days extremely hot (without air conditioning).		No issues identified at the time of assessment.	None		
Temperature in my classroom is generally comfortable (72F-76F)?			The temperature in my room constantly varies. It seems like on cold days it is extremely cold (with air conditioning) and on hot days extremely hot (without air conditioning).		No issues identified at the time of assessment.	None		
<b>Walkthrough</b>								
					Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	1

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
116	Temp	70.2	RH% 64.1	CO2 894	Occupants:		
<b>AIR CONDITIONING</b>							
	Air flowing from air supply?			No issues identified at the time of assessment.	None		
	Air is flowing without obstruction?			No issues identified at the time of assessment.	None		
	Room is free of smell of chemicals?			No issues identified at the time of assessment.	None		
	Room is free of smell of mold or mildew?			No issues identified at the time of assessment.	None		
	Room is free of smell of vehicle exhaust?			No issues identified at the time of assessment.	None		
	Windows/doors are operable and are kept closed?			No issues identified at the time of assessment.	None		
<b>ANIMALS IN THE CLASSROOM</b>							
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
<b>DRAIN TRAPS IN THE CLASSROOM</b>							
	Water poured down floor drains once per week (approx. 1 quart of water).			Water is not poured down floor drain at least once a week.	Site based administration should address maintenance of drains with facility serviceperson staff.	Site Based	2
<b>EXCESS MOISTURE IN CLASSROOMS</b>							
	Area around and under classroom sinks free of leaks?			Signs of water intrusion. Leak identified.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	2
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	1
	Cold water pipes free of continuous condensation?			No issues identified at the time of assessment.	None		
	Indoor surfaces of exterior walls free of continuous condensation?			No issues identified at the time of assessment.	None		
	Windows, windowsills and window frames free of continuous condensation?			No issues identified at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

116

Temp  RH%  CO2

Occupants:

**GENERAL CLEANLINESS**

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

Slight dust accumulation was observed on environmental surfaces at the time of assessment.

Site based administration should address general cleanliness with facility serviceperson staff.

Site Based

1

Room is free of pests?

No pests observed at the time of assessment.

None

**LOCAL EXHAUST FANS**

Bathroom exhaust fan is functioning properly?

No issues identified at the time of assessment.

None

Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)

It appears that classroom/functions are not consistent with educational specifications for room use.

Site based administration to discuss with facility Project Manager.

Site Based

1

My classroom has sufficient exhaust systems based on the activities/functionality of the room?

No issues identified at the time of assessment.

None

Other exhaust fans that may exist in the classroom are functioning properly?

No issues identified at the time of assessment.

None

**THERMAL COMFORT**

Classroom is free of significant temperature shifts?

No issues identified at the time of assessment.

None

Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)

No issues identified at the time of assessment.

None

Room is free of the introduction of outdoor air? (Gaps in window/door frames.)

No issues identified at the time of assessment.

None

Room is usually comfortable? (If no, please explain in the notes below.)

No issues identified at the time of assessment.

None

Temperature in my classroom is generally comfortable (72F-76F)?

No issues identified at the time of assessment.

None

117

Temp  RH%  CO2

Occupants:

**ANIMALS IN THE CLASSROOM**

Classroom is free of animals and pets?

117 acts as the Science room. The room has 3 fish tanks and during various months we have pet birds[ cockatiels.]

Animals were identified at the time of assessment. Animal/pet dander is a major allergen source that could impact occupant allergies.

Location to ensure that housing of animal or pet is in conjunction with approved curriculum. If not the animal must be removed.

Site Based

1

118

Temp  RH%  CO2  Occupants:

**AIR CONDITIONING**

Windows/doors are operable and are kept closed?	Windows have 1-2 inch gaps.	Windows are not operable. Open doors and windows allow humid untreated air into occupied environment.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	2
---	-----------------------------	---	--	---------------------------	---

**ANIMALS IN THE CLASSROOM**

Activities and/or room conditions are modified to address student allergies?		No issues identified at the time of assessment.	None		
You are informed about the potential allergies of your students?			Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3

**EXCESS MOISTURE IN CLASSROOMS**

Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?		No issues identified at the time of assessment.	None		
--	--	---	------	--	--

**GENERAL CLEANLINESS**

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		Excessive dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	1
Room is free of pests?		No pests observed at the time of assessment.	None		

**LOCAL EXHAUST FANS**

Other exhaust fans that may exist in the classroom are functioning properly?		No issues identified at the time of assessment.	None		
--	--	---	------	--	--

**THERMAL COMFORT**

Classroom is free of significant temperature shifts?	The room is either very cold or very hot.	No issues identified at the time of assessment.	None		
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	The room is either very cold or very hot.	No issues identified at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)	The room is either very cold or very hot.	No issues identified at the time of assessment.	None		
Temperature in my classroom is generally comfortable (72F-76F)?	The room is either very cold or very hot.	No issues identified at the time of assessment.	None		



FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
203	Temp	73.3	RH% 68.8	CO2 517	Occupants:		
<b>ANIMALS IN THE CLASSROOM</b>							
Activities and/or room conditions are modified to address student allergies?				No issues identified at the time of assessment.	None		
You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
<b>EXCESS MOISTURE IN CLASSROOMS</b>							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Signs of water intrusion. Leak identified.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	2
<b>GENERAL CLEANLINESS</b>							
Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Floor is cleaned on a regular basis?				No issues identified at the time of assessment.	None		
Room is free of pests?				No issues identified at the time of assessment.	None		
<b>THERMAL COMFORT</b>							
Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	3
<b>Walkthrough</b>							
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1

203A      Temp 73.3      RH% 68.8      CO2 517      Occupants:

**EXCESS MOISTURE IN CLASSROOMS**

Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?

Signs of water intrusion. Leak identified.

Facilities serviceperson to replace stained ceiling tiles.

Site Based

1

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

203A

Temp  RH%  CO2  Occupants:

**GENERAL CLEANLINESS**

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
Classroom is dusted/vacuumed thoroughly and regularly?		Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Classrooms general appearance is clean and acceptable?		General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	1
Floor is cleaned on a regular basis?		No issues identified at the time of assessment.	None		
Room is free of pests?		No pests observed at the time of assessment.	None		
Spills and other such issues requiring custodial assistance are addressed in a timely manner?		No issues identified at the time of assessment.	None		

**THERMAL COMFORT**

Room is usually comfortable? (If no, please explain in the notes below.)	freezing cold	Temperature was acceptable at the time of assessment.	None		
Temperature in my classroom is generally comfortable (72F-76F)?	freezing cold	No issues identified at the time of assessment.	None		

**Walkthrough**

Exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	1
--	--	---------------------------	---

204

Temp  RH%  CO2  Occupants:

**AIR CONDITIONING**

Air flowing from air supply?		No issues identified at the time of assessment.	None		
Room is free of smell of mold or mildew?		No microbial growth identified. No odor identified at the time of assessment.	None		
Windows/doors are operable and are kept closed?		Windows and/or doors were open at the time of assessment. Open doors and windows allow humid untreated air into occupied environment.	Site based administration to encourage staff to keep doors and windows closed. Open doors and windows allow humid untreated air into occupied environment.	Site Based	1

**EXCESS MOISTURE IN CLASSROOMS**

Area around and under classroom sinks free of leaks?		Signs of water intrusion. Leak identified.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	2
--	--	--	--	---------------------------	---

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
204	Temp	70.7	RH% 58.1	CO2 1350	Occupants:		
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Signs of water intrusion. Leak identified.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations 2
	Classroom lavatories/water fountains free of leaks?				Signs of water intrusion. Leak identified.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations 2
	Windows, windowsills and window frames free of continuous condensation?				No issues identified at the time of assessment.	None	
	<b>GENERAL CLEANLINESS</b>						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No issues identified at the time of assessment.	None	
	Classroom is dusted/vacuumed thoroughly and regularly?				No issues identified at the time of assessment.	None	
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?				No issues identified at the time of assessment.	None	
	<b>THERMAL COMFORT</b>						
	Classroom is free of significant temperature shifts?				No issues identified at the time of assessment.	None	
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)				No issues identified at the time of assessment.	None	
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)				Gaps in windows or doors identified at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations 2
	Room is usually comfortable? (If no, please explain in the notes below.)				No issues identified at the time of assessment.	None	
	Temperature in my classroom is generally comfortable (72F-76F)?				No issues identified at the time of assessment.	None	
	<b>Walkthrough</b>						
					Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based 1
					Items are stored on top of A/C unit.	Facilities serviceperson should remove items.	Site Based 2

205 Temp 70.1 RH% 60.1 CO2 737 Occupants:

**GENERAL CLEANLINESS**

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

No issues identified at the time of assessment. None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
205	Temp	70.1	RH% 60.1	CO2 737	Occupants:			
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	3
	Classrooms general appearance is clean and acceptable?				No issues identified at the time of assessment.	None		
	Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Room is free of pests?				No issues identified at the time of assessment.	None		
<b>LOCAL EXHAUST FANS</b>								
	Bathroom exhaust fan is functioning properly?		No bathroom in room 205		No issues identified at the time of assessment.	None		
<b>THERMAL COMFORT</b>								
	Classroom is free of significant temperature shifts?		Either too hot or too cold		No issues identified at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)		Either too hot or too cold		No issues identified at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?		Either too hot or too cold		No issues identified at the time of assessment.	None		
206	Temp	69.9	RH% 55.8	CO2 665	Occupants:			
<b>AIR CONDITIONING</b>								
	Room is free of smell of mold or mildew?		I am not sure what odor will occur if there is mold and mildew. But I have noticed a peculiar smell stemming from the vents.		No issues identified at the time of assessment.	None		
	Room is free of smell of vehicle exhaust?		I am not sure what odor will occur if there is mold and mildew. But I have noticed a peculiar smell stemming from the vents.		No issues identified at the time of assessment.	None		
<b>GENERAL CLEANLINESS</b>								
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		In regards to question b, there is no carpet in this room; it is tiled. However, dusting is not done on a regular basis.		Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	3
	Classroom is dusted/vacuumed thoroughly and regularly?		In regards to question b, there is no carpet in this room; it is tiled. However, dusting is not done on a regular basis.		Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	3

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
206	Temp	69.9	RH% 55.8	CO2 665	Occupants:		
	Floor is cleaned on a regular basis?	In regards to question b, there is no carpet in this room; it is tiled. However, dusting is not done on a regular basis.			No issues identified at the time of assessment.	None	
<b>LOCAL EXHAUST FANS</b>							
	Bathroom exhaust fan is functioning properly?	I do not have a bathroom in my classroom.			No issues identified at the time of assessment.	None	
<b>THERMAL COMFORT</b>							
	Room is usually comfortable? (If no, please explain in the notes below.)	Previously, there have been problems with the air conditioning unit which made the room extremely warm. However, the system has been repaired and now it is too cold.			No issues identified at the time of assessment.	None	
	Temperature in my classroom is generally comfortable (72F-76F)?	Previously, there have been problems with the air conditioning unit which made the room extremely warm. However, the system has been repaired and now it is too cold.			No issues identified at the time of assessment.	None	
<b>Walkthrough</b>							
					Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based 1
300A	Temp	69.9	RH% 66.5	CO2 771	Occupants:		
<b>AIR CONDITIONING</b>							
	Room is free of smell of mold or mildew?				No issues identified at the time of assessment.	None	
<b>EXCESS MOISTURE IN CLASSROOMS</b>							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Signs of water intrusion. Leak identified.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations 2
	Indoor surfaces of exterior walls free of continuous condensation?				Condensation on walls at the time of assessment. Leak identified.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations 3
	Windows, windowsills and window frames free of continuous condensation?				Condensation on windows at the time of assessment. Temperature was not within acceptable range and leaks were identified.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations 2
<b>GENERAL CLEANLINESS</b>							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 1

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
300A	Temp	69.9	RH% 66.5	CO2 771	Occupants:			
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	1
	Floor is cleaned on a regular basis?				No issues identified at the time of assessment.	None		
	Room is free of pests?				No pests observed at the time of assessment.	None		
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?				No issues identified at the time of assessment.	None		
	Trash is removed daily and trash bags are changed as appropriate?				No issues identified at the time of assessment.	None		
<b>LOCAL EXHAUST FANS</b>								
	Bathroom exhaust fan is functioning properly?				Exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	3
	Other exhaust fans that may exist in the classroom are functioning properly?				Exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	3
<b>THERMAL COMFORT</b>								
	Classroom is free of significant temperature shifts?				No issues identified at the time of assessment.	None		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)				Humidity was slightly elevated at the time of assessment. Windows and/or doors were open at the time of assessment. Open doors and windows allow humid untreated air into occupied environment.	Site based administration to encourage staff to keep doors and windows closed. Open doors and windows allow humid untreated air into occupied environment.	Site Based	3
	Room is usually comfortable? (If no, please explain in the notes below.)				No issues identified at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?				No issues identified at the time of assessment.	None		
<b>Walkthrough</b>								
					Plaster damage at windows.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
312	Temp	69.2	RH% 61.8	CO2 770	Occupants:			
<b>ANIMALS IN THE CLASSROOM</b>								
	You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
312	Temp	69.2	RH% 61.8	CO2 770	Occupants:		
<b>GENERAL CLEANLINESS</b>							
Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	1
<b>Walkthrough</b>							
				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize carpet.	Site Based	2
313	Temp	70.2	RH% 64.3	CO2 836	Occupants:		
<b>AIR CONDITIONING</b>							
Room is free of smell of chemicals?				No issues identified at the time of assessment.	None		
Room is free of smell of mold or mildew?				No microbial growth identified. No odor identified at the time of assessment.	None		
<b>ANIMALS IN THE CLASSROOM</b>							
You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
<b>EXCESS MOISTURE IN CLASSROOMS</b>							
Area around and under classroom sinks free of leaks?				No issues identified at the time of assessment.	None		\
Indoor surfaces of exterior walls free of continuous condensation?				No issues identified at the time of assessment.	None		
Windows, windowsills and window frames free of continuous condensation?				No issues identified at the time of assessment.	None		
<b>GENERAL CLEANLINESS</b>							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Spills and other such issues requiring custodial assistance are addressed in a timely manner?				No issues identified at the time of assessment.	None		
<b>THERMAL COMFORT</b>							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
313	Temp	70.2	RH%	64.3	CO2	836	Occupants:	
	Classroom is free of significant temperature shifts?				No issues identified at the time of assessment.	None		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)				No issues identified at the time of assessment.	None		
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)				No issues identified at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)				No issues identified at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?				No issues identified at the time of assessment.	None		
404	Temp	73	RH%	68.8	CO2	2023	Occupants:	
	<b>AIR CONDITIONING</b>							
	Room is free of smell of mold or mildew?				No microbial growth identified. No odor identified at the time of assessment.	None		
	<b>ANIMALS IN THE CLASSROOM</b>							
	You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	<b>EXCESS MOISTURE IN CLASSROOMS</b>							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Signs of water intrusion. Leak identified.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
	Cold water pipes free of continuous condensation?				No issues identified at the time of assessment.	None		
	Windows, windowsills and window frames free of continuous condensation?				No issues identified at the time of assessment.	None		
	<b>GENERAL CLEANLINESS</b>							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	2
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	1
	Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	1



FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
404	Temp	73	RH% 68.8	CO2 2023	Occupants:			
	Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	1
	Room is free of pests?				Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	
<b>THERMAL COMFORT</b>								
	Classroom is free of significant temperature shifts?		The room is usually cold and temperature is not regulated properly.		No issues identified at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)		The room is usually cold and temperature is not regulated properly.		No issues identified at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?		The room is usually cold and temperature is not regulated properly.		No issues identified at the time of assessment.	None		
<b>Walkthrough</b>								
					CO2 and humidity levels were slightly elevated.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower CO2 and humidity level.	Physical Plant Operations	2
					No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
406	Temp	73.5	RH% 61.5	CO2 1654	Occupants:			
<b>ANIMALS IN THE CLASSROOM</b>								
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
<b>GENERAL CLEANLINESS</b>								
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	1
	Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	1

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
406	Temp	73.5	RH% 61.5	CO2 1654	Occupants: <input type="text"/>		
	Room is free of pests?			No pests observed at the time of assessment.	None		
	<b>THERMAL COMFORT</b>						
	Classroom is free of significant temperature shifts?			No issues identified at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?			No issues identified at the time of assessment.	None		
	<b>Walkthrough</b>						
				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
408	Temp	74.1	RH% 60.3	CO2 1135	Occupants: <input type="text"/>		
	<b>GENERAL CLEANLINESS</b>						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	1
	Floor is cleaned on a regular basis?			Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	1
701	Temp	74.2	RH% 52.8	CO2 769	Occupants: <input type="text"/>		
	<b>EXCESS MOISTURE IN CLASSROOMS</b>						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No issues identified at the time of assessment.	None		
	Indoor surfaces of exterior walls free of continuous condensation?			No issues identified at the time of assessment.	None		
	<b>THERMAL COMFORT</b>						
	Classroom is free of significant temperature shifts?			No issues identified at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?			No issues identified at the time of assessment.	None		
	<b>Walkthrough</b>						

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
701	Temp	74.2	RH% 52.8	CO2 769	Occupants: <input type="text"/>		
				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
702	Temp	73.3	RH% 57	CO2 698	Occupants: <input type="text"/>		
<b>GENERAL CLEANLINESS</b>							
				No issues identified at the time of assessment.	None		
				Classroom is dusted/vacuumed thoroughly and regularly?			
				Classrooms general appearance is clean and acceptable?	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	1
				Floor is cleaned on a regular basis?	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	3
				Room is free of pests?	None		
				Spills and other such issues requiring custodial assistance are addressed in a timely manner?	None		
703	Temp	73	RH% 60.3	CO2 847	Occupants: <input type="text"/>		
<b>ANIMALS IN THE CLASSROOM</b>							
					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
				Activities and/or room conditions are modified to address student allergies?			
				You are informed about the potential allergies of your students?	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
<b>EXCESS MOISTURE IN CLASSROOMS</b>							
				Signs of water intrusion. Leak identified.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	1
				Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			
<b>GENERAL CLEANLINESS</b>							
				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
				Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
703	Temp	73	RH% 60.3	CO2 847	Occupants: <input type="text"/>		
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 1
	Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 3
	Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
	Room is free of pests?				No pests observed at the time of assessment.	None	
<b>LOCAL EXHAUST FANS</b>							
	Bathroom exhaust fan is functioning properly?				No issues identified at the time of assessment.	None	
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?				No issues identified at the time of assessment.	None	
	Other exhaust fans that may exist in the classroom are functioning properly?				No issues identified at the time of assessment.	None	
704	Temp	72.9	RH% 58.6	CO2 927	Occupants: <input type="text"/>		
<b>AIR CONDITIONING</b>							
	Room is free of smell of mold or mildew?				Odor detected and microbial growth identified.	Physical Plant Operations to evaluate cause of microbial growth and repair and remediate as appropriate.	Physical Plant Operations 1
<b>GENERAL CLEANLINESS</b>							
	Room is free of pests?				No issues identified at the time of assessment.	None	
<b>Walkthrough</b>							
					Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
					Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
					Plaster deteriorating next to window.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations 1

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
705	Temp	72.8	RH% 57.9	CO2 777	Occupants:		
<b>ANIMALS IN THE CLASSROOM</b>							
Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
<b>ART SUPPLIES</b>							
Industrial supplies okay?					No issues identified at the time of assessment.	None	
Science supplies okay?					No issues identified at the time of assessment.	None	
<b>DRAIN TRAPS IN THE CLASSROOM</b>							
Water poured down floor drains once per week (approx. 1 quart of water).					No issues identified at the time of assessment.	None	
<b>EXCESS MOISTURE IN CLASSROOMS</b>							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			one ceiling tile in classroom and closet has water spots		No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace damaged ceiling tiles.	Site Based 1
<b>GENERAL CLEANLINESS</b>							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?					Dust observed on return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 1
Classroom is dusted/vacuumed thoroughly and regularly?					No issues identified at the time of assessment.	None	
Classrooms general appearance is clean and acceptable?					No issues identified at the time of assessment.	None	
Floor is cleaned on a regular basis?					No issues identified at the time of assessment.	None	
Room is free of pests?					No pests observed at the time of assessment.	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
708	Temp	<input type="text" value="72.1"/>	RH% <input type="text" value="58.7"/>	CO2 <input type="text" value="963"/>	Occupants: <input type="text"/>		
<b>AIR CONDITIONING</b>							
Room is free of smell of mold or mildew?				No microbial growth identified. No odor identified at the time of assessment.	None		
<b>ANIMALS IN THE CLASSROOM</b>							
You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
<b>EXCESS MOISTURE IN CLASSROOMS</b>							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No issues identified at the time of assessment.	None		
Windows, windowsills and window frames free of continuous condensation?				No issues identified at the time of assessment.	None		
<b>GENERAL CLEANLINESS</b>							
Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	3
Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	3
Floor is cleaned on a regular basis?				No issues identified at the time of assessment.	None		
Spills and other such issues requiring custodial assistance are addressed in a timely manner?				No issues identified at the time of assessment.	None		
<b>LOCAL EXHAUST FANS</b>							
Bathroom exhaust fan is functioning properly?				No issues identified at the time of assessment.	None		
Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)				No issues identified at the time of assessment.	None		
My classroom has sufficient exhaust systems based on the activities/functionality of the room?				No issues identified at the time of assessment.	None		
Other exhaust fans that may exist in the classroom are functioning properly?				No issues identified at the time of assessment.	None		
<b>THERMAL COMFORT</b>							
Classroom is free of significant temperature shifts?				No issues identified at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
718	Temp	73	RH% 60	CO2 1260	Occupants:		
<b>AIR CONDITIONING</b>							
Room is free of smell of mold or mildew?				No microbial growth identified. No odor identified at the time of assessment.	None		
<b>ANIMALS IN THE CLASSROOM</b>							
Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
<b>EXCESS MOISTURE IN CLASSROOMS</b>							
Area around and under classroom sinks free of leaks?				No issues identified at the time of assessment.	None		
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace damaged ceiling tiles.	Site Based	1
Windows, windowsills and window frames free of continuous condensation?				No issues identified at the time of assessment.	None		
<b>GENERAL CLEANLINESS</b>							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	3
Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Floor is cleaned on a regular basis?				No issues identified at the time of assessment.	None		
<b>LOCAL EXHAUST FANS</b>							
Bathroom exhaust fan is functioning properly?				Exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	3
Other exhaust fans that may exist in the classroom are functioning properly?				No issues identified at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
720	Temp	73.8	RH% 59.9	CO2 1437	Occupants:		
<b>AIR CONDITIONING</b>							
	Room is free of smell of mold or mildew?				No microbial growth identified. No odor identified at the time of assessment.	None	
<b>EXCESS MOISTURE IN CLASSROOMS</b>							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace damaged ceiling tiles.	Site Based 1
<b>GENERAL CLEANLINESS</b>							
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
	Room is free of pests?				No pests observed at the time of assessment.	None	
<b>LOCAL EXHAUST FANS</b>							
	Bathroom exhaust fan is functioning properly?				Exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations 2
725	Temp	73.6	RH% 59.3	CO2 1227	Occupants:		
<b>AIR CONDITIONING</b>							
	Windows/doors are operable and are kept closed?				No issues identified at the time of assessment.	None	
<b>ANIMALS IN THE CLASSROOM</b>							
	Activities and/or room conditions are modified to address student allergies?				MY CLASS RECENTLY RECEIVED A FISH FOR GOOD BEHAVIOR FROM THE SCIENCE TEACHER.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	Classroom is free of animals and pets?				MY CLASS RECENTLY RECEIVED A FISH FOR GOOD BEHAVIOR FROM THE SCIENCE TEACHER.	None	
	You are informed about the potential allergies of your students?				MY CLASS RECENTLY RECEIVED A FISH FOR GOOD BEHAVIOR FROM THE SCIENCE TEACHER.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
<b>GENERAL CLEANLINESS</b>							



FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
725	Temp	73.6	RH% 59.3	CO2 1227	Occupants:		
	Classroom is dusted/vacuumed thoroughly and regularly?	THE CLASSROOMS GENERAL APPEARANCE IS O.K. I AM NOT CERTAIN IF THE REGISTERS ARE CLEANED REGULARLY.			No issues identified at the time of assessment.	None	
	<b>THERMAL COMFORT</b>						
	Classroom is free of significant temperature shifts?	I HAVE WINDOWS THAT ARE BROKEN IN THE CLASSROOM.			No issues identified at the time of assessment.	None	
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	I HAVE WINDOWS THAT ARE BROKEN IN THE CLASSROOM.			Gaps in windows or doors identified at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations 3
	<b>Walkthrough</b>						
					Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
872V	Temp	73.3	RH% 49.9	CO2 1190	Occupants:		
	<b>ANIMALS IN THE CLASSROOM</b>						
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	<b>EXCESS MOISTURE IN CLASSROOMS</b>						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace damaged ceiling tiles.	Site Based 1
	Windows, windowsills and window frames free of continuous condensation?				No issues identified at the time of assessment.	None	
	<b>GENERAL CLEANLINESS</b>						
	Classroom is dusted/vacuumed thoroughly and regularly?				No issues identified at the time of assessment.	None	
	Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 3
	Room is free of pests?				No pests observed at the time of assessment.	None	
	<b>Walkthrough</b>						
					Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2

FISH/Room	Participant Comments				Response	Recommendation	Responsible	Priority				
872V	Temp	73.3	RH%	49.9	CO2	1190	Occupants:		Dust and debris on HVAC filters.	Facilities serviceperson to replace HVAC filters.	Site Based	1