

Lloyd Estates Elementary

IAQ Walkthrough 5/20/2005

1091

Outside Temp RH% CO2

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
007	Temp <input type="text" value="78.8"/> RH% <input type="text" value="59"/> CO2 <input type="text" value="1181"/>	Occupants: <input type="text"/>			
	ANIMALS IN THE CLASSROOM				
	Activities and/or room conditions are modified to address student allergies?		None		None
	Classroom is free of animals and pets?	No animals identified at the time of assessment.	None		None
	DRAIN TRAPS IN THE CLASSROOM				
	Water poured down floor drains once per week (approx. 1 quart of water).	It appears as though water is poured down the floor drain at least once a week.	None		None
	EXCESS MOISTURE IN CLASSROOMS				
	Indoor surfaces of exterior walls free of continuous condensation?	No visible condensation or signs of water intrusion identified at the time of assessment.	None		None
	Windows, windowsills and window frames free of continuous condensation?	No condensation on windows at the time of assessment.	None		None
	GENERAL CLEANLINESS				
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	No dust observed on supply/return registers at the time of assessment.	None		None
	Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room.	None		None
	Classrooms general appearance is clean and acceptable?	General cleanliness of the room at the time of assessment was acceptable.	None		None
	Floor is cleaned on a regular basis?	Dust and dirt accumulation on floor.	None		None
	Room is free of pests?	No pests observed at the time of assessment.	None		None
	Room is free of the use of scented cleaners and air fresheners?	No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.	None		None
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?	No issues identified relating to spill clean up practices at the time of assessment..	None		None
	THERMAL COMFORT				

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
<i>007</i>	Temp	<input type="text" value="78.8"/>	RH%	<input type="text" value="59"/>	CO2	<input type="text" value="1181"/>	Occupants:	<input type="text"/>			
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)				No gaps in windows or doors identified at the time of assessment.	None	None				
<i>101E</i>	Temp	<input type="text" value="81.7"/>	RH%	<input type="text" value="36.3"/>	CO2	<input type="text" value="936"/>	Occupants:	<input type="text" value="3"/>			
	LOCAL EXHAUST FANS										
	Bathroom exhaust fan is functioning properly?				Bathroom exhaust fan is functioning properly.	None	None				
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)				It appears that the ventilation system is adequate based on room activities.	None	None				
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?				It appears that the ventilation system is adequate based on room activities.	None	None				
	Other exhaust fans that may exist in the classroom are functioning properly?				Exhaust fan is functioning properly.	None	None				
<i>101F</i>	Temp	<input type="text" value="81.7"/>	RH%	<input type="text" value="36.3"/>	CO2	<input type="text" value="936"/>	Occupants:	<input type="text"/>			
	GENERAL CLEANLINESS										
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None	None				
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	None				
	Trash is removed daily and trash bags are changed as appropriate?				No issues identified regarding trash removal practices.	None	None				
	LOCAL EXHAUST FANS										
	Bathroom exhaust fan is functioning properly?				Bathroom exhaust fan is functioning properly.	None	None				
	Other exhaust fans that may exist in the classroom are functioning properly?				Exhaust fan is functioning properly.	None	None				
<i>101G</i>	Temp	<input type="text" value="81.7"/>	RH%	<input type="text" value="36.3"/>	CO2	<input type="text" value="936"/>	Occupants:	<input type="text"/>			
	ANIMALS IN THE CLASSROOM										
	Activities and/or room conditions are modified to address student allergies?					None	None				
	You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based				3

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
101G	Temp	81.7	RH% 36.3	CO2 936	Occupants:		
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	None
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None	None
	Trash is removed daily and trash bags are changed as appropriate?				No issues identified regarding trash removal practices.	None	None
101J	Temp	81.7	RH% 36.3	CO2 936	Occupants:		
AIR CONDITIONING							
	Air flowing from air supply?				Air flowing without obstruction at the time of assessments.	None	None
	Air is flowing without obstruction?				Air flowing without obstruction at the time of assessments.	None	None
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	None
	Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was acceptable.	None	None
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None	None
	Trash is removed daily and trash bags are changed as appropriate?				No issues identified regarding trash removal practices.	None	None
LOCAL EXHAUST FANS							
	Other exhaust fans that may exist in the classroom are functioning properly?				Exhaust fan is functioning properly.	None	None
Walkthrough							
					Carpet was stained and torn.	Physical Plant Operations to evaluate and repair/replace as appropriate. Change carpet in entire front office area.	Physical Plant Operations 2
102	Temp	81.6	RH% 37.2	CO2 1007	Occupants:		
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
102	Temp	81.6	RH% 37.2	CO2 1007	Occupants:			
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None	None	
	Trash is removed daily and trash bags are changed as appropriate?				No issues identified regarding trash removal practices.	None	None	
LOCKER ROOM								
	Locker room and showers cleaned regularly and properly?				Issues not applicable. Room is not a locker room.	None	None	
102A	Temp	81.6	RH% 37.2	CO2 1007	Occupants:			
	GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	None	
Trash is removed daily and trash bags are changed as appropriate?				No issues identified regarding trash removal practices.	None	None		
Walkthrough								
					Reset the toilet.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations 2	
					It appears as though toilet is not utilized regularly. Sewer gas odor detected. By flushing toilet regularly it eliminates the potential for sewer gas odors.	Site based administration should address maintenance of toilets with facility serviceperson staff.	Site Based 2	
105	Temp	82.0	RH% 45.6	CO2 1000	Occupants:	4		
	EXCESS MOISTURE IN CLASSROOMS							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Dust and debris on ceiling tiles around supply air vents.	Facilities serviceperson to replace soiled ceiling tiles.	Site Based 2	
GENERAL CLEANLINESS								
Classroom is dusted/vacuumed thoroughly and regularly?					There does not appear to be a dusting issue within this room.	None	None	
Floor is cleaned on a regular basis?					Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2	
105A	Temp	81.5	RH% 43.6	CO2 890	Occupants:			
	EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?					No leaks or signs of water intrusion identified.	None	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
105A	Temp	<input type="text" value="81.5"/>	RH% <input type="text" value="43.6"/>	CO2 <input type="text" value="890"/>	Occupants: <input type="text"/>		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?					There does not appear to be a dusting issue within this room.	None	None
Floor is cleaned on a regular basis?					Floor was clean at the time of assessment.	None	None
Walkthrough							
					Install stand alone unit.	Physical Plant Operations to initiate work order to install stand alone unit.	Physical Plant Operations 1
105B	Temp	<input type="text" value="82.1"/>	RH% <input type="text" value="41.5"/>	CO2 <input type="text" value="1064"/>	Occupants: <input type="text" value="2"/>		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?						None	None
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?					There does not appear to be a dusting issue within this room.	None	None
Floor is cleaned on a regular basis?					Floor was clean at the time of assessment.	None	None
Walkthrough							
					Signs of water intrusion. Leak identified.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations 1
108	Temp	<input type="text" value="79.2"/>	RH% <input type="text" value="51.0"/>	CO2 <input type="text" value="1048"/>	Occupants: <input type="text" value="2"/>		
AIR CONDITIONING							
Air flowing from air supply?					Air flowing without obstruction at the time of assessments.	None	None
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?					No dust observed on supply/return registers at the time of assessment.	None	None
Floor is cleaned on a regular basis?					Floor was clean at the time of assessment.	None	None
THERMAL COMFORT							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
108	Temp	79.2	RH%	51.0	CO2	1048	Occupants:	2			
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		Central air does not run through this office. Stand alone A/C unit is currently inoperable.		Humidity was slightly elevated at the time of assessment - less than 10% greater than outdoors. Humidity slightly exceeded target range, however indoor humidity was more than 10% lower than the outside reading which is evidence that the ventilation system		Facilities serviceperson should monitor this room.	Site Based			3
	Room is usually comfortable? (If no, please explain in the notes below.)		Central air does not run through this office. Stand alone A/C unit is currently inoperable.		Environmental parameters were not within acceptable range at the time of assessment.		Physical Plant Operations to evaluate need for test and balance.	Physical Plant Operations			2
	Walkthrough				Repair/replace wall unit A/C.		Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations			2
					Repair A/C duct.		Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations			2
111	Temp	75.6	RH%	58.8	CO2	901	Occupants:				
	AIR CONDITIONING										
	Room is free of smell of mold or mildew?		Office sometimes has moldy, mildewy smell. I am highly allergic to both. 111A & 111B are areas within my main office and consistently smell of mold and mildew.		Odor detected and no microbial growth identified.		Physical Plant operations to evaluate cause of odor.	Physical Plant Operations			2
	Windows/doors are operable and are kept closed?		Office sometimes has moldy, mildewy smell. I am highly allergic to both. 111A & 111B are areas within my main office and consistently smell of mold and mildew.		Windows are not operable. Open doors and windows allow humid untreated air into occupied environment.		Physical Plant Operations to evaluate and repair as appropriate. However, site based administration to encourage staff to keep doors and windows closed.	Physical Plant Operations			3
	DRAIN TRAPS IN THE CLASSROOM										
	Water poured down floor drains once per week (approx. 1 quart of water).				It appears as though water is poured down the floor drain at least once a week.		None	None			
	Water run in sinks at least once per week (about 2 cups of water).				It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.		None	None			
	GENERAL CLEANLINESS										
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		Air quality of room has improved markedly since improvements were made last year to remove some mold sources. Office is often not cleaned even weekly. Floor is cleaned very infrequently. I feel this is due to not having enough custodians available.		Dust observed on supply/return registers at the time of assessment.		Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based			2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
111	Temp	75.6	RH% 58.8	CO2 901	Occupants: <input type="text"/>		
Classroom is dusted/vacuumed thoroughly and regularly?	Air quality of room has improved markedly since improvements were made last year to remove some mold sources. Office is often not cleaned even weekly. Floor is cleaned very infrequently. I feel this is due to not having enough custodians available.			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Floor is cleaned on a regular basis?	Air quality of room has improved markedly since improvements were made last year to remove some mold sources. Office is often not cleaned even weekly. Floor is cleaned very infrequently. I feel this is due to not having enough custodians available.			Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
Room is free of the use of scented cleaners and air fresheners?	Air quality of room has improved markedly since improvements were made last year to remove some mold sources. Office is often not cleaned even weekly. Floor is cleaned very infrequently. I feel this is due to not having enough custodians available.			Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1
LOCAL EXHAUST FANS							
Bathroom exhaust fan is functioning properly?	No bathroom			No bathroom. Identified in error.	None	None	
THERMAL COMFORT							
Classroom is free of significant temperature shifts?	Office is often uncomfortably cold.			Temperature was acceptable at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Office is often uncomfortably cold.			Humidity was slightly elevated at the time of assessment - less than 10% greater than outdoors. Humidity slightly exceeded target range, however indoor humidity was more than 10% lower than the outside reading which is evidence that the ventilation system	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
Room is usually comfortable? (If no, please explain in the notes below.)	Office is often uncomfortably cold.			Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate need for test and balance.	Physical Plant Operations	2
Temperature in my classroom is generally comfortable (72F-76F)?	Office is often uncomfortably cold.			Temperature was acceptable at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
112	Temp	77.1	RH% 53.4	CO2 934	Occupants:	4	
AIR CONDITIONING							
	Room is free of smell of kitchen/food?			No odor detected at the time of assessment.	None	None	
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None	None	
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None	None	
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None	None	
	Trash is removed daily and trash bags are changed as appropriate?			No issues identified regarding trash removal practices.	None	None	
Walkthrough							
				Repair leak along supply air grill.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
115	Temp	77.7	RH% 58.3	CO2 1104	Occupants:	25	
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.	None	None	
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None	None	
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?		I would love to teach in a class where the temperature is set in a comfortable range, not one that averages 62-65 degrees.	Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Room is usually comfortable? (If no, please explain in the notes below.)		I would love to teach in a class where the temperature is set in a comfortable range, not one that averages 62-65 degrees.	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate need for test and balance.	Physical Plant Operations	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
115	Temp <input type="text" value="77.7"/>	RH% <input type="text" value="58.3"/>	CO2 <input type="text" value="1104"/>	Occupants: <input type="text" value="25"/>			
Temperature in my classroom is generally comfortable (72F-76F)?	I would love to teach in a class where the temperature is set in a comfortable range, not one that averages 62-65 degrees.			Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
115B	Temp <input type="text" value="78.1"/>	RH% <input type="text" value="53.8"/>	CO2 <input type="text" value="913"/>	Occupants: <input type="text" value="2"/>			
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None	None	
Walkthrough				Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	2
					Remove roll of carpet under counter.	Site Based	2
116	Temp <input type="text" value="78.6"/>	RH% <input type="text" value="55.9"/>	CO2 <input type="text" value="915"/>	Occupants: <input type="text" value="21"/>			
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?				None	None	
GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?			The floors are not clean everyday. They are dirty and unacceptable. It is sad.	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Classrooms general appearance is clean and acceptable?			The floors are not clean everyday. They are dirty and unacceptable. It is sad.	General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Floor is cleaned on a regular basis?			The floors are not clean everyday. They are dirty and unacceptable. It is sad.	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
	Room is free of pests?			The floors are not clean everyday. They are dirty and unacceptable. It is sad.	Pests observed at the time of assessment.	Physical Plant Operation to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations 2
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?			The floors are not clean everyday. They are dirty and unacceptable. It is sad.	There appears to be a problem with spill clean up practices. To address all spills in a timely manner, all moisture effected materials must be dried within a 24-hour timeframe.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

116

Temp RH% CO2 Occupants:

THERMAL COMFORT

Classroom is free of significant temperature shifts?	It is extremely uncomfortable. We have a thermomether in our room and is NEVER over 65 degrees.	Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	It is extremely uncomfortable. We have a thermomether in our room and is NEVER over 65 degrees.	Humidity was slightly elevated at the time of assessment - 10% greater than outdoors.	Facilities serviceperson should monitor this room.	Site Based	3
Room is usually comfortable? (If no, please explain in the notes below.)	It is extremely uncomfortable. We have a thermomether in our room and is NEVER over 65 degrees.	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate need for test and balance.	Physical Plant Operations	2
Temperature in my classroom is generally comfortable (72F-76F)?	It is extremely uncomfortable. We have a thermomether in our room and is NEVER over 65 degrees.	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate need for test and balance.	Physical Plant Operations	2

Walkthrough

Ceiling grid on west wall rusted.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate. Change ceiling tiles.	Physical Plant Operations	1
	Remove household products.	Site Based	2

117

Temp RH% CO2 Occupants:

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	My floor needs to be waxed and cleaned. Folding walls are ripped and a hazard.	Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
Classroom is dusted/vacuumed thoroughly and regularly?	My floor needs to be waxed and cleaned. Folding walls are ripped and a hazard.	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Classrooms general appearance is clean and acceptable?	My floor needs to be waxed and cleaned. Folding walls are ripped and a hazard.	General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Floor is cleaned on a regular basis?	My floor needs to be waxed and cleaned. Folding walls are ripped and a hazard.	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
117	Temp	75.8	RH%	59.6	CO2	1003	Occupants:				
	Room is free of the use of scented cleaners and air fresheners?	My floor needs to be waxed and cleaned. Folding walls are ripped and a hazard.		Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based					1
	LOCAL EXHAUST FANS										
	Bathroom exhaust fan is functioning properly?			Bathroom exhaust fan is functioning properly.	None	None					
118	Temp	76.7	RH%	58.1	CO2	922	Occupants:	21			
	THERMAL COMFORT										
	Classroom is free of significant temperature shifts?	The classroom is always below temperature. It is very uncomfortable.		Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based					2
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	The classroom is always below temperature. It is very uncomfortable.		Humidity was slightly elevated at the time of assessment - less than 10% greater than outdoors. Humidity slightly exceeded target range, however indoor humidity was more than 10% lower than the outside reading which is evidence that the ventilation system	Facilities serviceperson should monitor this room.	Site Based					3
	Room is usually comfortable? (If no, please explain in the notes below.)	The classroom is always below temperature. It is very uncomfortable.		Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based					2
	Temperature in my classroom is generally comfortable (72F-76F)?	The classroom is always below temperature. It is very uncomfortable.		Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based					2
	Walkthrough										
				Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based					2
				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based					2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
118	Temp	<input type="text" value="76.7"/>	RH% <input type="text" value="58.1"/>	CO2 <input type="text" value="922"/>	Occupants: <input type="text" value="21"/>		
120	Temp	<input type="text" value="74.4"/>	RH% <input type="text" value="60.8"/>	CO2 <input type="text" value="886"/>	Occupants: <input type="text" value="2"/>		
AIR CONDITIONING							
Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None	None	
ANIMALS IN THE CLASSROOM							
You are informed about the potential allergies of your students?					None	None	
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None	None	
Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	None	
Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was acceptable.	None	None	
Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None	None	
Room is free of pests?				No pests observed at the time of assessment.	None	None	
THERMAL COMFORT							
Room is usually comfortable? (If no, please explain in the notes below.)		either very cold 65 or hot no air moving		Environmental parameters were within acceptable range at the time of assessment..	Physical Plant Operations to evaluate need for test and balance.	Physical Plant Operations	2
Walkthrough							
					Remove household products.	Site Based	2
120A	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
Walkthrough							
				Identify source of walls blistering.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	1
121	Temp	<input type="text" value="76.9"/>	RH% <input type="text" value="55.7"/>	CO2 <input type="text" value="1029"/>	Occupants: <input type="text" value="14"/>		
DRAIN TRAPS IN THE CLASSROOM							
If not regularly used, toilets flushed once each week.				It appears as though toilet is utilized regularly. No sewer gas odor detected. By flushing toilet regularly it eliminates the potential for sewer gas odors.	None	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
121	Temp	76.9	RH% 55.7	CO2 1029	Occupants: 14		
GENERAL CLEANLINESS							
Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None	None		
Room is free of pests?			No pests observed at the time of assessment.	None	None		
LOCAL EXHAUST FANS							
Other exhaust fans that may exist in the classroom are functioning properly?			Exhaust fan is functioning properly.	None	None		
Walkthrough							
			Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based		2
122	Temp	75.5	RH% 57.7	CO2 881	Occupants: 2		
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.	None	None		
Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None	None		
THERMAL COMFORT							
Classroom is free of significant temperature shifts?			The room temp. varies on a weekly basis from warm to very chilly.	Temperature was acceptable at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
Temperature in my classroom is generally comfortable (72F-76F)?			The room temp. varies on a weekly basis from warm to very chilly.	Temperature was acceptable at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
Walkthrough							
			Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations		1
				Remove pillows from lounge chairs.	Site Based		2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
123	Temp	76.8	RH% 55.3	CO2 1721	Occupants: 4		
GENERAL CLEANLINESS							
Floor is cleaned on a regular basis?	Planning area was NEVER cleaned over the summer and it had some nasty spills.....then after school started it was waxed over ..spills & all! often trash will be in same place for days before it has been cleaned up.			Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
THERMAL COMFORT							
Classroom is free of significant temperature shifts?	Can never get temp. right as it is always either too hot or too cold in the room.			Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Can never get temp. right as it is always either too hot or too cold in the room.			Humidity was slightly elevated at the time of assessment - less than 10% greater than outdoors. Humidity slightly exceeded target range, however indoor humidity was more than 10% lower than the outside reading which is evidence that the ventilation system	Facilities serviceperson should monitor this room.	Site Based	3
Room is usually comfortable? (If no, please explain in the notes below.)	Can never get temp. right as it is always either too hot or too cold in the room.			Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
Temperature in my classroom is generally comfortable (72F-76F)?	Can never get temp. right as it is always either too hot or too cold in the room.			Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2

124

Temp 74 RH% 62 CO2 934 Occupants:

GENERAL CLEANLINESS

Classroom is dusted/vacuumed thoroughly and regularly?

There does not appear to be a dusting issue within this room.

None

None

Floor is cleaned on a regular basis?

Dust and dirt accumulation on floor.

Site based administration should address general cleanliness with facility serviceperson staff.

Site Based

2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
124	Temp	74	RH%	62	CO2	934	Occupants:				
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?			No issues identified relating to spill clean up practices at the time of assessment..	None		None				
	THERMAL COMFORT										
	Classroom is free of significant temperature shifts?			The classroom temperatue changes dramatically throughout the day (from semi-warm to very cold).	Temperature was acceptable at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based				2
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)			The classroom temperatue changes dramatically throughout the day (from semi-warm to very cold).	Gaps in windows or doors identified at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations				2
	Temperature in my classroom is generally comfortable (72F-76F)?			The classroom temperatue changes dramatically throughout the day (from semi-warm to very cold).	Temperature was acceptable at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based				2
	Walkthrough										
						Remove household products.	Site Based				2
					Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations				1
125	Temp	75.3	RH%	60.5	CO2	844	Occupants:				
	GENERAL CLEANLINESS										
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		None			
	Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was acceptable.	None		None			
	Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based				2
	THERMAL COMFORT										
	Classroom is free of significant temperature shifts?				Temperature was acceptable at the time of assessment.	None		None			
	Room is usually comfortable? (If no, please explain in the notes below.)				Temperature was acceptable at the time of assessment.	None		None			

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
125	Temp	75.3	RH%	60.5	CO2	844	Occupants:				
	Temperature in my classroom is generally comfortable (72F-76F)?			Temperature was acceptable at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based					2
	Walkthrough			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based					2
				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based					2
126	Temp	76.9	RH%	57.6	CO2	961	Occupants:	9			
	AIR CONDITIONING										
	Room is free of smell of mold or mildew?			I cannot check airflow at return grille without climbing on top of the closet!	No odor detected at the time of assessment.	None					None
	ANIMALS IN THE CLASSROOM										
	Activities and/or room conditions are modified to address student allergies?										None
	EXCESS MOISTURE IN CLASSROOMS										
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks or signs of water intrusion identified.	None					None
	GENERAL CLEANLINESS										
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None					None
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None					None
	Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was acceptable.	None					None
	THERMAL COMFORT										

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
126	Temp	76.9	RH%	57.6	CO2	961	Occupants:	9			
	Classroom is free of significant temperature shifts?	Temperature makes wide swings in the course of a day. It is sometimes very cold, but at other times the air is oppressive and it seems stale and hard to breathe.			Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based				2
	Room is usually comfortable? (If no, please explain in the notes below.)	Temperature makes wide swings in the course of a day. It is sometimes very cold, but at other times the air is oppressive and it seems stale and hard to breathe.			Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate need for test and balance.	Physical Plant Operations				2
	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature makes wide swings in the course of a day. It is sometimes very cold, but at other times the air is oppressive and it seems stale and hard to breathe.			Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based				2
	Walkthrough				Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based				2
						Remove household products.	Site Based				1
					Air supply/return ventilation is not functioning qualitatively.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations				2
127	Temp	74.5	RH%	62.7	CO2	909	Occupants:				
	DRAIN TRAPS IN THE CLASSROOM										
	If not regularly used, toilets flushed once each week.	There is no toilet in this room. The sink is used everyday - there has been no problem with the flow of water.			No toilet in room.	None	None				
	Water poured down floor drains once per week (approx. 1 quart of water).	There is no toilet in this room. The sink is used everyday - there has been no problem with the flow of water.			It appears as though water is poured down the floor drain at least once a week.	None	None				
	THERMAL COMFORT										
	Classroom is free of significant temperature shifts?	Except for the occasional warmth, the room is usually very cold. The students are asked to wear their sweaters and jackets, but they still complain about the cold.			Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based				2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
127	Temp	74.5	RH%	62.7	CO2	909	Occupants:				
	Room is usually comfortable? (If no, please explain in the notes below.)	Except for the occasional warmth, the room is usually very cold. The students are asked to wear their sweaters and jackets, but they still complain about the cold.			Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Physical Plant Operations to evaluate need for test and balance.	Physical Plant Operations				2
	Temperature in my classroom is generally comfortable (72F-76F)?	Except for the occasional warmth, the room is usually very cold. The students are asked to wear their sweaters and jackets, but they still complain about the cold.			Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based				2
	Walkthrough				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based				2
					Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based				2
127A	Temp	73.8	RH%	62.9	CO2	902	Occupants:	2			
	GENERAL CLEANLINESS										
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None	None				
128	Temp	75.2	RH%	59.2	CO2	1123	Occupants:	3			
	AIR CONDITIONING										
	Room is free of smell of kitchen/food?				No odor detected at the time of assessment.	None	None				
	Windows/doors are operable and are kept closed?				Windows and doors are operable and are kept closed.	None	None				
	EXCESS MOISTURE IN CLASSROOMS										
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks or signs of water intrusion identified.	None	None				
	GENERAL CLEANLINESS										
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None	None				
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	None				

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
128	Temp	75.2	RH% 59.2	CO2 1123	Occupants: 3		
	Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?				No issues identified relating to spill clean up practices at the time of assessment..	None	None
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?		rooms have become comfortable w/in the past semester. previous to that, rooms were frequently uncomfortable because of temperature. the new assistant administrator has made the difference.		Temperature was acceptable at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based 2
	Room is usually comfortable? (If no, please explain in the notes below.)		rooms have become comfortable w/in the past semester. previous to that, rooms were frequently uncomfortable because of temperature. the new assistant administrator has made the difference.		Environmental parameters were within acceptable range at the time of assessment..	Physical Plant Operations to evaluate need for test and balance.	Physical Plant Operations 1
129	Temp	78.3	RH% 49.6	CO2 992	Occupants: 2		
	GENERAL CLEANLINESS						
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None	None
	Walkthrough						
					Dust and debris on ceiling tiles.	Facilities serviceperson to replace soiled ceiling tiles.	Site Based 2
						Remove pillows and throws from chairs and wash.	Site Based 2
130	Temp	75.1	RH% 59.7	CO2 1125	Occupants: 22		
	ANIMALS IN THE CLASSROOM						
	Activities and/or room conditions are modified to address student allergies?					None	None
	You are informed about the potential allergies of your students?					None	None
	GENERAL CLEANLINESS						

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
130	Temp	75.1	RH% 59.7	CO2 1125	Occupants: 22			
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	i.)generally Floors are swepted regularly though there are times we are short of custodians and it is not swept. The floor is not cleaned (mopped) regularly			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?	i.)generally Floors are swepted regularly though there are times we are short of custodians and it is not swept. The floor is not cleaned (mopped) regularly			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?	i.)generally Floors are swepted regularly though there are times we are short of custodians and it is not swept. The floor is not cleaned (mopped) regularly			Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	LOCAL EXHAUST FANS							
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)				It appears that the ventilation system is adequate based on room activities.	None	None	
	Walkthrough							
					Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
						Remove household products	Site Based	2
132	Temp		RH%	CO2	Occupants:			
	AIR CONDITIONING							
	Room is free of smell of kitchen/food?	This is the cafeteria; therefore, the smell of food is common.				Facilities serviceperson to evaluate cause of odor and inspect exhaust fans/fume hoods for proper operation.	Site Based	2
	Walkthrough							
					Dust and debris on ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
					Dust and dirt accumulation on floor.	Floors need to be stripped and waxed.	Site Based	2
					Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Physical Plant Operations	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
133	Temp	76.4	RH% 58.5	CO2 729	Occupants:			
AIR CONDITIONING								
	Room is free of smell of kitchen/food?	This is the kitchen; therefore, kitchen/food smells are commonplace.			No odor detected at the time of assessment.	None	None	
187	Temp	82.3	RH% 35.8	CO2 567	Occupants:			
AIR CONDITIONING								
	Air flowing from air supply?				Air flowing without obstruction at the time of assessments.	None	None	
	Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None	None	
ANIMALS IN THE CLASSROOM								
	Activities and/or room conditions are modified to address student allergies?					None	None	
	Classroom is free of animals and pets?				No pests observed at the time of assessment.	None	None	
GENERAL CLEANLINESS								
	Classroom is dusted/vacuumed thoroughly and regularly?	floors have not been moped this year.			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classrooms general appearance is clean and acceptable?	floors have not been moped this year.			General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?	floors have not been moped this year.			Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Room is free of pests?	floors have not been moped this year.			Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	2
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?	floors have not been moped this year.			There appears to be a problem with spill clean up practices. To address all spills in a timely manner, all moisture effected materials must be dried within a 24-hour timeframe.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Trash is removed daily and trash bags are changed as appropriate?	floors have not been moped this year.			There appears to be an issue regarding daily trash removal practices.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Walkthrough								
					Signs of water intrusion. Leak identified.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
187	Temp	82.3	RH% 35.8	CO2 567	Occupants: <input type="text"/>	Floor needs to be stripped and waxed.	Site Based 2
201	Temp	74.6	RH% 54.9	CO2 866	Occupants: <input type="text"/>		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?		I am not notified of any special needs, unless there are needs to be met. If so, then conditions will be modified as required.			None	None	
You are informed about the potential allergies of your students?		I am not notified of any special needs, unless there are needs to be met. If so, then conditions will be modified as required.			None	None	
Walkthrough							
					Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
						Repair wall beside door, check to see if wall is still leaking.	Physical Plant Operations 1
202	Temp	74.7	RH% 47.8	CO2 697	Occupants: <input type="text" value="2"/>		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?					There does not appear to be a dusting issue within this room.	None	None
Floor is cleaned on a regular basis?					Floor was clean at the time of assessment.	None	None
202A	Temp	74.6	RH% 51.1	CO2 638	Occupants: <input type="text"/>		
EXCESS MOISTURE IN CLASSROOMS							
Indoor surfaces of exterior walls free of continuous condensation?					No visible condensation or signs of water intrusion identified at the time of assessment.	None	None
Windows, windowsills and window frames free of continuous condensation?					No condensation on windows at the time of assessment.	None	None
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?					No dust observed on supply/return registers at the time of assessment.	None	None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
202B	Temp	73.3	RH% 53.3	CO2 683	Occupants:		
AIR CONDITIONING							
Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None	None		
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks or signs of water intrusion identified.	None	None		
Indoor surfaces of exterior walls free of continuous condensation?			No visible condensation at the time of assessment. Signs of previous water intrusion as evidenced by stains on walls.	None	None		
LOCAL EXHAUST FANS							
Bathroom exhaust fan is functioning properly?			Exhaust fan is functioning properly.	None	None		
Other exhaust fans that may exist in the classroom are functioning properly?			Exhaust fan is functioning properly.	None	None		
Walkthrough							
			Dust observed on ceiling tiles around supply/return registers at the time of assessment.	Facilities serviceperson to replace soiled ceiling tiles.	Site Based		2
204	Temp	75.7	RH% 49.2	CO2 739	Occupants:	23	
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?			There are ants and palmetto bugs.	There does not appear to be a dusting issue within this room.	None	None	
Room is free of pests?			There are ants and palmetto bugs.	No pests observed at the time of assessment.	None	None	
Walkthrough							
				Remove household cleaning products.	Site Based		2
205	Temp	70.4	RH% 57.8	CO2 663	Occupants:		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?					None	None	
You are informed about the potential allergies of your students?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based		3

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
205	Temp	70.4	RH% 57.8	CO2 663	Occupants:		
EXCESS MOISTURE IN CLASSROOMS							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Dust and debris on ceiling tiles around supply air grill..	Facilities serviceperson to replace soiled ceiling tiles.	Physical Plant Operations	2
	Indoor surfaces of exterior walls free of continuous condensation?			No condensation on windows at the time of assessment.	None	None	
	Windows, windowsills and window frames free of continuous condensation?			No condensation on windows at the time of assessment.	None	None	
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on ceiling tiles around supply/return registers at the time of assessment.	Facilities serviceperson to replace soiled ceiling tiles.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None	None	
	Classrooms general appearance is clean and acceptable?			General cleanliness of the room at the time of assessment was acceptable.	None	None	
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None	None	
	Room is free of pests?			No pests observed at the time of assessment.	None	None	
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?			Bathroom exhaust fan is functioning properly.	None	None	
	Other exhaust fans that may exist in the classroom are functioning properly?			Exhaust fan is functioning properly.	None	None	
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?		Very cold daily	Temperature was low at the time of assessment.	None	None	
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		Very cold daily	Humidity was acceptable at the time of assessment.	None	None	
	Room is usually comfortable? (If no, please explain in the notes below.)		Very cold daily	Temperature was low at the time of assessment.	None	None	
	Temperature in my classroom is generally comfortable (72F-76F)?		Very cold daily	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

206

Temp RH% CO2 Occupants:

AIR CONDITIONING

Room is free of smell of mold or mildew?	Mold and mildew smell is very prevalent when air conditioner is not on. Is the cold of the air conditioner masking the mold and mildew???	Odor detected at the time of assessment.	Physical Plant Operations to evaluate cause of odor.	Physical Plant Operations	2
--	---	--	--	---------------------------	---

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	There are ants and roaches, mice droppings and possible termite dust by the windows.	Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Classroom is dusted/vacuumed thoroughly and regularly?	There are ants and roaches, mice droppings and possible termite dust by the windows.	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Room is free of pests?	There are ants and roaches, mice droppings and possible termite dust by the windows.	Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	2

Walkthrough

Lens covers full of dead bugs.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Signs of water intrusion in wall.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
Remove household products.	Site Based	2	
Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
Bathroom exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
Possible water intrusion at windows.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	1

207

Temp RH% CO2 Occupants:

GENERAL CLEANLINESS

Classroom is dusted/vacuumed thoroughly and regularly?	No dust observed on supply/return registers at the time of assessment.	None	None
Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.	None	None
Room is free of pests?	Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations 2

Walkthrough

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
207	Temp	<input type="text" value="72"/>	RH% <input type="text" value="52.6"/>	CO2 <input type="text" value="865"/>	Occupants: <input type="text" value="22"/>		
				Carpet was stained, bubbling and torn.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	2
				Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	2
				Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations	1
248	Temp	<input type="text" value="80.0"/>	RH% <input type="text" value="58.0"/>	CO2 <input type="text" value="503"/>	Occupants: <input type="text"/>		
AIR CONDITIONING							
				Room is free of smell of mold or mildew?	No odor detected at the time of assessment.	None	None
ANIMALS IN THE CLASSROOM							
				Activities and/or room conditions are modified to address student allergies?		None	None
ART SUPPLIES							
				Industrial supplies okay?	No industrial supplies in room. Room not being used as an industrial room.	None	None
GENERAL CLEANLINESS							
				Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room.	None	None
				Food, if any, is stored in tightly sealed containers?	No unsealed food items were observed at the time of assessment.	None	None
				Room is free of pests?	No pests observed at the time of assessment.	None	None
				Trash is removed daily and trash bags are changed as appropriate?	No issues identified regarding trash removal practices.	None	None
LOCAL EXHAUST FANS							
				Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)		None	None
				My classroom has sufficient exhaust systems based on the activities/functionality of the room?	No exhaust system/ventilation in room. Identified in error.	None	None
THERMAL COMFORT							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
248	Temp	<input type="text" value="80.0"/>	RH% <input type="text" value="58.0"/>	CO2 <input type="text" value="503"/>	Occupants: <input type="text"/>		
	Classroom is free of significant temperature shifts?			Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Room is usually comfortable? (If no, please explain in the notes below.)			Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Walkthrough			Floor has soft spot.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	1
401	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
	GENERAL CLEANLINESS						
	Floor is cleaned on a regular basis?			Storage shed.	Floor was clean at the time of assessment.	None	None
501	Temp	<input type="text" value="73.2"/>	RH% <input type="text" value="59.0"/>	CO2 <input type="text" value="1422"/>	Occupants: <input type="text" value="2"/>		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None	None	None
	EXCESS MOISTURE IN CLASSROOMS						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks or signs of water intrusion identified.	None	None	None
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None	None	None
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None	None	None
	Room is free of pests?			No pests observed at the time of assessment.	None	None	None
	THERMAL COMFORT						

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
501	Temp	73.2	RH% 59.0	CO2 1422	Occupants: 2		
	Classroom is free of significant temperature shifts?		very cold at times	Temperature was acceptable at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Room is usually comfortable? (If no, please explain in the notes below.)		very cold at times	Temperature was acceptable at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Temperature in my classroom is generally comfortable (72F-76F)?		very cold at times	Temperature was acceptable at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Walkthrough			Carpet was stained and torn.	Facilities serviceperson to replace stained carpet.	Physical Plant Operations	2
				Signs of water intrusion at windows. Leak identified.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	1
				Evaluate A/C system to lower CO2 level.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	1
502	Temp	73.7	RH% 69.5	CO2 642	Occupants: 17		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None	None	
	ANIMALS IN THE CLASSROOM						
	Activities and/or room conditions are modified to address student allergies?				None	None	
	EXCESS MOISTURE IN CLASSROOMS						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks or signs of water intrusion identified.	None	None	
	GENERAL CLEANLINESS						

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
502	Temp	73.7	RH% 69.5	CO2 642	Occupants: 17		
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	None
	LOCAL EXHAUST FANS						
	Bathroom exhaust fan is functioning properly?				Bathroom exhaust fan is functioning properly.	None	None
	Other exhaust fans that may exist in the classroom are functioning properly?				Exhaust fan is not functioning properly.	None	None
504	Temp	71.9	RH% 67.1	CO2 559	Occupants:		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None	None
	EXCESS MOISTURE IN CLASSROOMS						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations 1
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	None
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None	None
	Room is free of pests?				No pests observed at the time of assessment.	None	None
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?				No issues identified relating to spill clean up practices at the time of assessment..	None	None
	LOCAL EXHAUST FANS						
	Bathroom exhaust fan is functioning properly?				Bathroom exhaust fan is functioning properly.	None	None
	Other exhaust fans that may exist in the classroom are functioning properly?				Exhaust fan is functioning properly.	None	None
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?		Sometimes too cold or too hot.		Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based 2
	Room is usually comfortable? (If no, please explain in the notes below.)		Sometimes too cold or too hot.		Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate need for test and balance.	Physical Plant Operations 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
504	Temp	71.9	RH% 67.1	CO2 559	Occupants:		
	Temperature in my classroom is generally comfortable (72F-76F)?	Sometimes too cold or too hot.		Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Walkthrough			Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations	1
				Install supply air grill.	Physical Plant Operations to initiate work order to install supply air grill.	Physical Plant Operations	1
505	Temp	76.3	RH% 57.7	CO2 895	Occupants:	19	
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None	None	
	EXCESS MOISTURE IN CLASSROOMS						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks or signs of water intrusion identified.	None	None	
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None	None	
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None	None	
	Room is free of pests?			No pests observed at the time of assessment.	None	None	
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?			No issues identified relating to spill clean up practices at the time of assessment..	None	None	
	LOCAL EXHAUST FANS						
	Bathroom exhaust fan is functioning properly?			Bathroom exhaust fan is functioning properly.	None	None	
	Other exhaust fans that may exist in the classroom are functioning properly?			Exhaust fan is functioning properly.	None	None	
	THERMAL COMFORT						

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
505	Temp	76.3	RH%	57.7	CO2	895	Occupants:	19			
	Classroom is free of significant temperature shifts?	Sometimes too cold or too hot.			Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based				2
	Room is usually comfortable? (If no, please explain in the notes below.)	Sometimes too cold or too hot.			Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate need for test and balance.	Physical Plant Operations				2
	Temperature in my classroom is generally comfortable (72F-76F)?	Sometimes too cold or too hot.			Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based				2
	Walkthrough				Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based				2
					Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations				1
508	Temp		RH%		CO2		Occupants:				
	GENERAL CLEANLINESS										
	Classroom is dusted/vacuumed thoroughly and regularly?	This is a Pe office/store room			There does not appear to be a dusting issue within this room.	None	None				
	THERMAL COMFORT										
	Room is usually comfortable? (If no, please explain in the notes below.)					None	None				
	Walkthrough				Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations				1
670C	Temp	76.6	RH%	44.0	CO2	1327	Occupants:	2			
	AIR CONDITIONING										
	Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None	None				
	ANIMALS IN THE CLASSROOM										

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
670C	Temp	76.6	RH% 44.0	CO2 1327	Occupants:	2	
	Activities and/or room conditions are modified to address student allergies?					None	None
	You are informed about the potential allergies of your students?					None	None
	EXCESS MOISTURE IN CLASSROOMS						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks or signs of water intrusion identified.	None	None
	Indoor surfaces of exterior walls free of continuous condensation?				No visible condensation or signs of water intrusion identified at the time of assessment.	None	None
	Windows, windowsills and window frames free of continuous condensation?				No condensation on windows at the time of assessment.	None	None
671C	Temp	79.6	RH% 38.7	CO2 1747	Occupants:	2	
	AIR CONDITIONING						
	Windows/doors are operable and are kept closed?				Windows and doors are operable and are kept closed.	None	None
	ANIMALS IN THE CLASSROOM						
	Activities and/or room conditions are modified to address student allergies?					None	None
	EXCESS MOISTURE IN CLASSROOMS						
	Indoor surfaces of exterior walls free of continuous condensation?				No visible condensation or signs of water intrusion identified at the time of assessment.	None	None
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	None
	Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was acceptable.	None	None
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None	None
	Room is free of pests?				Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations 2
	Trash is removed daily and trash bags are changed as appropriate?				No issues identified regarding trash removal practices.	None	None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
751	Temp	73.8	RH% 55.1	CO2 630	Occupants: 2		
ART SUPPLIES							
Industrial supplies okay?					No industrial supplies in room. Room not being used as an industrial room.	None	None
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?					There does not appear to be a dusting issue within this room.	None	None
Floor is cleaned on a regular basis?					Floor was clean at the time of assessment.	None	None
THERMAL COMFORT							
Classroom is free of significant temperature shifts?					Temperature was acceptable at the time of assessment.	None	None
Walkthrough							
					Animals were identified at the time of assessment. Animal/pet dander is a major allergen source that could impact occupant allergies.	Remove live rabbit from classroom.	Site Based 2
754	Temp	76	RH% 56.6	CO2 732	Occupants: 23		
ANIMALS IN THE CLASSROOM							
You are informed about the potential allergies of your students?						Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
DRAIN TRAPS IN THE CLASSROOM							
If not regularly used, toilets flushed once each week.					It appears as though toilet is utilized regularly. No sewer gas odor detected. By flushing toilet regularly it eliminates the potential for sewer gas odors.	None	None
Water run in sinks at least once per week (about 2 cups of water).					It appears as though water is poured down the floor drain at least once a week.	None	None
Walkthrough							
					Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
					Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
754	Temp	76	RH% 56.6	CO2 732	Occupants: 23		
				Signs of water intrusion.		Repair wall on sink counter due to water intrusion.	Physical Plant Operations 2
				Leak identified.		Tighten gooseneck faucet to sink to stop leak.	Site Based 2
757	Temp	75.1	RH% 56.9	CO2 627	Occupants: 2		
	EXCESS MOISTURE IN CLASSROOMS						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	My walls near the windows have dark spots.		Signs of water intrusion, stains on walls..		Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations 1
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.		None	None
	Walkthrough						
				Pests observed at the time of assessment.		Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations 2
				Dust and dirt accumulation on floor.		Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
759	Temp	70.8	RH% 56.7	CO2 632	Occupants: 2		
	EXCESS MOISTURE IN CLASSROOMS						
	Cold water pipes free of continuous condensation?			No condensation on pipes at the time of assessment.		None	None
	Indoor surfaces of exterior walls free of continuous condensation?			No condensation on walls at the time of assessment.		None	None
	Windows, windowsills and window frames free of continuous condensation?			No condensation on windows at the time of assessment.		None	None
	Walkthrough						
				Signs of water intrusion.		Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations 1
				Pests observed at the time of assessment.		Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
926C	Temp	<input type="text" value="80.4"/>	RH% <input type="text" value="32.7"/>	CO2 <input type="text" value="1507"/>	Occupants: <input type="text" value="2"/>		
	ANIMALS IN THE CLASSROOM						
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	None
	Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was acceptable.	None	None
	Walkthrough						
					Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations 2
					South wall a/c unit not working.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations 2
Hallway	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
	Walkthrough						
					Dust and dirt accumulation on floor. Strip and wax floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
					Ceiling tiles broken, damaged or missing.	Facilities serviceperson to replace damaged ceiling tiles.	Site Based 2
					Condensation on windows at the time of assessment. Temperature was not within acceptable range and no leaks were identified.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations 1
R13B	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
	Walkthrough						
					Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
<i>R14A</i>	Temp	83.2	RH% 49.5	CO2 752	Occupants:	19	
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?					There does not appear to be a dusting issue within this room.	None	None
Floor is cleaned on a regular basis?					Floor was clean at the time of assessment.	None	None
Walkthrough							
					Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
					Signs of water intrusion.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations 1
					Ceiling tiles broken, damaged or missing.	Facilities serviceperson to replace damaged ceiling tiles.	Site Based 2
<i>R14B</i>	Temp	81.3	RH% 49.6	CO2 647	Occupants:		
AIR CONDITIONING							
Room is free of smell of mold or mildew?					No odor detected at the time of assessment.	None	None
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?					Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations 1
Indoor surfaces of exterior walls free of continuous condensation?					No condensation on walls at the time of assessment.	None	None
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?					There does not appear to be a dusting issue within this room.	None	None
Floor is cleaned on a regular basis?					Dust and dirt accumulation on floor.	Floors need to be stripped and waxed.	Site Based 2
Room is free of pests?					No pests observed at the time of assessment.	None	None
Spills and other such issues requiring custodial assistance are addressed in a timely manner?					There appears to be a problem with spill clean up practices. To address all spills in a timely manner, all moisture effected materials must be dried within a 24-hour timeframe.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
Walkthrough							
					Ceiling tiles broken, damaged or missing.	Facilities serviceperson to replace damaged ceiling tiles.	Site Based 2