

# Maplewood Elementary

## IAQ Walkthrough 3/15/2005

2741

Outside Temp  RH%  CO2

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
016P	Temp <input type="text"/> RH% <input type="text"/> CO2 <input type="text"/>	Occupants: <input type="text"/>			
	GENERAL CLEANLINESS Classroom is dusted/vacuumed thoroughly and regularly? Classrooms general appearance is clean and acceptable? Floor is cleaned on a regular basis?				
101	Temp <input type="text" value="73.6"/> RH% <input type="text" value="62.7"/> CO2 <input type="text" value="926"/>	Occupants: <input type="text"/>			
	ANIMALS IN THE CLASSROOM Activities and/or room conditions are modified to address student allergies?	Front Office - issue is not applicable.	None		
	THERMAL COMFORT Classroom is free of significant temperature shifts?	The temperature in the classroom / office varies, some days temperatures are in the normal range and by the middle of the day they get colder. Other days the temperatures are way too cold in which we have to wear several layers of clothing. Some class ro	Temperature was acceptable at the time of assessment.	None	
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	The temperature in the classroom / office varies, some days temperatures are in the normal range and by the middle of the day they get colder. Other days the temperatures are way too cold in which we have to wear several layers of clothing. Some class ro	Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations 2
	Room is usually comfortable? (If no, please explain in the notes below.)	The temperature in the classroom / office varies, some days temperatures are in the normal range and by the middle of the day they get colder. Other days the temperatures are way too cold in which we have to wear several layers of clothing. Some class ro	Temperature was acceptable at the time of assessment.	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
<b>101</b>	<b>Temp</b> <input type="text" value="73.6"/>	<b>RH%</b> <input type="text" value="62.7"/>	<b>CO2</b> <input type="text" value="926"/>	<b>Occupants:</b> <input type="text"/>			
Temperature in my classroom is generally comfortable (72F-76F)?	The temperature in the classroom / office varies, some days temperatures are in the normal range and by the middle of the day they get colder. Other days the temperatures are way too cold in which we have to wear several layers of clothing. Some class ro			Temperature was acceptable at the time of assessment.	None		
<b>101D</b>	<b>Temp</b> <input type="text" value="74.8"/>	<b>RH%</b> <input type="text" value="61.8"/>	<b>CO2</b> <input type="text" value="993"/>	<b>Occupants:</b> <input type="text"/>			
<b>EXCESS MOISTURE IN CLASSROOMS</b>							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Ceiling tiles and exterior wall discolored. Identified gaps around ceiling tiles.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
<b>THERMAL COMFORT</b>							
Classroom is free of significant temperature shifts?				Temperature was acceptable at the time of assessment.	None		
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)				Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
Room is usually comfortable? (If no, please explain in the notes below.)				Temperature was acceptable at the time of assessment.	None		
Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was acceptable at the time of assessment.	None		
<b>101J</b>	<b>Temp</b> <input type="text" value="73.7"/>	<b>RH%</b> <input type="text" value="67.4"/>	<b>CO2</b> <input type="text" value="966"/>	<b>Occupants:</b> <input type="text"/>			
<b>GENERAL CLEANLINESS</b>							
Floor is cleaned on a regular basis?				Floor was clean at the time of assessment. Slight staining from age.	None		
<b>THERMAL COMFORT</b>							
Room is usually comfortable? (If no, please explain in the notes below.)	Too cold!!!!!!			Temperature was acceptable at the time of assessment.	None		
Temperature in my classroom is generally comfortable (72F-76F)?	Too cold!!!!!!			Temperature was acceptable at the time of assessment.	None		
<b>Walkthrough</b>							
				Visible staining on north false ceiling grate.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
-----------	----------------------	----------	----------------	-------------	----------

110

Temp  RH%  CO2  Occupants:

**AIR CONDITIONING**

Room is free of smell of chemicals?	No odor detected at the time of assessment.	None
Room is free of smell of kitchen/food?	No odor detected at the time of assessment.	None
Room is free of smell of mold or mildew?	No odor detected at the time of assessment.	None
Room is free of smell of vehicle exhaust?	No odor detected at the time of assessment.	None

**ANIMALS IN THE CLASSROOM**

Activities and/or room conditions are modified to address student allergies?		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
--	--	--	------------	---

**EXCESS MOISTURE IN CLASSROOMS**

Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	discolored ceiling tile	Ceiling tiles stained and bulging.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
--	-------------------------	------------------------------------	--	------------	---

**GENERAL CLEANLINESS**

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Room has spot on ceiling, previous leak, room is musty smelling and cold	No dust observed on supply/return registers at the time of assessment.	None		
Classroom is dusted/vacuumed thoroughly and regularly?	Room has spot on ceiling, previous leak, room is musty smelling and cold	General cleanliness of the room at the time of assessment was acceptable.	None		
Classrooms general appearance is clean and acceptable?	Room has spot on ceiling, previous leak, room is musty smelling and cold	General cleanliness of the room at the time of assessment was acceptable.	None		
Floor is cleaned on a regular basis?	Room has spot on ceiling, previous leak, room is musty smelling and cold	Floor is stained/worn in various areas..	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
Room is free of pests?	Room has spot on ceiling, previous leak, room is musty smelling and cold	No pests observed at the time of assessment.	None		

**LOCAL EXHAUST FANS**

Bathroom exhaust fan is functioning properly?	no exhaust fans are in this room	No bathroom. Identified in error.	None		
My classroom has sufficient exhaust systems based on the activities/functionality of the room?	no exhaust fans are in this room	No exhaust fans in room. Identified in error.	None		
Other exhaust fans that may exist in the classroom are functioning properly?	no exhaust fans are in this room	No exhaust fans in room. Identified in error.	None		

**THERMAL COMFORT**

Classroom is free of significant temperature shifts?		Temperature was acceptable at the time of assessment.	None		
--	--	---	------	--	--

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority	
110	<p>Temp <input type="text"/> RH% <input type="text"/> CO2 <input type="text"/></p> <p>Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)</p> <p>Room is usually comfortable? (If no, please explain in the notes below.)</p> <p>Temperature in my classroom is generally comfortable (72F-76F)?</p>	<p>Occupants: <input type="text"/></p> <p>Humidity was slightly elevated at the time of assessment.</p> <p>Temperature was acceptable at the time of assessment.</p> <p>Temperature was acceptable at the time of assessment.</p>	<p>Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.</p> <p>None</p> <p>None</p>	Physical Plant Operations	2	
112	<p>Temp <input type="text"/> RH% <input type="text"/> CO2 <input type="text"/></p> <p><b>LOCAL EXHAUST FANS</b></p> <p>Bathroom exhaust fan is functioning properly?</p> <p>Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)</p> <p>Other exhaust fans that may exist in the classroom are functioning properly?</p> <p><b>THERMAL COMFORT</b></p> <p>Room is usually comfortable? (If no, please explain in the notes below.)</p> <p>Temperature in my classroom is generally comfortable (72F-76F)?</p>	<p>This is an office space and does not have an exhaust fan.</p> <p>This is an office space and does not have an exhaust fan.</p> <p>This is an office space and does not have an exhaust fan.</p> <p>Sometimes it is very hot and stuffy.</p> <p>Sometimes it is very hot and stuffy.</p>	<p>No bathroom. Identified in error.</p> <p>This is an office.</p> <p>No exhaust fans in room. Identified in error.</p> <p>Temperature was acceptable at the time of assessment.</p> <p>Temperature was acceptable at the time of assessment.</p>	<p>None</p> <p>None</p> <p>None</p> <p>None</p> <p>Facilities serviceperson should monitor this room.</p>	Site Based	3
114	<p>Temp <input type="text"/> RH% <input type="text"/> CO2 <input type="text"/></p> <p><b>ANIMALS IN THE CLASSROOM</b></p> <p>Activities and/or room conditions are modified to address student allergies?</p> <p>You are informed about the potential allergies of your students?</p> <p><b>Walkthrough</b></p>	<p>No issues identified at the time of assessment.</p> <p>Several stained ceiling tiles.</p>	<p>None</p> <p>Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.</p> <p>Facilities serviceperson to replace stained ceiling tiles.</p>	Site Based	3	
				Site Based	2	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

115

Temp  RH%  CO2

Occupants:

**EXCESS MOISTURE IN CLASSROOMS**

Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?

Dust observed on ceiling tiles at supply register at the time of assessment.

Facilities serviceperson to clean ceiling tiles.

Site Based

2

**THERMAL COMFORT**

Classroom is free of significant temperature shifts?

Temperature was acceptable at the time of assessment.

None

Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)

Humidity was slightly elevated at the time of assessment.

Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.

Physical Plant Operations

2

Room is usually comfortable? (If no, please explain in the notes below.)

Temperature was acceptable at the time of assessment.

None

Temperature in my classroom is generally comfortable (72F-76F)?

Temperature was acceptable at the time of assessment.

None

115A

Temp  RH%  CO2

Occupants:

**AIR CONDITIONING**

Room is free of smell of mold or mildew?

No odor detected at the time of assessment.

None

**EXCESS MOISTURE IN CLASSROOMS**

Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?

Stained ceiling tiles.

Facilities serviceperson to replace stained ceiling tiles.

Site Based

2

**THERMAL COMFORT**

Classroom is free of significant temperature shifts?

Very cold

Environmental parameters were not within acceptable range at the time of assessment..

Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Site Based

2

Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)

Very cold

Humidity was slightly elevated at the time of assessment.

Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.

Physical Plant Operations

2

Room is usually comfortable? (If no, please explain in the notes below.)

Very cold

Environmental parameters were not within acceptable range at the time of assessment..

See previous item for recommendation.

Temperature in my classroom is generally comfortable (72F-76F)?

Very cold

Environmental parameters were not within acceptable range at the time of assessment..

See previous item for recommendation.

Walkthrough

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
115A	Temp	71.6	RH% 66	CO2 980	Occupants: <input type="text"/>		
				Floor tile has several areas where glue is coming through.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
115B	Temp	76.2	RH% 59.7	CO2 912	Occupants: <input type="text"/>		
<b>AIR CONDITIONING</b>							
	Air flowing from air supply?			One supply and no return.	Physical Plant operations to evaluate adding additional supply and return grills.	Physical Plant Operations	2
	Air is flowing without obstruction?			Smoke testing confirmed that air supply/return ventilation is functioning qualitatively.	None		
<b>ANIMALS IN THE CLASSROOM</b>							
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
<b>GENERAL CLEANLINESS</b>							
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None		
<b>LOCAL EXHAUST FANS</b>							
	Bathroom exhaust fan is functioning properly?	No exhaust fans		No bathroom. Identified in error.	None		
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?	No exhaust fans		No exhaust fans in room. Identified in error.	None		
	Other exhaust fans that may exist in the classroom are functioning properly?	No exhaust fans		No exhaust fans in room. Identified in error.	None		
<b>THERMAL COMFORT</b>							
	Room is usually comfortable? (If no, please explain in the notes below.)	The room is uncomfortably hot.		Temperature was acceptable at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based	2
	Temperature in my classroom is generally comfortable (72F-76F)?	The room is uncomfortably hot.		Room serves as network hub which is apparent cause of warm conditions.	Facilities serviceperson should monitor this room.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
115B	Temp	<input type="text" value="76.2"/>	RH% <input type="text" value="59.7"/>	CO2 <input type="text" value="912"/>	Occupants: <input type="text"/>		
116	Temp	<input type="text" value="73.2"/>	RH% <input type="text" value="62.2"/>	CO2 <input type="text" value="747"/>	Occupants: <input type="text"/>		
<b>AIR CONDITIONING</b>							
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None		3
<b>ANIMALS IN THE CLASSROOM</b>							
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
<b>EXCESS MOISTURE IN CLASSROOMS</b>							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Several stained ceiling tiles. Ceiling tiles appear bowed and have heavy dust impaction.	Facilities serviceperson to replace stained and damaged ceiling tiles.	Site Based	2
<b>THERMAL COMFORT</b>							
	Classroom is free of significant temperature shifts?		Room is very cold.	Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based	2
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		Room is very cold.	Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)		Room is very cold.	No issues identified at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)		Room is very cold.	Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?		Room is very cold.	Temperature was acceptable at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

117

Temp  RH%  CO2  Occupants:

**ANIMALS IN THE CLASSROOM**

Activities and/or room conditions are modified to address student allergies?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

**LOCAL EXHAUST FANS**

Bathroom exhaust fan is functioning properly?

117 has no bathroom or exhaust fans...Questions had to be answered in order to continue survey.

No bathroom. Identified in error.

None

My classroom has sufficient exhaust systems based on the activities/functionality of the room?

117 has no bathroom or exhaust fans...Questions had to be answered in order to continue survey.

No exhaust fans in room. Identified in error.

None

Other exhaust fans that may exist in the classroom are functioning properly?

117 has no bathroom or exhaust fans...Questions had to be answered in order to continue survey.

No exhaust fans in room. Identified in error.

None

**Walkthrough**

Ceiling tiles appear bowed and have heavy dust impaction.

Facilities serviceperson to replace damaged ceiling tiles.

Site Based

2

No signs of water intrusion under sink. Area under sink needs to be cleaned.

Site based administration should address general cleanliness with facility serviceperson staff.

Site Based

2

Two supply registers are missing covers and there is tape on the supply vent.

Physical Plant Operations to evaluate and repair/replace as appropriate.

Physical Plant Operations

2

118

Temp  RH%  CO2  Occupants:

**ANIMALS IN THE CLASSROOM**

Activities and/or room conditions are modified to address student allergies?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

**EXCESS MOISTURE IN CLASSROOMS**

Area around and under classroom sinks free of leaks?

No signs of water intrusion under sink. Area under sink needs to be cleaned.

Site based administration should address general cleanliness with facility serviceperson staff.

Site Based

2

**GENERAL CLEANLINESS**

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

Two supply registers missing covers and tape on supply vent.

Physical Plant Operations to evaluate and repair/replace as appropriate.

Physical Plant Operations

2



FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
<b>118</b>	Temp	<input type="text" value="73.4"/>	RH% <input type="text" value="63"/>	CO2 <input type="text" value="803"/>	Occupants: <input type="text"/>		
<b>LOCAL EXHAUST FANS</b>							
Bathroom exhaust fan is functioning properly?	I do not have a bathroom in my classroom, but had to give a response in order to continue with the survey..Also the exhaust is not in the Main Room 118, but in the Kiln Room 118A			No bathroom. Identified in error.	None		
My classroom has sufficient exhaust systems based on the activities/functionality of the room?	I do not have a bathroom in my classroom, but had to give a response in order to continue with the survey..Also the exhaust is not in the Main Room 118, but in the Kiln Room 118A			No exhaust fans in room. Identified in error.	None		
Other exhaust fans that may exist in the classroom are functioning properly?	I do not have a bathroom in my classroom, but had to give a response in order to continue with the survey..Also the exhaust is not in the Main Room 118, but in the Kiln Room 118A			No exhaust fans in room. Identified in error.	None		
<b>Walkthrough</b>							
				Floor tile is dirty and discolored in various areas.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
<b>118A</b>	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
<b>LOCAL EXHAUST FANS</b>							
Bathroom exhaust fan is functioning properly?	There is no Bathroom im Room 118A			This is a kiln room and there is a distinct odor associated with art activities/storage.	Physical Plant operations to evaluate A/C zone and review for potential for odor to be dispersed.	Physical Plant Operations	2
<b>118B</b>	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
<b>GENERAL CLEANLINESS</b>							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Room 118B is a storage room for the Art Room			No issues identified at the time of assessment. Stoarge room for the art room.	None		
<b>LOCAL EXHAUST FANS</b>							
Bathroom exhaust fan is functioning properly?	Room 118B does not have a bathroom.			No bathroom. Identified in error.	None		
My classroom has sufficient exhaust systems based on the activities/functionality of the room?	Room 118B does not have a bathroom.			No exhaust fans in room. Identified in error.	None		
<b>Walkthrough</b>							
				Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
<i>118B</i>	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
<i>118C</i>	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
<b>EXCESS MOISTURE IN CLASSROOMS</b>							
	Area around and under classroom sinks free of leaks?			No signs of water intrusion under sink. Area under sink needs to be cleaned.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Damage to wall behind dryer. Custodian indicated the paint crew has a work order to repair. Dust on ceiling tiles.	Facilities serviceperson to follow up on work order for wall and clean or replace ceiling tiles as appropriate.	Site Based	2
<b>GENERAL CLEANLINESS</b>							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		Room 118C is part of the Art Room and is used for Storage as well has housing the Washer/Dryer that the Maintenance workers use. There is also an additional sink in Room118C.	Supply vent is missing cover.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	2
<b>LOCAL EXHAUST FANS</b>							
	Bathroom exhaust fan is functioning properly?		Room 118C has no Bathroom....	No bathroom. Identified in error.	None		
<i>118D</i>	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
<b>ANIMALS IN THE CLASSROOM</b>							
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
<b>GENERAL CLEANLINESS</b>							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		Room 118D is a storage room and serves as my office area as part of the Art Room.	No dust observed on supply/return registers at the time of assessment.	None		
<b>LOCAL EXHAUST FANS</b>							
	Bathroom exhaust fan is functioning properly?			No bathroom. Identified in error.	None		
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?			No exhaust fans in room. Identified in error.	None		
<b>Walkthrough</b>							
				Hole in one of the ceiling tiles.	Facilities serviceperson to replace damaged ceiling tiles.	Site Based	2

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority	
118E	Temp <input type="text"/> RH% <input type="text"/> CO2 <input type="text"/>	Occupants: <input type="text"/>				
	<b>ANIMALS IN THE CLASSROOM</b> Activities and/or room conditions are modified to address student allergies?		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
	<b>GENERAL CLEANLINESS</b> Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Room 118E is a storage facility for the Art Room.	No dust observed on supply/return registers at the time of assessment.	None		
	<b>LOCAL EXHAUST FANS</b> My classroom has sufficient exhaust systems based on the activities/functionality of the room?	118E has no bathroom...	No bathroom. Identified in error.	None		
119	Temp <input type="text"/> RH% <input type="text"/> CO2 <input type="text"/>	Occupants: <input type="text"/>				
	<b>LOCAL EXHAUST FANS</b> Bathroom exhaust fan is functioning properly?	There are no exhaust fans in the classroom.	No bathroom. Identified in error.	None		
	Other exhaust fans that may exist in the classroom are functioning properly?	There are no exhaust fans in the classroom.	No exhaust fans in room. Identified in error.	None		
	<b>THERMAL COMFORT</b> Room is usually comfortable? (If no, please explain in the notes below.)	Classroom is too cold. I have a thermometer in the room and it is usually 68 degrees. The children and parents complain that it is too cold an environment. It is not an optimum condition for the children to perform. They often complain of being too c	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Temperature in my classroom is generally comfortable (72F-76F)?	Classroom is too cold. I have a thermometer in the room and it is usually 68 degrees. The children and parents complain that it is too cold an environment. It is not an optimum condition for the children to perform. They often complain of being too c	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
120	Temp <input type="text"/> RH% <input type="text"/> CO2 <input type="text"/>	Occupants: <input type="text"/>				
	<b>AIR CONDITIONING</b> Room is free of smell of chemicals?		No odor detected at the time of assessment.	None		

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority	
120	Temp <input type="text"/> RH% <input type="text"/> CO2 <input type="text"/>	Occupants: <input type="text"/>				
	Room is free of smell of kitchen/food?	No odor detected at the time of assessment.	None			
	Room is free of smell of mold or mildew?	No odor detected at the time of assessment.	None			
<b>ANIMALS IN THE CLASSROOM</b>						
	Activities and/or room conditions are modified to address student allergies?		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
<b>GENERAL CLEANLINESS</b>						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	The temperature is uneven and the room is very dusty and stuffy.This sometimes gives me a headache and bothers my sinus.	No dust observed on supply/return registers at the time of assessment.	None		
	Classroom is dusted/vacuumed thoroughly and regularly?	The temperature is uneven and the room is very dusty and stuffy.This sometimes gives me a headache and bothers my sinus.	General cleanliness of the room at the time of assessment was acceptable.	None		
	Classrooms general appearance is clean and acceptable?	The temperature is uneven and the room is very dusty and stuffy.This sometimes gives me a headache and bothers my sinus.	General cleanliness of the room at the time of assessment was acceptable.	None		
	Floor is cleaned on a regular basis?	The temperature is uneven and the room is very dusty and stuffy.This sometimes gives me a headache and bothers my sinus.	Stains on floor (from Mastic).	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Room is free of pests?	The temperature is uneven and the room is very dusty and stuffy.This sometimes gives me a headache and bothers my sinus.	No pests observed at the time of assessment.	None		
	Room is free of the use of scented cleaners and air fresheners?	The temperature is uneven and the room is very dusty and stuffy.This sometimes gives me a headache and bothers my sinus.	No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.	None		
<b>LOCAL EXHAUST FANS</b>						
	Bathroom exhaust fan is functioning properly?		Exhaust fan is functioning properly.	None		
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?		No issues identified at the time of assessment.	None		
	Other exhaust fans that may exist in the classroom are functioning properly?		Exhaust fan is functioning properly.	None		
<b>THERMAL COMFORT</b>						
	Classroom is free of significant temperature shifts?	The temperature spreads unevenly causing some areas warm and some cold.	Environmental parameters were within acceptable range at the time of assessment..	None		

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
120	<p>Temp <input type="text"/> RH% <input type="text"/> CO2 <input type="text"/></p> <p>Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)</p> <p>Room is usually comfortable? (If no, please explain in the notes below.)</p> <p>Temperature in my classroom is generally comfortable (72F-76F)?</p>	<p>Occupants: <input type="text"/></p> <p>Humidity was acceptable at the time of assessment.</p> <p>Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.</p> <p>Temperature was acceptable at the time of assessment.</p>	<p>None</p> <p>Facilities serviceperson should monitor this room.</p> <p>None</p>	<p>Site Based</p>	<p>2</p>
121	<p>Temp <input type="text" value="70.1"/> RH% <input type="text" value="54.1"/> CO2 <input type="text" value="1065"/></p> <p>LOCAL EXHAUST FANS</p> <p>Other exhaust fans that may exist in the classroom are functioning properly?</p> <p>THERMAL COMFORT</p> <p>Room is usually comfortable? (If no, please explain in the notes below.)</p> <p>Temperature in my classroom is generally comfortable (72F-76F)?</p> <p>Walkthrough</p>	<p>Occupants: <input type="text" value="0"/></p> <p>Exhaust fan is functioning properly.</p> <p>Temperature was low at the time of assessment.</p> <p>Temperature was low at the time of assessment.</p> <p>Stains on floor (from Mastic).</p>	<p>None</p> <p>See previous item for recommendation.</p> <p>Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.</p> <p>Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.</p>	<p>Site Based</p> <p>Site Based</p> <p>Site Based</p>	<p>2</p> <p>2</p> <p>2</p>
122	<p>Temp <input type="text" value="70.4"/> RH% <input type="text" value="54.1"/> CO2 <input type="text" value="1142"/></p> <p>AIR CONDITIONING</p> <p>Room is free of smell of mold or mildew?</p> <p>ANIMALS IN THE CLASSROOM</p> <p>Activities and/or room conditions are modified to address student allergies?</p> <p>DRAIN TRAPS IN THE CLASSROOM</p>	<p>Occupants: <input type="text" value="0"/></p> <p>No odor detected at the time of assessment.</p>	<p>None</p> <p>Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.</p>	<p>Site Based</p>	<p>3</p>

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
122	Temp	70.4	RH% 54.1	CO2 1142	Occupants: 0		
	Water poured down floor drains once per week (approx. 1 quart of water).				No floor drain in room.	None	
	<b>EXCESS MOISTURE IN CLASSROOMS</b>						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks or signs of water intrusion identified.	None	
	<b>GENERAL CLEANLINESS</b>						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	room is dusty	cold	stuffy	No dust observed on supply/return registers at the time of assessment.	None	
	Classroom is dusted/vacuumed thoroughly and regularly?	room is dusty	cold	stuffy	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	2
	Classrooms general appearance is clean and acceptable?	room is dusty	cold	stuffy	General cleanliness of the room at the time of assessment was acceptable.	None	
	Floor is cleaned on a regular basis?	room is dusty	cold	stuffy	Floor was clean at the time of assessment.	None	
	Room is free of pests?	room is dusty	cold	stuffy	No pests observed at the time of assessment.	None	
	<b>LOCAL EXHAUST FANS</b>						
	Bathroom exhaust fan is functioning properly?				Exhaust fan is functioning properly.	None	
	Other exhaust fans that may exist in the classroom are functioning properly?				Exhaust fan is functioning properly.	None	
	<b>THERMAL COMFORT</b>						
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	my classroom is cold			Humidity was acceptable at the time of assessment.	None	
	Room is usually comfortable? (If no, please explain in the notes below.)	my classroom is cold			Temperature was low at the time of assessment.	See previous item for recommendation.	
	Temperature in my classroom is generally comfortable (72F-76F)?	my classroom is cold			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
123A	Temp	72.7	RH% 54.1	CO2 1244	Occupants: 19		
<b>AIR CONDITIONING</b>							
	Room is free of smell of mold or mildew?	g) dont know if room is free of mold or mildew. constantly feeling ill/sick in room.		No odor detected at the time of assessment.	None		
<b>ANIMALS IN THE CLASSROOM</b>							
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
<b>GENERAL CLEANLINESS</b>							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.	None		
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Room is free of pests?			No pests observed at the time of assessment.	None		
<b>LOCAL EXHAUST FANS</b>							
	Bathroom exhaust fan is functioning properly?			No bathroom. Identified in error.	None		
<b>THERMAL COMFORT</b>							
	Classroom is free of significant temperature shifts?	air is either too cold or too hot. never in between. getting constant headaches, throat irritation, and sniffing due to air.		Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based	2
	Room is usually comfortable? (If no, please explain in the notes below.)	air is either too cold or too hot. never in between. getting constant headaches, throat irritation, and sniffing due to air.		Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?	air is either too cold or too hot. never in between. getting constant headaches, throat irritation, and sniffing due to air.		Temperature was acceptable at the time of assessment.	None		
<b>Walkthrough</b>							
				Stains on floor (from Mastic)	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
124	Temp	71.8	RH% 53.8	CO2 1188	Occupants: 23		
	<b>EXCESS MOISTURE IN CLASSROOMS</b>						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	discoloration around air vents		No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	2
	<b>GENERAL CLEANLINESS</b>						
	Classroom is dusted/vacuumed thoroughly and regularly?			General cleanliness of the room at the time of assessment was acceptable.	None		
	<b>THERMAL COMFORT</b>						
	Classroom is free of significant temperature shifts?			Environmental parameters were within acceptable range at the time of assessment..	None		
125	Temp	71.6	RH% 53.1	CO2 1238	Occupants: 23		
	Walkthrough						
				Stains on floor (from Mastic).	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
126	Temp	69.7	RH% 54	CO2 1014	Occupants: 3		
	Walkthrough						
				Exterior walls dry.	None		
				One stained ceiling tile.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
				Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
127	Temp	69.2	RH% 57.9	CO2 1119	Occupants: 22		
	<b>EXCESS MOISTURE IN CLASSROOMS</b>						
	Classroom lavatories/water fountains free of leaks?			No leaks identified. Non-approved chemicals, scented cleaners or air fresheners found under sink at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1
	<b>GENERAL CLEANLINESS</b>						



FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
127	Temp	69.2	RH% 57.9	CO2 1119	Occupants: 22		
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None	
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	2
	<b>THERMAL COMFORT</b>						
	Classroom is free of significant temperature shifts?		Room has been more comfortable this year-years past this room has been consistently warm 76-78		Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	2
128	Temp	69.3	RH% 56.7	CO2 1030	Occupants: 0		
	<b>ANIMALS IN THE CLASSROOM</b>						
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	3
	<b>GENERAL CLEANLINESS</b>						
	Classroom is dusted/vacuumed thoroughly and regularly?				Dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	2
	<b>THERMAL COMFORT</b>						
	Classroom is free of significant temperature shifts?		Room is very cold,but there are times if it is changed when it becomes too warm. We need an appropriate balance.				
	Room is usually comfortable? (If no, please explain in the notes below.)		Room is very cold,but there are times if it is changed when it becomes too warm. We need an appropriate balance.		Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	2
	Temperature in my classroom is generally comfortable (72F-76F)?		Room is very cold,but there are times if it is changed when it becomes too warm. We need an appropriate balance.				

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
129	Temp	69.2	RH% 59.4	CO2 1080	Occupants: 0		
Walkthrough							
				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
				Stains on floor (Mastic).	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
130	Temp	69.6	RH% 55.7	CO2 1085	Occupants: 18		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?						Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None		
Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
THERMAL COMFORT							
Room is usually comfortable? (If no, please explain in the notes below.)			Until this year my room was usually too warm, sticky and smelly. Temperatures ran as high as 78 on some days. This year my room is exceptionally chilly. But chilly is better than hot and smelly!	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
Temperature in my classroom is generally comfortable (72F-76F)?			Until this year my room was usually too warm, sticky and smelly. Temperatures ran as high as 78 on some days. This year my room is exceptionally chilly. But chilly is better than hot and smelly!				
Walkthrough							
				Stains on floor (Mastic)	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
				Dust observed on ceiling tiles at supply register at the time of assessment.	Facilities serviceperson to clean ceiling tiles as appropriate.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
131	Temp	69.5	RH% 54.8	CO2 1033	Occupants:	2	
<b>GENERAL CLEANLINESS</b>							
Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
<b>THERMAL COMFORT</b>							
Classroom is free of significant temperature shifts?		Room is always cold and very uncomfortable to work in. The students have runny noses and complain of how cold it is. I (teacher) have to dress with layers of clothes in order to feel warm and comfortable to teach. It is continuously cold in my classroom		Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		Room is always cold and very uncomfortable to work in. The students have runny noses and complain of how cold it is. I (teacher) have to dress with layers of clothes in order to feel warm and comfortable to teach. It is continuously cold in my classroom		Humidity was acceptable at the time of assessment.	None		
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)		Room is always cold and very uncomfortable to work in. The students have runny noses and complain of how cold it is. I (teacher) have to dress with layers of clothes in order to feel warm and comfortable to teach. It is continuously cold in my classroom		No windows in room.	None		
Room is usually comfortable? (If no, please explain in the notes below.)		Room is always cold and very uncomfortable to work in. The students have runny noses and complain of how cold it is. I (teacher) have to dress with layers of clothes in order to feel warm and comfortable to teach. It is continuously cold in my classroom					
Temperature in my classroom is generally comfortable (72F-76F)?		Room is always cold and very uncomfortable to work in. The students have runny noses and complain of how cold it is. I (teacher) have to dress with layers of clothes in order to feel warm and comfortable to teach. It is continuously cold in my classroom					
<b>Walkthrough</b>							
				Stains on floor (Mastic).	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
				Occupant indicated sewage smell.	Physical Plant Operations to evaluate cause of odor. Check seal on toilet.	Physical Plant Operations	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

132

Temp  RH%  CO2  Occupants:

**ANIMALS IN THE CLASSROOM**

Activities and/or room conditions are modified to address student allergies?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

**EXCESS MOISTURE IN CLASSROOMS**

Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?

No leaks or signs of water intrusion identified.

None

Indoor surfaces of exterior walls free of continuous condensation?

No visible condensation or signs of water intrusion identified at the time of assessment.

None

**GENERAL CLEANLINESS**

Classroom is dusted/vacuumed thoroughly and regularly?

General cleanliness of the room at the time of assessment was acceptable.

None

**THERMAL COMFORT**

Classroom is free of significant temperature shifts?

Room is always cold and very uncomfortable to work in. The students are have runny noses and complain of how cold it is. I (teacher) have been sick consistantly through the year. I dress in long pants and sweaters daily.It is continously cold on a daily

Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)

Room is always cold and very uncomfortable to work in. The students are have runny noses and complain of how cold it is. I (teacher) have been sick consistantly through the year. I dress in long pants and sweaters daily.It is continously cold on a daily

Humidity was acceptable at the time of assessment.

None

Room is free of the introduction of outdoor air? (Gaps in window/door frames.)

Room is always cold and very uncomfortable to work in. The students are have runny noses and complain of how cold it is. I (teacher) have been sick consistantly through the year. I dress in long pants and sweaters daily.It is continously cold on a daily

No windows in room.

None

Room is usually comfortable? (If no, please explain in the notes below.)

Room is always cold and very uncomfortable to work in. The students are have runny noses and complain of how cold it is. I (teacher) have been sick consistantly through the year. I dress in long pants and sweaters daily.It is continously cold on a daily

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority					
132	Temp	68.2	RH%	57.1	CO2	1021	Occupants:	0				
	Temperature in my classroom is generally comfortable (72F-76F)?			Room is always cold and very uncomfortable to work in. The students are have runny noses and complain of how cold it is. I (teacher) have been sick consistantly through the year. I dress in long pants and sweaters daily.It is continously cold on a daily			Temperature was low at the time of assessment.		Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.		Site Based	2
135	Temp	71	RH%	54	CO2	1188	Occupants:	22				
	Walkthrough			Bathroom has broken tile.			Physical Plant Operations to evaluate and repair as appropriate.		Physical Plant Operations		2	
136	Temp	71.4	RH%	53	CO2	1226	Occupants:	23				
	AIR CONDITIONING			Room is free of smell of mold or mildew?			No odor detected at the time of assessment.		None			
	DRAIN TRAPS IN THE CLASSROOM			If not regularly used, toilets flushed once each week.			No issues identified at the time of assessment.		None			
				Water poured down floor drains once per week (approx. 1 quart of water).			No issues identified at the time of assessment.		None			
	EXCESS MOISTURE IN CLASSROOMS			Area around and under classroom sinks free of leaks?			No leaks or signs of water intrusion identified.		None			
				Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Elevated moisture levels on exterior wall near separating wall.		Physical Plant Operations to evaluate and repair as appropriate.		Physical Plant Operations	1
				Classroom lavatories/water fountains free of leaks?			No leaks or signs of water intrusion identified.		None			
	GENERAL CLEANLINESS			Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.		None			
				Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.		Site Based	2
				Classrooms general appearance is clean and acceptable?			General cleanliness of the room at the time of assessment was acceptable.		None			

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
136	Temp	71.4	RH% 53	CO2 1226	Occupants: 23		
	Floor is cleaned on a regular basis?				Stains on floor (Mastic).	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?				No issues identified at the time of assessment.	None	
	<b>LOCAL EXHAUST FANS</b>						
	Other exhaust fans that may exist in the classroom are functioning properly?				No exhaust fans in room. Identified in error.	None	
	<b>THERMAL COMFORT</b>						
	Room is usually comfortable? (If no, please explain in the notes below.)				Environmental parameters were within acceptable range at the time of assessment..	None	
137	Temp	70.9	RH% 53.3	CO2 1172	Occupants: 20		
	<b>LOCAL EXHAUST FANS</b>						
	Bathroom exhaust fan is functioning properly?				Exhaust fan is functioning properly.	None	
138	Temp		RH%	CO2	Occupants:		
	<b>GENERAL CLEANLINESS</b>						
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Floor is cleaned on a regular basis?				The classroom is vacuumed occasionally, but rarely mopped. The room appears to collect thick dust quickly. I have had several lizards, cockroaches and even a huge spider in the room, along with a frog that must have climbed up the pipes.	Stains on floor (Mastic).	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. Site Based 2
	Room is free of pests?				The classroom is vacuumed occasionally, but rarely mopped. The room appears to collect thick dust quickly. I have had several lizards, cockroaches and even a huge spider in the room, along with a frog that must have climbed up the pipes.	No pests observed at the time of assessment.	None
	<b>THERMAL COMFORT</b>						

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority	
138	Temp <input type="text"/> RH% <input type="text"/> CO2 <input type="text"/>	Occupants: <input type="text"/>				
	Classroom is free of significant temperature shifts?	It is either freezing in the classroom or it feels like the air has been shut off. The classroom never feels comfortable. One day it may be hot and another day it may be too cold. Children and parents have complained.				
	Room is usually comfortable? (If no, please explain in the notes below.)	It is either freezing in the classroom or it feels like the air has been shut off. The classroom never feels comfortable. One day it may be hot and another day it may be too cold. Children and parents have complained.				
	Temperature in my classroom is generally comfortable (72F-76F)?	It is either freezing in the classroom or it feels like the air has been shut off. The classroom never feels comfortable. One day it may be hot and another day it may be too cold. Children and parents have complained.	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Walkthrough		Dust on ceiling tiles near air supply vents. One stained ceiling tile (Northwest corner).	Facilities serviceperson to clean ceiling tiles near supply vents and replace stained ceiling tile.	Site Based	2
139	Temp <input type="text" value="70.5"/> RH% <input type="text" value="55.2"/> CO2 <input type="text" value="1065"/>	Occupants: <input type="text" value="19"/>				
	AIR CONDITIONING					
	Air flowing from air supply?	Some air supply vents may not be functioning. I know that the one adjacent to the front door is functioning by doing the suggested test.	Air flowing without obstruction at the time of assessment.	None		
140	Temp <input type="text" value="70.7"/> RH% <input type="text" value="55"/> CO2 <input type="text" value="1148"/>	Occupants: <input type="text" value="21"/>				
	AIR CONDITIONING					
	Room is free of smell of mold or mildew?	very musty smell	No odor detected at the time of assessment.	None		
	EXCESS MOISTURE IN CLASSROOMS					
	Windows, windowsills and window frames free of continuous condensation?		Signs of previous water intrusion. Appears to be corrected.	Facilities serviceperson should monitor this room.	Site Based	3
	GENERAL CLEANLINESS					
	Classroom is dusted/vacuumed thoroughly and regularly?		Dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

140

Temp  RH%  CO2  Occupants:

**LOCAL EXHAUST FANS**

Other exhaust fans that may exist in the classroom are functioning properly?

only exhaust fan is in bathroom - turns on - but there is very few ventilation so odors stay

Exhaust fan is functioning properly.

None

**THERMAL COMFORT**

Classroom is free of significant temperature shifts?

Air quality is usually freezing - there is a gap between outdoor playground door and the floor tile - air gets in - close in class is colder than classroom - temperature is usually unbearable - students have runny noses and usually wear a coat

Humidity was acceptable at the time of assessment.

None

Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)

Air quality is usually freezing - there is a gap between outdoor playground door and the floor tile - air gets in - close in class is colder than classroom - temperature is usually unbearable - students have runny noses and usually wear a coat

Room is free of the introduction of outdoor air? (Gaps in window/door frames.)

Air quality is usually freezing - there is a gap between outdoor playground door and the floor tile - air gets in - close in class is colder than classroom - temperature is usually unbearable - students have runny noses and usually wear a coat

Door to outside has gap at bottom.

Physical Plant Operations to evaluate and repair as appropriate.

Physical Plant Operations

1

Room is usually comfortable? (If no, please explain in the notes below.)

Air quality is usually freezing - there is a gap between outdoor playground door and the floor tile - air gets in - close in class is colder than classroom - temperature is usually unbearable - students have runny noses and usually wear a coat

Temperature was low at the time of assessment.

Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Site Based

2

Temperature in my classroom is generally comfortable (72F-76F)?

Air quality is usually freezing - there is a gap between outdoor playground door and the floor tile - air gets in - close in class is colder than classroom - temperature is usually unbearable - students have runny noses and usually wear a coat

140D

Temp  RH%  CO2  Occupants:

**AIR CONDITIONING**

Air flowing from air supply?

This is an exterior closet with no air vents.

Air is flowing without obstruction?

This is an exterior closet with no air vents.

Room is free of smell of mold or mildew?

This is an exterior closet with no air vents.



FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
-----------	----------------------	----------	----------------	-------------	----------

140D

Temp  RH%  CO2  Occupants:

**GENERAL CLEANLINESS**

Classroom is dusted/vacuumed thoroughly and regularly?	This is an exterior storage closet, so many of these questions do not apply.
Floor is cleaned on a regular basis?	This is an exterior storage closet, so many of these questions do not apply.
Trash is removed daily and trash bags are changed as appropriate?	This is an exterior storage closet, so many of these questions do not apply.

**LOCAL EXHAUST FANS**

My classroom has sufficient exhaust systems based on the activities/functionality of the room?	No bathroom in this closet, no exhaust fan
--	--

**THERMAL COMFORT**

Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)

Temperature in my classroom is generally comfortable (72F-76F)?

141

Temp  RH%  CO2  Occupants:

**AIR CONDITIONING**

Air flowing from air supply?	Air flowing without obstruction at the time of assessments.	None
Room is free of smell of mold or mildew?	No odor detected at the time of assessment.	None

**ART SUPPLIES**

Exposure minimized for art supplies?	Room is adjacent to art room. Possible kiln odor.	Evaluate kiln room to ensure that exhaust is adequate and vent is operating when kiln is in use.	Site Based	2
Exposure minimized for industrial supplies?	No issues identified at the time of assessment.	None		
Exposure minimized for science supplies?	No issues identified at the time of assessment.	None		

**GENERAL CLEANLINESS**

Classroom is dusted/vacuumed thoroughly and regularly?	General cleanliness of the room at the time of assessment was acceptable.	None
--	---	------

**LOCAL EXHAUST FANS**

Bathroom exhaust fan is functioning properly?	Exhaust fan is functioning properly.	None
---	--------------------------------------	------

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
-----------	----------------------	----------	----------------	-------------	----------

141

Temp  RH%  CO2

Occupants:

Other exhaust fans that may exist in the classroom are functioning properly?

No exhaust fans in room. Identified in error.

None

142

Temp  RH%  CO2

Occupants:

**AIR CONDITIONING**

Room is free of smell of mold or mildew?

No odor detected at the time of assessment.

None

**EXCESS MOISTURE IN CLASSROOMS**

Windows, windowsills and window frames free of continuous condensation?

Signs of previous water intrusion from water fountain leak. Appears to be corrected.

None

**LOCAL EXHAUST FANS**

Bathroom exhaust fan is functioning properly?

Exhaust fan is functioning properly.

None

Other exhaust fans that may exist in the classroom are functioning properly?

Exhaust fan is functioning properly.

None

**THERMAL COMFORT**

Classroom is free of significant temperature shifts?

Room is always too cold.

Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)

Room is always too cold.

Humidity was acceptable at the time of assessment.

None

Room is free of the introduction of outdoor air? (Gaps in window/door frames.)

Room is always too cold.

Gap in exterior door to playground.

Physical Plant Operations to evaluate and repair as appropriate.

Physical Plant Operations

1

Room is usually comfortable? (If no, please explain in the notes below.)

Room is always too cold.

Temperature was low at the time of assessment.

Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Site Based

2

Temperature in my classroom is generally comfortable (72F-76F)?

Room is always too cold.

144

Temp  RH%  CO2

Occupants:

**AIR CONDITIONING**

Air is flowing without obstruction?

There is no air return grille. Cooking odors from cafeteria are present on occasion.

Smoke testing confirmed that air supply/return ventilation is functioning qualitatively.

None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
144	Temp	75.5	RH% 46.3	CO2 744	Occupants: 1			
	Room is free of smell of kitchen/food?	There is no air return grille. Cooking odors from cafeteria are present on occasion.			Room is near cafeteria. Occupant indicated not a problem.	None		
<b>ANIMALS IN THE CLASSROOM</b>								
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
	You are informed about the potential allergies of your students?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
<b>DRAIN TRAPS IN THE CLASSROOM</b>								
	Water run in sinks at least once per week (about 2 cups of water).				It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	None		
<b>GENERAL CLEANLINESS</b>								
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Custodians have been asked to mop the room three times in one week and have not done so, have not been cleaned in two months.			Dust observed on supply register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?	Custodians have been asked to mop the room three times in one week and have not done so, have not been cleaned in two months.			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?	Custodians have been asked to mop the room three times in one week and have not done so, have not been cleaned in two months.			Floor was clean at the time of assessment.	None		
<b>LOCAL EXHAUST FANS</b>								
	Bathroom exhaust fan is functioning properly?	There is no exhaust system. There is no bathroom.			No exhaust fans in room. Identified in error.	None		
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?	There is no exhaust system. There is no bathroom.			No exhaust fans in room. Identified in error.	None		
	Other exhaust fans that may exist in the classroom are functioning properly?	There is no exhaust system. There is no bathroom.			No exhaust fans in room. Identified in error.	None		
<b>THERMAL COMFORT</b>								
	Classroom is free of significant temperature shifts?	Some times to cold and then to warm for the computers, The room is very warm most of the time.			Environmental parameters were within acceptable range at the time of assessment..	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
<i>144</i>	Temp	<input type="text" value="75.5"/>	RH% <input type="text" value="46.3"/>	CO2 <input type="text" value="744"/>	Occupants: <input type="text" value="1"/>			
	Room is usually comfortable? (If no, please explain in the notes below.)	Some times to cold and then to warm for the computers, The room is very warm most of the time.			Environmental parameters were within acceptable range at the time of assessment..	None		
	Temperature in my classroom is generally comfortable (72F-76F)?	Some times to cold and then to warm for the computers, The room is very warm most of the time.			Environmental parameters were within acceptable range at the time of assessment..	None		
<i>144A</i>	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>			
<b>AIR CONDITIONING</b>								
	Windows/doors are operable and are kept closed?	No windows in room. This is a storage closet.				None		
<b>ANIMALS IN THE CLASSROOM</b>								
	Activities and/or room conditions are modified to address student allergies?	This is a storage closet.				None	3	
	You are informed about the potential allergies of your students?	This is a storage closet.				None		
<b>DRAIN TRAPS IN THE CLASSROOM</b>								
	If not regularly used, toilets flushed once each week.	This is a storage closet.				None		
	Water poured down floor drains once per week (approx. 1 quart of water).	This is a storage closet.				None		
	Water run in sinks at least once per week (about 2 cups of water).	This is a storage closet.				None		
<b>GENERAL CLEANLINESS</b>								
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	This is a storage closet			Slight dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?	This is a storage closet			General cleanliness of the room at the time of assessment was acceptable.	None		
	Classrooms general appearance is clean and acceptable?	This is a storage closet			General cleanliness of the room at the time of assessment was acceptable.	None		
	Floor is cleaned on a regular basis?	This is a storage closet			Floor was clean at the time of assessment.	None		
	Trash is removed daily and trash bags are changed as appropriate?	This is a storage closet			This is a storage closet.	None		
<b>LOCAL EXHAUST FANS</b>								
	Bathroom exhaust fan is functioning properly?	There are no exhaust fans. There is no bathroom.			This is a storage closet.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
<b>144A</b>	<b>Temp</b> <input type="text"/>	<b>RH%</b> <input type="text"/>	<b>CO2</b> <input type="text"/>	<b>Occupants:</b> <input type="text"/>			
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?	There are no exhaust fans. There is no bathroom.		This is a storage closet.	None		
	Other exhaust fans that may exist in the classroom are functioning properly?	There are no exhaust fans. There is no bathroom.		This is a storage closet.	None		
	<b>THERMAL COMFORT</b>						
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Room is too warm.		This is a storage closet.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)	Room is too warm.		This is a storage closet.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?	Room is too warm.		This is a storage closet.	None		
<b>145A</b>	<b>Temp</b> <input type="text"/>	<b>RH%</b> <input type="text"/>	<b>CO2</b> <input type="text"/>	<b>Occupants:</b> <input type="text"/>			
	<b>AIR CONDITIONING</b>						
	Windows/doors are operable and are kept closed?			No windows in room.	None		
	<b>ANIMALS IN THE CLASSROOM</b>						
	Activities and/or room conditions are modified to address student allergies?			This is a storage closet.	None		
	You are informed about the potential allergies of your students?			This is a storage closet.	None		
	<b>DRAIN TRAPS IN THE CLASSROOM</b>						
	Water poured down floor drains once per week (approx. 1 quart of water).			This is a storage closet.	None		
	Water run in sinks at least once per week (about 2 cups of water).			It appears as though sink is not utilized regularly. Sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	None		
	<b>EXCESS MOISTURE IN CLASSROOMS</b>						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks or signs of water intrusion identified.	None		
	<b>GENERAL CLEANLINESS</b>						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	This is a storage closet, not a classroom.		Slight dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?	This is a storage closet, not a classroom.		This is a storage closet.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
<b>145A</b>	<b>Temp</b>	<input type="text"/>	<b>RH%</b>	<input type="text"/>	<b>CO2</b>	<input type="text"/>	<b>Occupants:</b>	<input type="text"/>
	Classrooms general appearance is clean and acceptable?		This is a storage closet, not a classroom.	This is a storage closet.		None		
	Floor is cleaned on a regular basis?		This is a storage closet, not a classroom.	Floor was clean at the time of assessment.		None		
<b>LOCAL EXHAUST FANS</b>								
	Bathroom exhaust fan is functioning properly?		There are no exhaust fans.	This is a storage closet.		None		
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?		There are no exhaust fans.	This is a storage closet.		None		
	Other exhaust fans that may exist in the classroom are functioning properly?		There are no exhaust fans.	This is a storage closet.		None		
<b>THERMAL COMFORT</b>								
	Classroom is free of significant temperature shifts?		The door is usually kept closed so the closet is cooler than the classroom of which it is a part.	This is a storage closet.		None		
	Room is usually comfortable? (If no, please explain in the notes below.)		The door is usually kept closed so the closet is cooler than the classroom of which it is a part.	This is a storage closet.		None		
	Temperature in my classroom is generally comfortable (72F-76F)?		The door is usually kept closed so the closet is cooler than the classroom of which it is a part.	This is a storage closet.		None		

**151A**      **Temp**  **RH%**  **CO2**       **Occupants:**

**GENERAL CLEANLINESS**

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	I am in a classroom that the partition is open making two classrooms used as one. I am actually 151 and 154. I have no respiratory problems at home or outside the school. After being in school an hour I look like I have a major cold . eyes water and nose	No dust observed on supply/return registers at the time of assessment.	None		
Classroom is dusted/vacuumed thoroughly and regularly?	I am in a classroom that the partition is open making two classrooms used as one. I am actually 151 and 154. I have no respiratory problems at home or outside the school. After being in school an hour I look like I have a major cold . eyes water and nose	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Floor is cleaned on a regular basis?	I am in a classroom that the partition is open making two classrooms used as one. I am actually 151 and 154. I have no respiratory problems at home or outside the school. After being in school an hour I look like I have a major cold . eyes water and nose	Stains on floor (Mastic).	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

151A

Temp  RH%  CO2  Occupants:

**THERMAL COMFORT**

Classroom is free of significant temperature shifts?	Most of the time it is cold. I wear my sweater 90% of the time. While I am in school.	Environmental parameters were within acceptable range at the time of assessment..	None
Room is usually comfortable? (If no, please explain in the notes below.)	Most of the time it is cold. I wear my sweater 90% of the time. While I am in school.	Environmental parameters were within acceptable range at the time of assessment..	None
Temperature in my classroom is generally comfortable (72F-76F)?	Most of the time it is cold. I wear my sweater 90% of the time. While I am in school.	Environmental parameters were within acceptable range at the time of assessment..	None

152

Temp  RH%  CO2  Occupants:

**GENERAL CLEANLINESS**

Classroom is dusted/vacuumed thoroughly and regularly?	My classroom rugs are vacuumed regularly, however the tile floor is extremely dirty.	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Floor is cleaned on a regular basis?	My classroom rugs are vacuumed regularly, however the tile floor is extremely dirty.	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
Trash is removed daily and trash bags are changed as appropriate?	My classroom rugs are vacuumed regularly, however the tile floor is extremely dirty.	No issues identified regarding trash removal practices.	None		

**LOCAL EXHAUST FANS**

Bathroom exhaust fan is functioning properly?	There are No Exhaust fans in the bathroom and it stinks inside.	No exhaust fans in room. Identified in error.	None
My classroom has sufficient exhaust systems based on the activities/functionality of the room?	There are No Exhaust fans in the bathroom and it stinks inside.	No exhaust fans in room. Identified in error.	None
Other exhaust fans that may exist in the classroom are functioning properly?	There are No Exhaust fans in the bathroom and it stinks inside.	No exhaust fans in room. Identified in error.	None

**THERMAL COMFORT**

Classroom is free of significant temperature shifts?		Environmental parameters were within acceptable range at the time of assessment..	None
--	--	---	------

152A

Temp  RH%  CO2  Occupants:

**AIR CONDITIONING**

Air flowing from air supply?		Smoke testing confirmed that air supply/return ventilation is functioning qualitatively.	None
------------------------------	--	--	------

**ANIMALS IN THE CLASSROOM**

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
<b>152A</b>	<b>Temp</b>	77.5	<b>RH%</b>	49.7	<b>CO2</b>	899	<b>Occupants:</b>	1			
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based					3
<b>GENERAL CLEANLINESS</b>											
	Classroom is dusted/vacuumed thoroughly and regularly?			General cleanliness of the room at the time of assessment was acceptable.	None						
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None						
	Trash is removed daily and trash bags are changed as appropriate?			No issues identified regarding trash removal practices.	None						
<b>LOCAL EXHAUST FANS</b>											
	Bathroom exhaust fan is functioning properly?		I DO NOT HAVE A BATHROOM, I do not have an exhaust fan.	No exhaust fans in room. Identified in error.							
	Other exhaust fans that may exist in the classroom are functioning properly?		I DO NOT HAVE A BATHROOM, I do not have an exhaust fan.	No exhaust fans in room. Identified in error.							
<b>THERMAL COMFORT</b>											
	Classroom is free of significant temperature shifts?		too cool	Environmental parameters were within acceptable range at the time of assessment..	None						
	Room is usually comfortable? (If no, please explain in the notes below.)		too cool	Environmental parameters were within acceptable range at the time of assessment..	None						
	Temperature in my classroom is generally comfortable (72F-76F)?		too cool	Environmental parameters were within acceptable range at the time of assessment..	None						
<b>154</b>	<b>Temp</b>	73.7	<b>RH%</b>	53.7	<b>CO2</b>	796	<b>Occupants:</b>	10			
<b>AIR CONDITIONING</b>											
	Room is free of smell of kitchen/food?		At times, the room will have a musty smell.	No odor detected at the time of assessment.	None						
	Room is free of smell of mold or mildew?		At times, the room will have a musty smell.	No odor detected at the time of assessment.							
<b>GENERAL CLEANLINESS</b>											
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		This classroom is actually two identical classrooms. The partition between the two has been open, making it into one classroom. The classroom number of the other side is 151.	No dust observed on supply/return registers at the time of assessment.	None						
	Classroom is dusted/vacuumed thoroughly and regularly?		This classroom is actually two identical classrooms. The partition between the two has been open, making it into one classroom. The classroom number of the other side is 151.	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based					2



FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
<b>154</b>	Temp	73.7	RH% 53.7	CO2 796	Occupants: 10		
	Floor is cleaned on a regular basis?	This classroom is actually two identical classrooms. The partition between the two has been open, making it into one classroom. The classroom number of the other side is 151.		Stains on floor (Mastic).	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Trash is removed daily and trash bags are changed as appropriate?	This classroom is actually two identical classrooms. The partition between the two has been open, making it into one classroom. The classroom number of the other side is 151.		No issues identified regarding trash removal practices.	None		
	<b>LOCAL EXHAUST FANS</b>						
	Bathroom exhaust fan is functioning properly?	Do not have a bathroom or other exhaust fan system in the classroom.		No exhaust fans in room. Identified in error.	None		
	Other exhaust fans that may exist in the classroom are functioning properly?	Do not have a bathroom or other exhaust fan system in the classroom.		No exhaust fans in room. Identified in error.	None		
<b>156</b>	Temp		RH%	CO2	Occupants:		
	<b>GENERAL CLEANLINESS</b>						
	Classroom is dusted/vacuumed thoroughly and regularly?	this is a storage room- so does not require daily attention		This is a PE storage room.	None		
	Floor is cleaned on a regular basis?	this is a storage room- so does not require daily attention		Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Room is free of pests?	this is a storage room- so does not require daily attention		Dead pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	2
	<b>LOCAL EXHAUST FANS</b>						
	Bathroom exhaust fan is functioning properly?			No bathroom. Identified in error.	None		
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)			This is a PE storage room.	None		
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?			No exhaust fans in room. Identified in error.	None		
	Other exhaust fans that may exist in the classroom are functioning properly?			No exhaust fans in room. Identified in error.	None		
<b>164</b>	Temp	74.9	RH% 49.6	CO2 1008	Occupants: 20		
	<b>AIR CONDITIONING</b>						
	Room is free of smell of kitchen/food?	After a weekend the room has a musty smell. Equipment has a filmy feeling and books have a slight odor, especially stored books.		No odor detected at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
164	Temp	74.9	RH% 49.6	CO2 1008	Occupants: 20		
	Room is free of smell of mold or mildew?	After a weekend the room has a musty smell. Equipment has a filmy feeling and books have a slight odor, especially stored books.			No odor detected at the time of assessment.	None	
<b>ANIMALS IN THE CLASSROOM</b>							
	You are informed about the potential allergies of your students?	There is no list of students with specific allergies available.				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
<b>GENERAL CLEANLINESS</b>							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	The air vents have black dust streaks coming from them. Rolls of dust blow around on the floor. Equipment is dusty.			No dust observed on supply/return registers at the time of assessment.	None	
	Classroom is dusted/vacuumed thoroughly and regularly?	The air vents have black dust streaks coming from them. Rolls of dust blow around on the floor. Equipment is dusty.			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Floor is cleaned on a regular basis?	The air vents have black dust streaks coming from them. Rolls of dust blow around on the floor. Equipment is dusty.			Floor was clean at the time of assessment.	None	
<b>THERMAL COMFORT</b>							
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	At times the room temperature is warm and sticky feeling.			Humidity was acceptable at the time of assessment.	None	
	Room is usually comfortable? (If no, please explain in the notes below.)	At times the room temperature is warm and sticky feeling.			Environmental parameters were within acceptable range at the time of assessment..	None	
	Temperature in my classroom is generally comfortable (72F-76F)?	At times the room temperature is warm and sticky feeling.			Environmental parameters were within acceptable range at the time of assessment..	None	
	Walkthrough				Several bowed ceiling tiles which suggest previous humidity issues. Several dusty ceiling tiles around supply vents. Speaker wire hanging from ceiling.	Facilities serviceperson should clean ceiling tiles as appropriate and remove wire.	Site Based 2

201/202

Temp	73.9	RH% 51.9	CO2 1253	Occupants: 13
------	------	----------	----------	---------------

**AIR CONDITIONING**

Room is free of smell of mold or mildew?

The classroom smells of mold. Only time window or doors are left open is when the AC is not working for more than one day.

No odor detected at the time of assessment. Odor identified by occupant may be related to wet wall.

None

**DRAIN TRAPS IN THE CLASSROOM**

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
201/202	Temp	73.9	RH% 51.9	CO2 1253	Occupants: 13		
Water poured down floor drains once per week (approx. 1 quart of water).			The shower in room 201 is not used and either is the shower. No one goes in the room and custodians do not run the water in either sink drain or shower drain.	No floor drain in room.	None		
<b>EXCESS MOISTURE IN CLASSROOMS</b>							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Both shower and bathroom have been had stains painted over several times. Wallpaper is coming off walls in the classroom.	No leaks or signs of water intrusion identified on ceiling.	None		
Indoor surfaces of exterior walls free of continuous condensation?			Both shower and bathroom have been had stains painted over several times. Wallpaper is coming off walls in the classroom.	West wall (202) has high moisture level.			
Windows, windowsills and window frames free of continuous condensation?			Both shower and bathroom have been had stains painted over several times. Wallpaper is coming off walls in the classroom.	No visible condensation at the time of assessment.	None		
<b>GENERAL CLEANLINESS</b>							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			I have the use of both room 201 and 202 so I am answering the questions for both rooms.	No dust observed on supply/return registers at the time of assessment.	None		
Classroom is dusted/vacuumed thoroughly and regularly?			I have the use of both room 201 and 202 so I am answering the questions for both rooms.	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Classrooms general appearance is clean and acceptable?			I have the use of both room 201 and 202 so I am answering the questions for both rooms.	General cleanliness of the room at the time of assessment was acceptable.	None		
Floor is cleaned on a regular basis?			I have the use of both room 201 and 202 so I am answering the questions for both rooms.	Floor was clean at the time of assessment.	None		
Room is free of the use of scented cleaners and air fresheners?			I have the use of both room 201 and 202 so I am answering the questions for both rooms.	No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.	None		
Spills and other such issues requiring custodial assistance are addressed in a timely manner?			I have the use of both room 201 and 202 so I am answering the questions for both rooms.	No issues identified at the time of assessment.	None		
<b>LOCAL EXHAUST FANS</b>							
Bathroom exhaust fan is functioning properly?			What exhaust system????	Exhaust fan is functioning properly.	None		
Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)			What exhaust system????	No exhaust fans in room. Identified in error.	None		
My classroom has sufficient exhaust systems based on the activities/functionality of the room?			What exhaust system????	No exhaust fans in room. Identified in error.	None		
Other exhaust fans that may exist in the classroom are functioning properly?			What exhaust system????	No exhaust fans in room. Identified in error.	None		

**LOCKER ROOM**

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
201/202	Temp	<input type="text" value="73.9"/>	RH% <input type="text" value="51.9"/>	CO2 <input type="text" value="1253"/>	Occupants: <input type="text" value="13"/>		
	Locker room and showers cleaned regularly and properly?	Shower in my classroom has never been cleaned.		Dust and debris identified in shower at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
<b>THERMAL COMFORT</b>							
	Classroom is free of significant temperature shifts?	It is usually very cold in my classroom and very hot and humid in the bathrooms.		Environmental parameters were within acceptable range at the time of assessment..	None		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	It is usually very cold in my classroom and very hot and humid in the bathrooms.		Humidity was acceptable at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)	It is usually very cold in my classroom and very hot and humid in the bathrooms.		Environmental parameters were within acceptable range at the time of assessment..	None		
	Temperature in my classroom is generally comfortable (72F-76F)?	It is usually very cold in my classroom and very hot and humid in the bathrooms.		Environmental parameters were within acceptable range at the time of assessment..	None		
279C	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
<b>AIR CONDITIONING</b>							
	Room is free of smell of chemicals?	There is a chemical type smell about twice weekly that comes from the outside into the portable and stays all day. Also, when the grass is being cut outside of the portable the dirt and debris comes back into the portable as well as being in the outside		Odor detected. Room was recently painted and odor may be related to paint.	Facilities serviceperson should monitor this room.	Site Based	2
	Room is free of smell of mold or mildew?	There is a chemical type smell about twice weekly that comes from the outside into the portable and stays all day. Also, when the grass is being cut outside of the portable the dirt and debris comes back into the portable as well as being in the outside		No odor detected from mold and mildew at the time of assessment.	None		
	Room is free of smell of vehicle exhaust?	There is a chemical type smell about twice weekly that comes from the outside into the portable and stays all day. Also, when the grass is being cut outside of the portable the dirt and debris comes back into the portable as well as being in the outside		No odor from vehicle exhaust detected at the time of assessment.	None		
<b>ANIMALS IN THE CLASSROOM</b>							
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
279C	Temp <input type="text"/> RH% <input type="text"/> CO2 <input type="text"/>	Occupants: <input type="text"/>			
	You are informed about the potential allergies of your students?		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
<b>LOCAL EXHAUST FANS</b>					
	Bathroom exhaust fan is functioning properly?	I am unsure of what exhaust fans are and where they would be located. I do have a fan that operates in the air/heat unit that is supposed to circulate air. It does work as far as I can tell. I do not have a bathroom so letter c does not apply.	No bathroom. Identified in error.	None	
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?	I am unsure of what exhaust fans are and where they would be located. I do have a fan that operates in the air/heat unit that is supposed to circulate air. It does work as far as I can tell. I do not have a bathroom so letter c does not apply.	Exhaust fan is functioning properly.	None	
	Other exhaust fans that may exist in the classroom are functioning properly?	I am unsure of what exhaust fans are and where they would be located. I do have a fan that operates in the air/heat unit that is supposed to circulate air. It does work as far as I can tell. I do not have a bathroom so letter c does not apply.	Exhaust fan is functioning properly.	None	
<b>THERMAL COMFORT</b>					
	Classroom is free of significant temperature shifts?	Response to letter d - I am unsure of humidity being at an acceptable level.	Environmental parameters were within acceptable range at the time of assessment..	None	
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Response to letter d - I am unsure of humidity being at an acceptable level.	Humidity was acceptable at the time of assessment.	None	
<b>Walkthrough</b>					
			Dust and debris on HVAC coils.	Physical Plant operations to evaluate and clean HVAC coils.	Physical Plant Operations 1
			Severe rust around light fixtures.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations 2

348V Temp  RH%  CO2  Occupants:

**AIR CONDITIONING**

Room is free of smell of mold or mildew? No odor detected at the time of assessment. None

**ANIMALS IN THE CLASSROOM**

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
348V	Temp	72.1	RH% 52.5	CO2 2723	Occupants: 18		
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
<b>ART SUPPLIES</b>							
	Industrial supplies okay?			No industrial supplies in room. Room not being used as an industrial room.	None		
<b>EXCESS MOISTURE IN CLASSROOMS</b>							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
	Classroom lavatories/water fountains free of leaks?			No leaks or signs of water intrusion identified.	None		
<b>GENERAL CLEANLINESS</b>							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		The floor is partially cleaned on an irregular basis and black dirt is not scrubbed off.	No dust observed on supply/return registers at the time of assessment.	None		
	Classroom is dusted/vacuumed thoroughly and regularly?		The floor is partially cleaned on an irregular basis and black dirt is not scrubbed off.	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classrooms general appearance is clean and acceptable?		The floor is partially cleaned on an irregular basis and black dirt is not scrubbed off.	General cleanliness of the room at the time of assessment was acceptable. Significant amount of educational materials in room.	None		
	Floor is cleaned on a regular basis?		The floor is partially cleaned on an irregular basis and black dirt is not scrubbed off.	Stains on tile (Mastic).	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
<b>LOCAL EXHAUST FANS</b>							
	Bathroom exhaust fan is functioning properly?		The bathroom always smells.	Exhaust fan is functioning properly.	None		
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?		The bathroom always smells.	No exhaust fans in room. Identified in error.	None		
<b>THERMAL COMFORT</b>							
	Classroom is free of significant temperature shifts?		There are no functioning blinds on the windows so I can not control the heat that enters.	Environmental parameters were within acceptable range at the time of assessment..	None		
	Room is usually comfortable? (If no, please explain in the notes below.)		There are no functioning blinds on the windows so I can not control the heat that enters.	Environmental parameters were within acceptable range at the time of assessment..	None		

Walkthrough

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
348V	Temp	72.1	RH% 52.5	CO2 2723	Occupants: 18		
				Dust and debris on HVAC coils.	Physical Plant operations to evaluate and clean HVAC coils.	Physical Plant Operations	1
401	Temp	75.7	RH% 49.1	CO2 1485	Occupants: 26		
<b>EXCESS MOISTURE IN CLASSROOMS</b>							
	Area around and under classroom sinks free of leaks?			No leaks or signs of water intrusion identified.	None		
<b>GENERAL CLEANLINESS</b>							
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None		
	Room is free of the use of scented cleaners and air fresheners?			No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.	None		
<b>THERMAL COMFORT</b>							
	Classroom is free of significant temperature shifts?		The air will not click on if it is too cold outside. The temperature when on is usually colder than necessary.	Environmental parameters were within acceptable range at the time of assessment..	None		
	Room is usually comfortable? (If no, please explain in the notes below.)		The air will not click on if it is too cold outside. The temperature when on is usually colder than necessary.	Environmental parameters were within acceptable range at the time of assessment..	None		
	Temperature in my classroom is generally comfortable (72F-76F)?		The air will not click on if it is too cold outside. The temperature when on is usually colder than necessary.	Environmental parameters were within acceptable range at the time of assessment..	None		
402	Temp	75.6	RH% 43.5	CO2 1104	Occupants: 18		
<b>GENERAL CLEANLINESS</b>							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		Floor cleaning consists of daily dry sweeping and sometimes a wet mop wipe off.  Room is free of pests now, but have had problems with ants, large, small, winged, etc., coming in through the cracks/spaces between counter and outside wall.	No dust observed on supply/return registers at the time of assessment.	None		
Walkthrough							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
402	Temp	75.6	RH% 43.5	CO2 1104	Occupants: 18		
				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
				Dead pests and droppings observed under window at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	2
				Damaged wallboard under window. Moisture meter indicated elevated moisture in several areas.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	1
403	Temp	73.3	RH% 50.5	CO2 1091	Occupants: 0		
<b>AIR CONDITIONING</b>							
				Room is free of smell of mold or mildew?	No odor detected at the time of assessment.	None	
				Room is free of smell of vehicle exhaust?	No odor detected at the time of assessment.	None	
<b>ART SUPPLIES</b>							
				Art supplies okay?	No art supplies in room. Room not being used as an art room.	None	
				Science supplies okay?	No science supplies in room. Room not being used as a science room.	None	
<b>EXCESS MOISTURE IN CLASSROOMS</b>							
				Area around and under classroom sinks free of leaks?	No leaks or signs of water intrusion identified.	None	
				Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks or signs of water intrusion identified.	None	
				Classroom lavatories/water fountains free of leaks?	No leaks or signs of water intrusion identified.	None	
				Windows, windowsills and window frames free of continuous condensation?	No visible condensation at the time of assessment.	None	
<b>LOCAL EXHAUST FANS</b>							
				Bathroom exhaust fan is functioning properly?	Exhaust fan is functioning properly.	None	
				My classroom has sufficient exhaust systems based on the activities/functionality of the room?	Exhaust fan is functioning properly.	None	
<b>THERMAL COMFORT</b>							
				Classroom is free of significant temperature shifts?	The room is either uncomfortably warm or cold. Environmental parameters were within acceptable range at the time of assessment..	None	



FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
403	Temp	73.3	RH%	50.5	CO2	1091	Occupants:	0			
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		The room is either uncomfortably warm or cold.		Humidity was acceptable at the time of assessment.		None				
	Room is usually comfortable? (If no, please explain in the notes below.)		The room is either uncomfortably warm or cold.		Environmental parameters were within acceptable range at the time of assessment..		None				
	Temperature in my classroom is generally comfortable (72F-76F)?		The room is either uncomfortably warm or cold.		Environmental parameters were within acceptable range at the time of assessment..		None				
	Walkthrough				Dust and dirt accumulation on floor.		Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based			2
404	Temp	76.4	RH%	42.9	CO2	1178	Occupants:	0			
	AIR CONDITIONING										
	Room is free of smell of mold or mildew?				No odor detected at the time of assessment.		None				
	GENERAL CLEANLINESS										
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.	Site Based			2
	Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor.		Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based			2
	Room is free of pests?				No pests observed at the time of assessment. Spider webs observed in window sills.		Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations			2
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?				No issues identified at the time of assessment.		None				
	THERMAL COMFORT										
	Classroom is free of significant temperature shifts?		The room can be extremely cold.		Environmental parameters were within acceptable range at the time of assessment..		None				
	Room is usually comfortable? (If no, please explain in the notes below.)		The room can be extremely cold.		Environmental parameters were within acceptable range at the time of assessment..		None				
	Walkthrough				Excessive dust observed on return register at the time of assessment.		Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based			1

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
501	Temp	73.1	RH% 47.9	CO2 1039	Occupants:	0	
<b>ANIMALS IN THE CLASSROOM</b>							
Classroom is free of animals and pets?				No animals identified at the time of assessment.	None		
<b>EXCESS MOISTURE IN CLASSROOMS</b>							
Indoor surfaces of exterior walls free of continuous condensation?				South wall was recently repaired. Baseboard is missing.	Physical Plant operations to install baseboard.	Physical Plant Operations	3
Windows, windowsills and window frames free of continuous condensation?				No visible condensation at the time of assessment.	None		
<b>GENERAL CLEANLINESS</b>							
Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was acceptable.	None		
Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None		
Room is free of pests?				No pests observed at the time of assessment.	None		
Spills and other such issues requiring custodial assistance are addressed in a timely manner?				No issues identified at the time of assessment.	None		
Trash is removed daily and trash bags are changed as appropriate?				No issues identified regarding trash removal practices.	None		
504	Temp	74.9	RH% 46.6	CO2 1314	Occupants:	0	
<b>AIR CONDITIONING</b>							
Air flowing from air supply?				Smoke testing confirmed that air supply/return ventilation is functioning qualitatively.	None		
<b>GENERAL CLEANLINESS</b>							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			THERE IS A LOT OF DUST/MOLD ON MY VENTS AND CEILING.	Slight dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
Floor is cleaned on a regular basis?			THERE IS A LOT OF DUST/MOLD ON MY VENTS AND CEILING.	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
<b>LOCAL EXHAUST FANS</b>							
Bathroom exhaust fan is functioning properly?				No bathroom. Identified in error.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
504	Temp	74.9	RH% 46.6	CO2 1314	Occupants: 0		
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?			No issues identified at the time of assessment.	None		
	Other exhaust fans that may exist in the classroom are functioning properly?			Exhaust fan is functioning properly.	None		
	<b>THERMAL COMFORT</b>						
	Classroom is free of significant temperature shifts?			Environmental parameters were within acceptable range at the time of assessment..	None		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)			Humidity was acceptable at the time of assessment.	None		
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)			No issues identified at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)			Environmental parameters were within acceptable range at the time of assessment..	None		
	Temperature in my classroom is generally comfortable (72F-76F)?			Environmental parameters were within acceptable range at the time of assessment..	None		
	<b>Walkthrough</b>						
				North wall near dry erase board shows evidence of previous water damage. Moisture testing indicated slightly elevated.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	1
850	Temp	77.6	RH% 56	CO2 1174	Occupants: 24		
	<b>GENERAL CLEANLINESS</b>						
	Floor is cleaned on a regular basis?			Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
851	Temp	75.7	RH% 56.6	CO2 708	Occupants: 0		
	<b>GENERAL CLEANLINESS</b>						
	Food, if any, is stored in tightly sealed containers?			No issues identified at the time of assessment.	None		
852	Temp	76.3	RH% 68.9	CO2 1171	Occupants: 0		
	<b>GENERAL CLEANLINESS</b>						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
852	Temp	<input type="text" value="76.3"/>	RH% <input type="text" value="68.9"/>	CO2 <input type="text" value="1171"/>	Occupants: <input type="text" value="0"/>		
853	Temp	<input type="text" value="76"/>	RH% <input type="text" value="56"/>	CO2 <input type="text" value="690"/>	Occupants: <input type="text" value="3"/>		
Walkthrough				Odor detected at the time of assessment. Cause not found.	Physical Plant Operations to evaluate cause of odor.	Physical Plant Operations	2
854	Temp	<input type="text" value="75.5"/>	RH% <input type="text" value="62.3"/>	CO2 <input type="text" value="862"/>	Occupants: <input type="text" value="1"/>		
Walkthrough				No issues identified at the time of assessment.	None		
855	Temp	<input type="text" value="76.2"/>	RH% <input type="text" value="63.3"/>	CO2 <input type="text" value="641"/>	Occupants: <input type="text" value="0"/>		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				General cleanliness of the room at the time of assessment was acceptable.	None		
856	Temp	<input type="text" value="76.3"/>	RH% <input type="text" value="52.3"/>	CO2 <input type="text" value="879"/>	Occupants: <input type="text" value="1"/>		
GENERAL CLEANLINESS							
Room is free of pests?			Pests = lizards	No pests observed at the time of assessment.	None		
Walkthrough				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
857	Temp	<input type="text" value="76.5"/>	RH% <input type="text" value="58.5"/>	CO2 <input type="text" value="631"/>	Occupants: <input type="text" value="19"/>		
GENERAL CLEANLINESS							
Classrooms general appearance is clean and acceptable?				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
858	Temp	<input type="text" value="72.5"/>	RH% <input type="text" value="53.2"/>	CO2 <input type="text" value="609"/>	Occupants: <input type="text" value="1"/>		
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.		None		
88IVE	Temp	<input type="text" value="75.5"/>	RH% <input type="text" value="47.3"/>	CO2 <input type="text" value="1683"/>	Occupants: <input type="text" value="0"/>		
AIR CONDITIONING							
Room is free of smell of chemicals?			Room has odor. I do not know the source.		Physical Plant Operations to evaluate and repair as appropriate.		Physical Plant Operations 1
Room is free of smell of mold or mildew?			Room has odor. I do not know the source.		None		
8P	Temp	<input type="text" value="77.6"/>	RH% <input type="text" value="47.1"/>	CO2 <input type="text" value="702"/>	Occupants: <input type="text" value="1"/>		
AIR CONDITIONING							
Room is free of smell of mold or mildew?			After week-ends or long vacations the portable does feel damp and clammy and smell of mold and mildew. Sometimes it causes my eyes to burn.		Musty odor in portable.		Physical Plant Operations to evaluate cause of odor. Physical Plant Operations 1
GENERAL CLEANLINESS							
Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.		None		
THERMAL COMFORT							
Classroom is free of significant temperature shifts?			This portable has 2 functioning, individually controlled air conditioners that allow us to adjust temperatures.		Environmental parameters were within acceptable range at the time of assessment..		None
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)			This portable has 2 functioning, individually controlled air conditioners that allow us to adjust temperatures.		No issues identified at the time of assessment.		None
Modular Units	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
Walkthrough							
			General issue regarding Modular Units - the bathroom exhaust fans appear to continually run even when the light is off.		Physical Plant Operations to evaluate and repair as appropriate.		Physical Plant Operations 2