

McNab Elementary

IAQ Walkthrough 5/11/2005

0841

Outside Temp RH% CO2

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
101	Temp <input type="text" value="76.3"/> RH% <input type="text" value="52.0"/> CO2 <input type="text" value="598"/>	Occupants: <input type="text" value="7"/>			
	EXCESS MOISTURE IN CLASSROOMS				
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	We are in a new building (1 1/2 years old) but the low window ledge next to my desk has water damage. The paint is blistering and it getting more and more discolored. It feels soft to the touch.	No leaks or signs of water intrusion identified.	None	
	Indoor surfaces of exterior walls free of continuous condensation?	We are in a new building (1 1/2 years old) but the low window ledge next to my desk has water damage. The paint is blistering and it getting more and more discolored. It feels soft to the touch.	Condensation on walls at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations 2
	Windows, windowsills and window frames free of continuous condensation?	We are in a new building (1 1/2 years old) but the low window ledge next to my desk has water damage. The paint is blistering and it getting more and more discolored. It feels soft to the touch.	Condensation on windows at the time of assessment. Temperature was within acceptable range and no leaks were identified.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations 2
	THERMAL COMFORT				
	Room is usually comfortable? (If no, please explain in the notes below.)	The office is always cold.	Temperature was acceptable at the time of assessment.	None	
	Temperature in my classroom is generally comfortable (72F-76F)?	The office is always cold.	Temperature was acceptable at the time of assessment.	None	
101E	Temp <input type="text" value="74.2"/> RH% <input type="text" value="57.5"/> CO2 <input type="text" value="578"/>	Occupants: <input type="text" value="2"/>			
	AIR CONDITIONING				
	Windows/doors are operable and are kept closed?		Windows and doors are operable and are kept closed.	None	
	GENERAL CLEANLINESS				
	Classroom is dusted/vacuumed thoroughly and regularly?		Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Room is free of pests?		No pests observed at the time of assessment.	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
101E	Temp <input type="text" value="74.2"/>	RH% <input type="text" value="57.5"/>	CO2 <input type="text" value="578"/>	Occupants: <input type="text" value="2"/>			
THERMAL COMFORT							
Classroom is free of significant temperature shifts?		It is very cold in my office.		Temperature was acceptable at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)		It is very cold in my office.		Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based	2
Temperature in my classroom is generally comfortable (72F-76F)?		It is very cold in my office.		Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based	2
101F	Temp <input type="text" value="74.0"/>	RH% <input type="text" value="57.9"/>	CO2 <input type="text" value="547"/>	Occupants: <input type="text" value="1"/>			
THERMAL COMFORT							
Classroom is free of significant temperature shifts?				Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based	2
Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was acceptable at the time of assessment.	None		
101L	Temp <input type="text" value="73.8"/>	RH% <input type="text" value="58.7"/>	CO2 <input type="text" value="597"/>	Occupants: <input type="text"/>			
THERMAL COMFORT							
Room is usually comfortable? (If no, please explain in the notes below.)		My office is usually too cold.		Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based	2
Temperature in my classroom is generally comfortable (72F-76F)?		My office is usually too cold.		Temperature was acceptable at the time of assessment.	None		
101P	Temp <input type="text" value="70.9"/>	RH% <input type="text" value="64.0"/>	CO2 <input type="text" value="547"/>	Occupants: <input type="text"/>			
AIR CONDITIONING							
Air is flowing without obstruction?		I have had breathing problems since the beginning of the year and would like my air unit checked for possible mold etc.		Air flowing without obstruction at the time of assessments.	None		
THERMAL COMFORT							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority			
101P	Temp	70.9	RH%	64.0	CO2	547	Occupants:			
Classroom is free of significant temperature shifts?			For the most part my room is so cold that I have to find alternative areas to work with the students. Mid-day is when it usually becomes the coldest!!!	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based				2
Room is usually comfortable? (If no, please explain in the notes below.)			For the most part my room is so cold that I have to find alternative areas to work with the students. Mid-day is when it usually becomes the coldest!!!	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based				2
Temperature in my classroom is generally comfortable (72F-76F)?			For the most part my room is so cold that I have to find alternative areas to work with the students. Mid-day is when it usually becomes the coldest!!!	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based				2
106	Temp	72.4	RH%	56.5	CO2	607	Occupants:	4		
EXCESS MOISTURE IN CLASSROOMS										
Windows, windowsills and window frames free of continuous condensation?							No condensation on windows at the time of assessment.		None	
THERMAL COMFORT										
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)			Temperature is too cold. This has been addressed, but never taken care of . Other staff members and outside visitors comment on temperature in this office.	Gaps in windows or doors identified at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations				2
Room is usually comfortable? (If no, please explain in the notes below.)			Temperature is too cold. This has been addressed, but never taken care of . Other staff members and outside visitors comment on temperature in this office.	Temperature was acceptable at the time of assessment.	None					
Temperature in my classroom is generally comfortable (72F-76F)?			Temperature is too cold. This has been addressed, but never taken care of . Other staff members and outside visitors comment on temperature in this office.	Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based				2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
315	Temp	73.2	RH% 57.6	CO2 1126	Occupants:	23	
EXCESS MOISTURE IN CLASSROOMS							
Area around and under classroom sinks free of leaks?					No leaks or signs of water intrusion identified.	None	
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?					Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based 2
Classroom lavatories/water fountains free of leaks?					No lavatories/water fountains in room.	None	
Windows, windowsills and window frames free of continuous condensation?					No condensation on windows at the time of assessment.	None	
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?					No dust observed on supply/return registers at the time of assessment.	None	
Classroom is dusted/vacuumed thoroughly and regularly?					General cleanliness of the room at the time of assessment was acceptable.	None	
Trash is removed daily and trash bags are changed as appropriate?					No issues identified regarding trash removal practices.	None	
THERMAL COMFORT							
Classroom is free of significant temperature shifts?					Temperature was acceptable at the time of assessment.	None	
Temperature in my classroom is generally comfortable (72F-76F)?					Temperature was acceptable at the time of assessment.	None	
316	Temp	72.9	RH% 56.9	CO2 1109	Occupants:	21	
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?					This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
Classroom is free of animals and pets?					No animals identified at the time of assessment.	None	
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?					No dust observed on supply/return registers at the time of assessment.	None	
Classroom is dusted/vacuumed thoroughly and regularly?					Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
316	Temp	<input type="text" value="72.9"/>	RH% <input type="text" value="56.9"/>	CO2 <input type="text" value="1109"/>	Occupants: <input type="text" value="21"/>		
	Room is free of pests?			No pests observed at the time of assessment.	None		
318	Temp	<input type="text" value="72.1"/>	RH% <input type="text" value="57.5"/>	CO2 <input type="text" value="1014"/>	Occupants: <input type="text"/>		
	ANIMALS IN THE CLASSROOM						
	You are informed about the potential allergies of your students?	I have not been informed as of this time of any potential allergies of my students.		This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	EXCESS MOISTURE IN CLASSROOMS						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks or signs of water intrusion identified.	None		
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?	I have an ant problem that has been on-going for quite a long time.		Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Room is free of pests?	I have an ant problem that has been on-going for quite a long time.		Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	2
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?	It is getting better, but it is warm quite often and muggy in my room.		Temperature was acceptable at the time of assessment.	None		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	It is getting better, but it is warm quite often and muggy in my room.		Humidity was acceptable at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)	It is getting better, but it is warm quite often and muggy in my room.		Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?	It is getting better, but it is warm quite often and muggy in my room.		Temperature was acceptable at the time of assessment.	None		
327	Temp	<input type="text" value="71.3"/>	RH% <input type="text" value="57.9"/>	CO2 <input type="text" value="998"/>	Occupants: <input type="text" value="22"/>		
	EXCESS MOISTURE IN CLASSROOMS						
	Area around and under classroom sinks free of leaks?	the water fountain in my classroom is too close to the edge of the counter, when the kids get drinks the water runs down the front of cabinet that sits under the sink. the doors on the cabinet have swelled too from the water. the toilet frequently has to		No leaks or signs of water intrusion identified.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
327	Temp	71.3	RH% 57.9	CO2 998	Occupants: 22		
Classroom lavatories/water fountains free of leaks?	the water fountain in my classroom is too close to the edge of the counter, when the kids get drinks the water runs down the front of cabinet that sits under the sink. the doors on the cabinet have swelled too from the water. the toilet frequently has to			No leaks or signs of water intrusion identified.	None		
Indoor surfaces of exterior walls free of continuous condensation?	the water fountain in my classroom is too close to the edge of the counter, when the kids get drinks the water runs down the front of cabinet that sits under the sink. the doors on the cabinet have swelled too from the water. the toilet frequently has to			No condensation at the time of assessment.	None		
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	furniture is nit dusted regularly and the floor is not washed regularly. it has only been waxed once or twice in a year. our custodians have too much to do on our campus!			No dust observed on supply/return registers at the time of assessment.	None		
Classroom is dusted/vacuumed thoroughly and regularly?	furniture is nit dusted regularly and the floor is not washed regularly. it has only been waxed once or twice in a year. our custodians have too much to do on our campus!			General cleanliness of the room at the time of assessment was acceptable.	None		
Floor is cleaned on a regular basis?	furniture is nit dusted regularly and the floor is not washed regularly. it has only been waxed once or twice in a year. our custodians have too much to do on our campus!			Floor was clean at the time of assessment.	None		
THERMAL COMFORT							
Classroom is free of significant temperature shifts?	in the warmer weather i am always uncomfortable a reading was done last year the humidity was high when i move around a lot i get hot after pay time the kids complain they are hot			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	3
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	in the warmer weather i am always uncomfortable a reading was done last year the humidity was high when i move around a lot i get hot after pay time the kids complain they are hot			Humidity was slightly elevated at the time of assessment - 10% greater than outdoors.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
Room is usually comfortable? (If no, please explain in the notes below.)	in the warmer weather i am always uncomfortable a reading was done last year the humidity was high when i move around a lot i get hot after pay time the kids complain they are hot			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
327	Temp	71.3	RH%	57.9	CO2	998	Occupants:	22			
	Temperature in my classroom is generally comfortable (72F-76F)?			in the warmer weather i am always uncomfortable a reading was done last year the humidity was high when i move around a lot i get hot after pay time the kids complain they are hot	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based				2
331	Temp	74.0	RH%	52.2	CO2	1038	Occupants:	15			
	ANIMALS IN THE CLASSROOM Classroom is free of animals and pets?			We have 2 hermit crabs in our science center. The cage is cleaned regularly. We have had them for six months and have not had any problems.	No animals identified at the time of assessment.	None					
	EXCESS MOISTURE IN CLASSROOMS Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			I have some discoloration on my ceiling tiles.	Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based				2
333	Temp	73.2	RH%	59.4	CO2	1055	Occupants:	21			
	ANIMALS IN THE CLASSROOM Classroom is free of animals and pets?			We have a hermit crab.	No issue	None					
	GENERAL CLEANLINESS Classroom is dusted/vacuumed thoroughly and regularly?			Needs to be dusted more often.	General cleanliness of the room at the time of assessment was acceptable.	None					
335	Temp	73.0	RH%	55.6	CO2	800	Occupants:	22			
	AIR CONDITIONING Windows/doors are operable and are kept closed?				Windows and doors are operable and are kept closed.	None					
	GENERAL CLEANLINESS Room is free of the use of scented cleaners and air fresheners?				No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.	None					

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
336A	Temp	72.9	RH% 54.7	CO2 634	Occupants: 2		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders.		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
DRAIN TRAPS IN THE CLASSROOM							
Water run in sinks at least once per week (about 2 cups of water).			It appears as though water is poured down the floor drain at least once a week.		None		
EXCESS MOISTURE IN CLASSROOMS							
Classroom lavatories/water fountains free of leaks?			Water in my classroom sink and water fountain have been turned completely off for the past few months due to a leak in my room and the room across the hall. The sink was constantly dripping so they fixed it by shutting off the water.		Signs of water intrusion. Leak identified.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations 2
337	Temp	72.4	RH% 55.2	CO2 662	Occupants: 21		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?			Floor is swept with a push broom. This just creates a dust cloud which settles over the room. The room and small carpeted area need to be vacuumed		Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
Walkthrough					Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
339	Temp	72.6	RH% 55.0	CO2 729	Occupants: 3		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?			c.) Hermit Crabs		This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
339	Temp	72.6	RH% 55.0	CO2 729	Occupants: 3		
	Classroom is free of animals and pets?		c.) Hermit Crabs	No animals identified at the time of assessment.	None		
	You are informed about the potential allergies of your students?		c.) Hermit Crabs	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?		Area rug needs to be vacuumed. TV stand, computer area, and counters need to be dusted.m	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
347	Temp	72.3	RH% 55.7	CO2 681	Occupants: 2		
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?		Even when I or the custodian dusts it becomes dusty again almost immediately.	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?		Even when I or the custodian dusts it becomes dusty again almost immediately.	Floor was clean at the time of assessment.	None		
349	Temp	73.3	RH% 53.7	CO2 679	Occupants: 2		
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?			General cleanliness of the room at the time of assessment was acceptable.	None		
	Floor is cleaned on a regular basis?			Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Trash is removed daily and trash bags are changed as appropriate?			No issues identified regarding trash removal practices.	None		
920	Temp	68.1	RH% 54.8	CO2 932	Occupants: 23		
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		The carpet has stains that will not come out. The bathroom floor tile needs a through cleaning and so do the wall tiles. There are missing ceiling tiles and the media center often has a musty smell.	Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
920	Temp	68.1	RH%	54.8	CO2	932	Occupants:	23			
	Room is free of pests?	The carpet has stains that will not come out. The bathroom floor tile needs a through cleaning and so do the wall tiles. There are missing ceiling tiles and the media center often has a musty smell.			No pests observed at the time of assessment.	None					
	Walkthrough				Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based				2
					Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based				2
924	Temp	67.5	RH%	62.3	CO2	1356	Occupants:	24			
	GENERAL CLEANLINESS										
	Classroom is dusted/vacuumed thoroughly and regularly?	The classrooms are very dusty. Many of the ceiling tiles have been damaged by water and not replaced. The rooms smell moldy, dingy and musty. Not sure if the air filters are changed regularly. There is carpet in my room. Many of my students are sick			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based				2
	Floor is cleaned on a regular basis?	The classrooms are very dusty. Many of the ceiling tiles have been damaged by water and not replaced. The rooms smell moldy, dingy and musty. Not sure if the air filters are changed regularly. There is carpet in my room. Many of my students are sick			Remove carpet and install new tile floor.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations				2
	Room is free of pests?	The classrooms are very dusty. Many of the ceiling tiles have been damaged by water and not replaced. The rooms smell moldy, dingy and musty. Not sure if the air filters are changed regularly. There is carpet in my room. Many of my students are sick			No pests observed at the time of assessment.	None					
	Walkthrough				Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based				2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
926	Temp	68.3	RH% 57.8	CO2	Occupants:		
AIR CONDITIONING							
	Room is free of smell of chemicals?	Each morning definite urine like musty odor is evident, sometimes overwhelmingly so.		No odor detected at the time of assessment.	None		
	Room is free of smell of mold or mildew?	Each morning definite urine like musty odor is evident, sometimes overwhelmingly so.		Smell of urine	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
EXCESS MOISTURE IN CLASSROOMS							
	Area around and under classroom sinks free of leaks?	Several ceiling tiles have yellowish-brown stains. One tile nearest to hallway door has grown from a yellow stain spot to a dark brown/ and blackish center.		No leaks or signs of water intrusion identified.	None		
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	Several ceiling tiles have yellowish-brown stains. One tile nearest to hallway door has grown from a yellow stain spot to a dark brown/ and blackish center.		Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
	Classroom lavatories/water fountains free of leaks?	Several ceiling tiles have yellowish-brown stains. One tile nearest to hallway door has grown from a yellow stain spot to a dark brown/ and blackish center.		No leaks or signs of water intrusion identified.	None		
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Carpeting is dusty/moldy smelling when we enter each morning. When students move their chairs or desks over the carpeting, my throat and nose become constricted.		Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classrooms general appearance is clean and acceptable?	Carpeting is dusty/moldy smelling when we enter each morning. When students move their chairs or desks over the carpeting, my throat and nose become constricted.		Carpet was stained. Dust and debris accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?	Mornings are stuffy and humid. After students arrive classroom cools, frequently too cool.		Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority			
926	Temp	68.3	RH%	57.8	CO2		Occupants:			
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		Mornings are stuffy and humid. After students arrive classroom cools, frequently too cool.	Humidity was slightly elevated at the time of assessment - 10% greater than outdoors.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations				2
	Room is usually comfortable? (If no, please explain in the notes below.)		Mornings are stuffy and humid. After students arrive classroom cools, frequently too cool.	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based				2
	Temperature in my classroom is generally comfortable (72F-76F)?		Mornings are stuffy and humid. After students arrive classroom cools, frequently too cool.	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based				2
927	Temp	69.5	RH%	53.6	CO2	1563	Occupants:	27		
	AIR CONDITIONING									
	Room is free of smell of mold or mildew?		My room smells disgusting. I come in and get a headache from the smell daily. This is why I open the windows and back door. I need to ventilate the room, or my headache lasts all day.	Odor detected at the time of assessment.	Physical Plant Operations to evaluate cause of odor.	Physical Plant Operations				2
	GENERAL CLEANLINESS									
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		The custodial staff keeps my room clean, however, it smells like dirty socks every single day. Every morning when I come in, I need to open the windows and back door to try to remove some of the smell.	No dust observed on supply/return registers at the time of assessment.	None					
	LOCAL EXHAUST FANS									
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?			Exhaust fan is functioning properly.	None					
	THERMAL COMFORT									
	Room is usually comfortable? (If no, please explain in the notes below.)		My room is kept very cold. The School Dept. has been trying to fix this problem, however, normally, it is cold enough that students wear sweatshirts on a regular basis, and I keep a sweater and jacket in my room.	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based				2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
927	Temp	69.5	RH% 53.6	CO2 1563	Occupants: 27			
	Temperature in my classroom is generally comfortable (72F-76F)?	My room is kept very cold. The School Dept. has been trying to fix this problem, however, normally, it is cold enough that students wear sweatshirts on a regular basis, and I keep a sweater and jacket in my room.			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
931	Temp	67.2	RH% 63.5	CO2 1455	Occupants: 24			
	AIR CONDITIONING							
	Room is free of smell of mold or mildew?	Classrooms and building have a HORRIBLE SMELL!!!			Odor detected.	Physical Plant Operations to evaluate cause of odor.	Physical Plant Operations	2
	ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	EXCESS MOISTURE IN CLASSROOMS							
	Windows, windowsills and window frames free of continuous condensation?				No condensation on windows at the time of assessment.	None		
	GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?				General cleanliness of the room at the time of assessment was acceptable.	None		
	Floor is cleaned on a regular basis?				Remove soiled, stained carpet. Install new tile floor.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	1
	LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?	I am not aware of any fans			Bathroom exhaust fan is functioning properly.	None		
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?	I am not aware of any fans			It appears that the ventilation system is adequate based on room activities.	None		
	Other exhaust fans that may exist in the classroom are functioning properly?	I am not aware of any fans			Exhaust fan is functioning properly.	None		
	THERMAL COMFORT							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
931	Temp	67.2	RH% 63.5	CO2 1455	Occupants: 24			
	Classroom is free of significant temperature shifts?	Rooms are generally freezing, however lately the temperature has been moderately better.			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Room is usually comfortable? (If no, please explain in the notes below.)	Rooms are generally freezing, however lately the temperature has been moderately better.			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.		
	Temperature in my classroom is generally comfortable (72F-76F)?	Rooms are generally freezing, however lately the temperature has been moderately better.			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
932	Temp	67.5	RH% 59.4	CO2 1322	Occupants: 24			
	AIR CONDITIONING							
	Room is free of smell of mold or mildew?				Odor detected at the time of assessment.	Physical Plant Operations to evaluate cause of odor.	Physical Plant Operations	2
	EXCESS MOISTURE IN CLASSROOMS							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
	GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Floors are vacuumed regularly, but the room is seldom if ever dusted. Temperature is irregular and a strong smell of mold/mildew is always present.			Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	THERMAL COMFORT							
	Classroom is free of significant temperature shifts?	Room is more often than not, uncomfortable as far as temperature. It is often too cold or too hot. There is a constant odor of mold/mildew. There is often a damp feeling when walking in the classroom.			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
932	Temp	67.5	RH% 59.4	CO2 1322	Occupants: 24			
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Room is more often than not, uncomfortable as far as temperature. It is often too cold or too hot. There is a constant odor of mold/mildew. There is often a damp feeling when walking in the classroom.			Humidity was acceptable at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
	Room is usually comfortable? (If no, please explain in the notes below.)	Room is more often than not, uncomfortable as far as temperature. It is often too cold or too hot. There is a constant odor of mold/mildew. There is often a damp feeling when walking in the classroom.			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Temperature in my classroom is generally comfortable (72F-76F)?	Room is more often than not, uncomfortable as far as temperature. It is often too cold or too hot. There is a constant odor of mold/mildew. There is often a damp feeling when walking in the classroom.			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Walkthrough				Stained and soiled carpet. Install tile floor.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	1