

# North Side Elementary

## IAQ Walkthrough 5/17/2005

Outside Temp  RH%  CO2

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
104 Walkthrough	Temp <input type="text"/> RH% <input type="text"/> CO2 <input type="text"/>	Occupants: <input type="text"/>			
		Two stained ceiling tiles in administration area and one ceiling tile with green foreign object stuck in it.	Facilities serviceperson to replace stained ceiling tiles and other tile.	Site Based	2
107 Walkthrough	Temp <input type="text"/> RH% <input type="text"/> CO2 <input type="text"/>	Occupants: <input type="text"/>			
		Two stained ceiling tiles outside of this office.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
130B AIR CONDITIONING	Temp <input type="text" value="77.3"/> RH% <input type="text" value="50"/> CO2 <input type="text" value="1155"/>	Occupants: <input type="text" value="3"/>			
	Room is free of smell of mold or mildew?	Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	2
	DRAIN TRAPS IN THE CLASSROOM				
	Water run in sinks at least once per week (about 2 cups of water).	Sink faucet handle is broken.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
	GENERAL CLEANLINESS				
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	No animals identified at the time of assessment.	None	None	
	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.	None	None	
	Classroom is dusted/vacuumed thoroughly and regularly?	General cleanliness of the room at the time of assessment was acceptable.	None	None	
Walkthrough		No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
130B	Temp	77.3	RH% 50	CO2 1155	Occupants: 3		
				Dust and debris around condensate drain line.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	1
261	Temp	81.2	RH% 63.1	CO2 511	Occupants:		
GENERAL CLEANLINESS							
	Floor is cleaned on a regular basis?		the floor is swept daily, but it is not mopped daily nor buffed on a regular basis.	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classrooms general appearance is clean and acceptable?		the floor is swept daily, but it is not mopped daily nor buffed on a regular basis.	General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?		the floor is swept daily, but it is not mopped daily nor buffed on a regular basis.	General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
806	Temp		RH%	CO2	Occupants:		
GENERAL CLEANLINESS							
	Floor is cleaned on a regular basis?		General appearance of classroom is good. Floors behind and under furniture are not cleaned regularly. This area is cleaned only when teacher cleans it.	Dust and dirt accumulation on floor under desk, etc..	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?		General appearance of classroom is good. Floors behind and under furniture are not cleaned regularly. This area is cleaned only when teacher cleans it.	General cleanliness of the room at the time of assessment was acceptable.	None	None	
THERMAL COMFORT							
	Temperature in my classroom is generally comfortable (72F-76F)?		Classroom is normally too cold. Children have to wear heavier clothing inside our classroom then outside.	Temperature was acceptable at the time of assessment.	None	None	
	Room is usually comfortable? (If no, please explain in the notes below.)		Classroom is normally too cold. Children have to wear heavier clothing inside our classroom then outside.	Environmental parameters were within acceptable range at the time of assessment..	None	None	
	Classroom is free of significant temperature shifts?		Classroom is normally too cold. Children have to wear heavier clothing inside our classroom then outside.	Environmental parameters were within acceptable range at the time of assessment..	None	None	
Walkthrough							
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
806	Temp <input type="text"/> RH% <input type="text"/> CO2 <input type="text"/>	Occupants: <input type="text"/>			
		Crack identified at right window, broken screens and broken window crank.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
		Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	2
808	Temp <input type="text"/> RH% <input type="text"/> CO2 <input type="text"/>	Occupants: <input type="text"/>			
	<b>GENERAL CLEANLINESS</b>				
	Classrooms general appearance is clean and acceptable?	General cleanliness of the room at the time of assessment was acceptable.	None	None	
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.	None	None	
	Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting and cleaning efforts	Site Based	2
	<b>LOCAL EXHAUST FANS</b>				
	Bathroom exhaust fan is functioning properly?	No issues identified at the time of assessment.	None	None	
	<b>Walkthrough</b>				
		Unsealed food items were observed at the time of assessment. Unsealed food items may attract pests.	Site based administration should encourage all staff to maintain food items within sealable plastic storage containers.	Site Based	2
		Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1
		Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
		Dust and debris on ceiling tiles.	Facilities serviceperson to replace soiled ceiling tiles.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
901	Temp	<input type="text"/>	RH%	<input type="text"/>	CO2	<input type="text"/>	Occupants:	<input type="text"/>			
Walkthrough											
					Dust observed on return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based				2
					Excessive paper behind teachers desk.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	Site Based				2