

RISK MANAGEMENT...

managing risk with responsibility

Jeffrey S. Moquin, Director
Risk Management Department

Telephone: 754-321-3200
Facsimile: 754-321-3290

May 21, 2007

Signature on File

TO: Mr. Chuck McCanna, Principal
Nova Blanche Forman Elementary

FROM: Robert Krickovich, Coordinator, LEA
Facilities and Construction Management

SUBJECT: Indoor Air Quality (IAQ) Assessment
FISH 101T

<u>For Custodial Supervisor Use Only</u>	
<input type="checkbox"/>	Custodial Issues Addressed
<input type="checkbox"/>	Custodial Issues Not Addressed

On March 16, 2007 Richard Rosa conducted an assessment of FISH 101T at **Nova Blanche Forman Elementary**. This evaluation included observations of the flooring system, ceiling tiles, false ceiling plenum, environmental surfaces, interior and exterior walls, and the accessible ventilation equipment. Additionally, environmental parameter measurements were taken to include temperature, relative humidity, and carbon dioxide. The detailed findings, along with the recommended corrective action can be found on the attached IAQ Assessment Worksheets.

The IAQ assessment did identify one or more existing conditions impacting IAQ and has generated appropriate work orders to correct deficiencies in systems and maintenance that could contribute to decreased indoor air quality. At the time of the assessment, these concerns were not an immediate health or safety concern to building occupants. However, due to individual sensitivities and predisposing health factors, it is possible that some building occupants may elicit a health response to agents and / or conditions identified during the evaluation. Therefore, to further improve IAQ, prevent development of future IAQ-related problems, and to reduce the potential for IAQ-related complaints by building occupants, the IAQ Assessment Team recommends appropriate follow up of each item identified and listed in the attached evaluation.

Please ensure that your Head Facilities Serviceperson receives a copy of this correspondence so that the recommendations requiring their attention can be addressed. Within two weeks a representative from the Custodial/Grounds Department will conduct a follow-up visit to ensure that all issues have been appropriately addressed.

Should any questions arise, or if the current concerns continue after the attached recommendations have been addressed, please feel free to contact me at 754-321-1638.

cc: Dr. Harry LaCava, Area Superintendent
Toni Weissberg, Area Director
Jeffrey S. Moquin, Director, Risk Management
Scott Gillen, Project Manager, Facilities and Construction Management
Dane Ramson, Broward Teachers Union
Roy Jarrett, Federation of Public Employees
Mark Dorsett, Manager 1, Physical Plant Operations Division, Zone 1
Roy Norton, Manager Custodial/Grounds, Physical Plant Operations Division

RK/tc
Enc.

IAQ Assessment

Location Number

Nova Blanche Forman Elementary School

Evaluation Requested

Time of Day

Evaluation Date

Outdoor Conditions Temperature Relative Humidity Ambient CO2

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
<input type="text" value="101T"/>	<input type="text" value="71.3"/>	<input type="text" value="72 - 78"/>	<input type="text" value="52.2"/>	<input type="text" value="30% - 60%"/>	<input type="text" value="728"/>	<input type="text" value="Max 700 > Ambient"/>	<input type="text" value="1"/>
Noticeable Odor		Visible water damage / staining?		Visible microbial growth?		Amount of material affected	
<input type="text" value="No"/>		<input type="text" value="Yes"/>		<input type="text" value="No"/>		<input type="text" value="2 Ceiling Tiles"/>	
Ceiling Type	<input type="text" value="2 x 4 Lay In"/>		<input type="text" value="Yes"/>	<input type="text" value="No"/>		<input type="text" value="2 Ceiling Tiles"/>	
Wall Type	<input type="text" value="Drywall"/>		<input type="text" value="No"/>	<input type="text" value="No"/>		<input type="text" value="None"/>	
Flooring	<input type="text" value="Carpet"/>		<input type="text" value="No"/>	<input type="text" value="No"/>		<input type="text" value="None"/>	

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	<input type="text" value="No"/>	<input type="text" value="Yes"/>	<input type="text" value="Yes"/>	<input type="text" value="Replace stained ceiling tiles"/>
Walls	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Flooring	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Supply Grills	<input type="text" value="No"/>	<input type="text" value="Yes"/>	<input type="text" value="Yes"/>	<input type="text" value="Clean with Wexcide disinfectant"/>
HVAC Return Grills	<input type="text" value="No"/>	<input type="text" value="Yes"/>	<input type="text" value="Yes"/>	<input type="text" value="Clean with Wexcide disinfectant"/>
Ceiling at Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Surfaces in Room	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>

Observations

Findings:

- Dust and debris on HVAC supply and return grills
- Temperature was low at the time of the assessment
- 2 stained ceiling tiles

-Recommendations:

Site Based Maintenance:

- Clean HVAC supply and return grills with Wexcide disinfectant solution
- Adjust the thermostat to increase the temperature. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
- Remove and replace stained ceiling tiles
- Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate

Physical Plant Operations:

- Evaluate roof for leaks and evaluate pipes above drop ceiling for source or water intrusion. Repair as appropriate.