

Telephone: 754-321-3200

Facsimile: 754-321-3290

February 2, 2009

Signature on File

TO: Mr. Chuck McCanna,, Principal
Nova Blanche Forman Elementary School

FROM: Edward See, Project Manager
Risk Management Department

SUBJECT: Indoor Air Quality (IAQ) Assessment
Portable 847VE

For Custodial Supervisor Use Only	
<input type="checkbox"/>	Custodial Issues Addressed
<input type="checkbox"/>	Custodial Issues Not Addressed

On January 30, 2009 I conducted an assessment of Portable 847VE at **Nova Blanche Forman Elementary School**. This evaluation included observations of the flooring system, ceiling tiles, false ceiling plenum, environmental surfaces, interior and exterior walls, and the accessible ventilation equipment. Additionally, environmental parameter measurements were taken to include temperature, relative humidity, and carbon dioxide. The detailed findings, along with the recommended corrective action can be found on the attached IAQ Assessment Worksheets.

The IAQ assessment did identify one or more existing conditions impacting IAQ and appropriate action has been taken to correct deficiencies in systems and maintenance that could contribute to decreased indoor air quality. At the time of the assessment, these concerns were not an immediate health or safety concern to building occupants. However, due to individual sensitivities and predisposing health factors, it is possible that some building occupants may elicit a health response to agents and / or conditions identified during the evaluation. Therefore, to further improve IAQ, prevent development of future IAQ-related problems, and to reduce the potential for IAQ-related complaints by building occupants, the IAQ Assessment Team recommends appropriate follow up of each item identified and listed in the attached evaluation.

Please ensure that your Head Facilities Serviceperson receives a copy of this correspondence so that the recommendations requiring their attention can be addressed. Within two weeks a representative from the Custodial/Grounds Department will conduct a follow-up visit to ensure that all issues have been appropriately addressed.

Should any questions arise, or if the current concerns continue after the attached recommendations have been addressed, please feel free to contact me at 754-321-3200.

cc: Dr. Leontine Butler, Area Superintendent
Dr. Desmond Blackburn, Area Director
Jeffrey S. Moquin, Executive Director, Support Operations
Scott Gillen, Project Manager, Facilities and Construction Management
Diane Watts, Broward Teachers Union
Roy Jarrett, National Federation of Public and Private Employees
Mark Dorsett, Manager 1, Physical Plant Operations Division, Zone 1
Roy Norton, Manager Custodial/Grounds, Physical Plant Operations Division
Robert Krickovich, Coordinator, LEA, Facilities and Construction Management

ES/tc
Enc.

IAQ Assessment

Location Number
 Evaluation Requested
 Evaluation Date

Nova Blanche Forman Elementary School

Time of Day

Outdoor Conditions Temperature Relative Humidity Ambient CO2

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
<input type="text" value="P-847VE"/>	<input type="text" value="72.2"/>	<input type="text" value="72 - 78"/>	<input type="text" value="50.3"/>	<input type="text" value="30% - 60%"/>	<input type="text" value="445"/>	<input type="text" value="Max 700 > Ambient"/>	<input type="text" value="2"/>
Noticeable Odor	<input type="text" value="No"/>		Visible water damage / staining?		Visible microbial growth?		Amount of material affected
Ceiling Type	<input type="text" value="2 x 4"/>		<input type="text" value="Yes"/>		<input type="text" value="No"/>		<input type="text" value="1 ceiling tile"/>
Wall Type	<input type="text" value="Vinyl"/>		<input type="text" value="No"/>		<input type="text" value="No"/>		<input type="text" value="None"/>
Flooring	<input type="text" value="12 x 12"/>		<input type="text" value="No"/>		<input type="text" value="No"/>		<input type="text" value="None"/>

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	<input type="text" value="No"/>	<input type="text" value="Yes"/>	<input type="text" value="Yes"/>	<input type="text" value="Evaluate cause of stained ceiling tile"/>
Walls	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Flooring	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Return Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Ceiling at Supply Grills	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text" value="N/A"/>
Surfaces in Room	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>

Observations

Findings:
 - 1 stained ceiling tile. HFSP advised tile has been changed and staining returns

Restroom in portable:
 - Baseboard behind toilet shows signs of water damage
 - South wall damaged with multiple holes
 - Water stains on walls

Recommendations:
Site Based Maintenance:
 - Wipe down walls in restroom
 - Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate

Physical Plant Operations:
 - Evaluate cause of stained ceiling tile and repair as appropriate
 - Evaluate restroom in portable - evaluate cause of water damaged baseboard and South wall - and repair as appropriate. Repair/replace wall material as necessary.