

Nova Blanche Forman Elementary

IAQ Walkthrough 5/25/2005

1282

Outside Temp RH% CO2

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
<i>101A</i>	Temp <input type="text" value="73.9"/> RH% <input type="text" value="47.2"/> CO2 <input type="text" value="419"/>	Occupants: <input type="text"/>			
	LOCAL EXHAUST FANS				
	Bathroom exhaust fan is functioning properly?	No issues identified at the time of assessment.	None		
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)	No issues identified at the time of assessment.	None		
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?	No issues identified at the time of assessment.	None		
	Other exhaust fans that may exist in the classroom are functioning properly?	No issues identified at the time of assessment.	None		
	Walkthrough				
		No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
<i>101D</i>	Temp <input type="text" value="69.8"/> RH% <input type="text" value="44"/> CO2 <input type="text" value="420"/>	Occupants: <input type="text"/>			
	LOCAL EXHAUST FANS				
	Bathroom exhaust fan is functioning properly?	No issues identified at the time of assessment.	None		
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)	No issues identified at the time of assessment.	None		
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?	No issues identified at the time of assessment.	None		
	Other exhaust fans that may exist in the classroom are functioning properly?	No issues identified at the time of assessment.	None		
	THERMAL COMFORT				
	Classroom is free of significant temperature shifts?	No issues identified at the time of assessment.	None		
	Walkthrough				
		No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
<i>101D</i>	Temp	<input type="text" value="69.8"/>	RH% <input type="text" value="44"/>	CO2 <input type="text" value="420"/>	Occupants: <input type="text"/>		
				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
<i>101E</i>	Temp	<input type="text" value="72.1"/>	RH% <input type="text" value="51.8"/>	CO2 <input type="text" value="416"/>	Occupants: <input type="text"/>		
GENERAL CLEANLINESS							
				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
LOCAL EXHAUST FANS							
				Bathroom exhaust fan is functioning properly?	* There are no local exhaust fans in my office.	No exhaust fans in room. Identified in error.	None
				Other exhaust fans that may exist in the classroom are functioning properly?	* There are no local exhaust fans in my office.	No exhaust fans in room. Identified in error.	None
<i>101G</i>	Temp	<input type="text" value="73.4"/>	RH% <input type="text" value="48.6"/>	CO2 <input type="text" value="408"/>	Occupants: <input type="text"/>		
AIR CONDITIONING							
				Room is free of smell of mold or mildew?		No odor detected at the time of assessment.	None
				Windows/doors are operable and are kept closed?		No windows in room.	None
ANIMALS IN THE CLASSROOM							
				Activities and/or room conditions are modified to address student allergies?		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
DRAIN TRAPS IN THE CLASSROOM							
				Water poured down floor drains once per week (approx. 1 quart of water).		No issues identified at the time of assessment.	None
EXCESS MOISTURE IN CLASSROOMS							
				Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?		No leaks or signs of water intrusion identified.	None
				Indoor surfaces of exterior walls free of continuous condensation?		No visible condensation at the time of assessment.	None
GENERAL CLEANLINESS							
				Classroom is dusted/vacuumed thoroughly and regularly?		General cleanliness of the room at the time of assessment was acceptable.	None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
101G	Temp	<input type="text" value="73.4"/>	RH% <input type="text" value="48.6"/>	CO2 <input type="text" value="408"/>	Occupants: <input type="text"/>		
LOCAL EXHAUST FANS							
Bathroom exhaust fan is functioning properly?				No issues identified at the time of assessment.	None		
Other exhaust fans that may exist in the classroom are functioning properly?				No issues identified at the time of assessment.	None		
101H	Temp	<input type="text" value="73.2"/>	RH% <input type="text" value="48.7"/>	CO2 <input type="text" value="407"/>	Occupants: <input type="text"/>		
AIR CONDITIONING							
Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None		
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks or signs of water intrusion identified.	None		
Indoor surfaces of exterior walls free of continuous condensation?				No visible condensation at the time of assessment.	None		
LOCAL EXHAUST FANS							
Bathroom exhaust fan is functioning properly?				No issues identified at the time of assessment.	None		
Walkthrough							
				Floor box in slab is covered by new carpet that needs to be trimmed and cut - tripping hazard.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
101K	Temp	<input type="text" value="72.4"/>	RH% <input type="text" value="49.3"/>	CO2 <input type="text" value="450"/>	Occupants: <input type="text"/>		
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
Indoor surfaces of exterior walls free of continuous condensation?				No visible condensation at the time of assessment.	None		
LOCAL EXHAUST FANS							
Bathroom exhaust fan is functioning properly?			I do not have an exhaust fan in my office.	No exhaust fans in room. Identified in error.	None		
Other exhaust fans that may exist in the classroom are functioning properly?			I do not have an exhaust fan in my office.	No exhaust fans in room. Identified in error.	None		

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
<i>101L</i>	Temp <input type="text"/> RH% <input type="text"/> CO2 <input type="text"/>	Occupants: <input type="text"/>			
	EXCESS MOISTURE IN CLASSROOMS Indoor surfaces of exterior walls free of continuous condensation?	No visible condensation at the time of assessment.	None		
<i>101Q</i>	Temp <input type="text"/> RH% <input type="text"/> CO2 <input type="text"/>	Occupants: <input type="text"/>			
	LOCAL EXHAUST FANS Bathroom exhaust fan is functioning properly?	No bathroom. Identified in error.	None		
	Other exhaust fans that may exist in the classroom are functioning properly?	No exhaust fans in room. Identified in error.	None		
<i>101S</i>	Temp <input type="text" value="72.3"/> RH% <input type="text" value="49.8"/> CO2 <input type="text" value="425"/>	Occupants: <input type="text"/>			
	AIR CONDITIONING Room is free of smell of mold or mildew?	No odor detected at the time of assessment.	None		
	GENERAL CLEANLINESS Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	No dust observed on supply/return registers at the time of assessment.	None		
	LOCAL EXHAUST FANS Bathroom exhaust fan is functioning properly?	No issues identified at the time of assessment.	None		
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)	No issues identified at the time of assessment.	None		
	Other exhaust fans that may exist in the classroom are functioning properly?	No issues identified at the time of assessment.	None		
	THERMAL COMFORT Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..	None		
	Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was acceptable at the time of assessment.	None		
<i>101T</i>	Temp <input type="text" value="72.3"/> RH% <input type="text" value="49.3"/> CO2 <input type="text" value="430"/>	Occupants: <input type="text"/>			
	GENERAL CLEANLINESS Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	No dust observed on supply/return registers at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
101T	Temp	<input type="text" value="72.3"/>	RH% <input type="text" value="49.3"/>	CO2 <input type="text" value="430"/>	Occupants: <input type="text"/>		
THERMAL COMFORT							
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)					No windows in room.	None	
Walkthrough							
					No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based 2
103	Temp	<input type="text" value="72.3"/>	RH% <input type="text" value="48.9"/>	CO2 <input type="text" value="420"/>	Occupants: <input type="text"/>		
ANIMALS IN THE CLASSROOM							
You are informed about the potential allergies of your students?						Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?					Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
Classroom is dusted/vacuumed thoroughly and regularly?					Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
LOCAL EXHAUST FANS							
Bathroom exhaust fan is functioning properly?			No bathroom in room.		No bathroom. Identified in error.	None	
Other exhaust fans that may exist in the classroom are functioning properly?			No bathroom in room.		No exhaust fans in room. Identified in error.	None	
104	Temp	<input type="text" value="73.2"/>	RH% <input type="text" value="47.1"/>	CO2 <input type="text" value="429"/>	Occupants: <input type="text"/>		
ANIMALS IN THE CLASSROOM							
You are informed about the potential allergies of your students?						Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?					No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
104	Temp	<input type="text" value="73.2"/>	RH%	<input type="text" value="47.1"/>	CO2	<input type="text" value="429"/>	Occupants:	<input type="text"/>
GENERAL CLEANLINESS								
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based		2	
Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based		2	
LOCAL EXHAUST FANS								
Bathroom exhaust fan is functioning properly?			there is not a bathroom	No bathroom. Identified in error.	None			
Other exhaust fans that may exist in the classroom are functioning properly?			there is not a bathroom	No exhaust fans in room. Identified in error.	None			
THERMAL COMFORT								
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)			No windows in room.	None				
109A	Temp	<input type="text" value="75.3"/>	RH%	<input type="text" value="46.1"/>	CO2	<input type="text" value="423"/>	Occupants:	<input type="text"/>
AIR CONDITIONING								
Room is free of smell of mold or mildew?			No odor detected at the time of assessment. Coffee pot was in use during assessment.	None				
ANIMALS IN THE CLASSROOM								
Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based		3	
GENERAL CLEANLINESS								
Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	Site Based		2	
Room is free of pests?			No pests observed at the time of assessment.	None				

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
131	Temp	74.6	RH% 53.4	CO2 423	Occupants:		
THERMAL COMFORT							
Room is usually comfortable? (If no, please explain in the notes below.)		It may be just a little too cold.		Environmental parameters were within acceptable range at the time of assessment.	None		
Temperature in my classroom is generally comfortable (72F-76F)?		It may be just a little too cold.		Temperature was acceptable at the time of assessment.	None		
133	Temp	74.8	RH% 53.7	CO2 438	Occupants:		
ANIMALS IN THE CLASSROOM							
Classroom is free of animals and pets?				No animals identified at the time of assessment.	None		
LOCAL EXHAUST FANS							
Bathroom exhaust fan is functioning properly?				Exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	1
THERMAL COMFORT							
Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was acceptable at the time of assessment.	None		
134	Temp	73.1	RH% 48.1	CO2 442	Occupants:		
ANIMALS IN THE CLASSROOM							
Classroom is free of animals and pets?				No animals identified at the time of assessment.	None		
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
136	Temp	72.9	RH% 47.7	CO2 456	Occupants:		
ANIMALS IN THE CLASSROOM							
Classroom is free of animals and pets?				No animals identified at the time of assessment.	None		
EXCESS MOISTURE IN CLASSROOMS							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
136	Temp	72.9	RH% 47.7	CO2 456	Occupants: <input type="text"/>		
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?			Excessive dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	Site Based	2
	Classrooms general appearance is clean and acceptable?			Room is cluttered.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	Site Based	2
	Room is free of pests?			No pests observed at the time of assessment.	None		
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?		Either too cold or to hot at all times. I wear two jackets sometimes.		Environmental parameters were within acceptable range at the time of assessment..	None	
	Room is usually comfortable? (If no, please explain in the notes below.)		Either too cold or to hot at all times. I wear two jackets sometimes.		Environmental parameters were within acceptable range at the time of assessment..	None	
	Temperature in my classroom is generally comfortable (72F-76F)?		Either too cold or to hot at all times. I wear two jackets sometimes.		Temperature was acceptable at the time of assessment.	None	
137	Temp	72.7	RH% 43.3	CO2 415	Occupants: <input type="text"/>		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None		
	ANIMALS IN THE CLASSROOM						
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	EXCESS MOISTURE IN CLASSROOMS						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
137	Temp	72.7	RH% 43.3	CO2 415	Occupants:		
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	
	Room is free of pests?				No pests observed at the time of assessment.	None	
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?				Exhaust fan is functioning properly.	None	
138	Temp	72.3	RH% 46.4	CO2 486	Occupants:		
ANIMALS IN THE CLASSROOM							
	Classroom is free of animals and pets?				There has still been signs of rodents in the classroom as of 2/23/05. The closet had to be cleaned of rodent droppings and urine. All food was removed and/or put in sealed containers.	Unsealed food items were observed at the time of assessment. Unsealed food items may attract pests.	Site based administration should encourage all staff to maintain food items within sealable plastic storage containers. Site Based 1
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?				Floors need to be mopped on a regular basis, especially the restroom. The sink area including the counter should also be cleaned on a daily basis. Water fountain in classroom does not work properly.	Excessive dust accumulation was observed on environmental surfaces at the time of assessment. Room is cluttered.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts. Site Based 2
	Floor is cleaned on a regular basis?				Floors need to be mopped on a regular basis, especially the restroom. The sink area including the counter should also be cleaned on a daily basis. Water fountain in classroom does not work properly.	Dust and dirt accumulation on floor. Room is cluttered.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their cleaning efforts. Site Based 2
	Room is free of pests?				Floors need to be mopped on a regular basis, especially the restroom. The sink area including the counter should also be cleaned on a daily basis. Water fountain in classroom does not work properly.	Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action. Physical Plant Operations 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
138N	Temp	<input type="text" value="76.3"/>	RH% <input type="text" value="43.4"/>	CO2 <input type="text" value="1219"/>	Occupants: <input type="text"/>		
AIR CONDITIONING							
	Room is free of smell of mold or mildew?			No odor of mold and mildew detected at the time of assessment.			1
	Windows/doors are operable and are kept closed?			No issues identified at the time of assessment.	None		
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Room is free of the use of scented cleaners and air fresheners?			Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1
THERMAL COMFORT							
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)		There are gaps along the floor frame exposing to the outside	No issues identified at the time of assessment.	None		
Walkthrough							
				Gap between floor sheathing and wall due to previous abatement work.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1
139	Temp	<input type="text" value="73.1"/>	RH% <input type="text" value="47.2"/>	CO2 <input type="text" value="419"/>	Occupants: <input type="text"/>		
GENERAL CLEANLINESS							
	Room is free of pests?			No pests observed at the time of assessment.	None		
141	Temp	<input type="text" value="71.9"/>	RH% <input type="text" value="44.7"/>	CO2 <input type="text" value="404"/>	Occupants: <input type="text"/>		
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	Classroom is free of animals and pets?			No animals identified at the time of assessment.	None		
GENERAL CLEANLINESS							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
141	Temp	71.9	RH%	44.7	CO2	404	Occupants:				
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based					2
	Room is free of pests?			No pests observed at the time of assessment.	None						
	THERMAL COMFORT										
	Classroom is free of significant temperature shifts?			too cold	Environmental parameters were within acceptable range at the time of assessment..	None					
	Room is usually comfortable? (If no, please explain in the notes below.)			too cold	Environmental parameters were within acceptable range at the time of assessment..	None					
	Temperature in my classroom is generally comfortable (72F-76F)?			too cold	Temperature was acceptable at the time of assessment.	None					
	Walkthrough										
				Signs of water intrusion. Leak identified. Sink is leaking and cabinet needs to be repaired.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations					1
142	Temp	71.8	RH%	46.8	CO2	457	Occupants:				
	ANIMALS IN THE CLASSROOM										
	Classroom is free of animals and pets?				No animals identified at the time of assessment.	None					
	GENERAL CLEANLINESS										
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based				2
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None					
	Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was acceptable.	None					
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None					
	Room is free of pests?				Unsealed food items were observed at the time of assessment. Unsealed food items may attract pests.	Site based administration should encourage all staff to maintain food items within sealable plastic storage containers.	Site Based				1
	THERMAL COMFORT										
	Classroom is free of significant temperature shifts?				Environmental parameters were within acceptable range at the time of assessment..	None					

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

144

Temp RH% CO2

Occupants:

ANIMALS IN THE CLASSROOM

Classroom is free of animals and pets?

We do have a fish tank

No animals identified at the time of assessment.

None

I also have occasional allergies that I have not medically determined to what. Bad air quality may be part of it

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

*Room is currently free of pests, but in the fall an animal had eaten cookies out of a bag in a closet. No other problems since.
* the floor is swept regularly, but not spot mopped
* occasional use of antibacterial spray to help reduce germs commonly

Dust observed on return register at the time of assessment.

Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Site Based

2

Classroom is dusted/vacuumed thoroughly and regularly?

*Room is currently free of pests, but in the fall an animal had eaten cookies out of a bag in a closet. No other problems since.
* the floor is swept regularly, but not spot mopped
* occasional use of antibacterial spray to help reduce germs commonly

There does not appear to be a dusting issue within this room.

None

Room is free of the use of scented cleaners and air fresheners?

*Room is currently free of pests, but in the fall an animal had eaten cookies out of a bag in a closet. No other problems since.
* the floor is swept regularly, but not spot mopped
* occasional use of antibacterial spray to help reduce germs commonly

Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment. (under sink)

Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.

Site Based

1

THERMAL COMFORT

Classroom is free of significant temperature shifts?

Classroom temperature is always on the cold side seemingly colder in the afternoon after lunch. This is recent within the past 4 month. Many days jackets are needed inside when not needed outside.

Occupant advised of temperature fluctuations.

Physical Plant Operations to evaluate HVAC system for proper operation.

Physical Plant Operations

2

In the past temperature used to raise in the afternoon.

Room is usually comfortable? (If no, please explain in the notes below.)

Classroom temperature is always on the cold side seemingly colder in the afternoon after lunch. This is recent within the past 4 month. Many days jackets are needed inside when not needed outside.

See other recommendation.

In the past temperature used to raise in the afternoon.

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
144	Temp	72.8	RH% 61.5	CO2 426	Occupants:		
Temperature in my classroom is generally comfortable (72F-76F)?	Classroom temperature is always on the cold side seemingly colder in the afternoon after lunch. This is recent within the past 4 month. Many days jackets are needed inside when not needed outside.			Temperature was acceptable at the time of assessment.	None		
	In the past temperature used to raise in the afternoon.						
145	Temp	72.2	RH% 48.3	CO2 400	Occupants:		
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?			I have a fish tank, with some small fish. I do not consider it an animal or pet.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.		
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None		
	Room is free of pests?			No pests observed at the time of assessment.	None		
Walkthrough				No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
146	Temp	72.9	RH% 56.7	CO2 432	Occupants:		
EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Stained ceiling tiles and water in light fixtures.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	1
GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None		
	Room is free of pests?			No pests observed at the time of assessment.	None		
THERMAL COMFORT							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
146	Temp	72.9	RH% 56.7	CO2 432	Occupants: <input type="text"/>		
	Room is usually comfortable? (If no, please explain in the notes below.)	My room is very cold!			Environmental parameters were within acceptable range at the time of assessment.	None	
	Temperature in my classroom is generally comfortable (72F-76F)?	My room is very cold!			Temperature was acceptable at the time of assessment.	None	
147	Temp	71.7	RH% 71	CO2 402	Occupants: <input type="text"/>		
	AIR CONDITIONING						
	Windows/doors are operable and are kept closed?				Exterior door needs new weather stripping.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations 1
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	Classroom is free of animals and pets?				Animals were identified at the time of assessment. Animal/pet dander is a major allergen source that could impact occupant allergies.	Location to ensure that housing of animal or pet is in conjunction with approved curriculum. If not the animal must be removed.	Site Based 1
ART SUPPLIES							
	Art supplies okay?				No issues identified at the time of assessment.	None	
	Industrial supplies okay?				No issues identified at the time of assessment.	None	
	Science supplies okay?				No issues identified at the time of assessment.	None	
EXCESS MOISTURE IN CLASSROOMS							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based 2
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
	Room is free of pests?				No pests observed at the time of assessment.	None	
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?				Temperature was acceptable at the time of assessment.	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
147	Temp	71.7	RH% 71	CO2 402	Occupants: <input type="text"/>		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)				Humidity was elevated at the time of the assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations 2
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)				Exterior door needs new weather stripping.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations 1
	Room is usually comfortable? (If no, please explain in the notes below.)				Temperature was acceptable at the time of assessment.	None	
	Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was acceptable at the time of assessment.	None	
150	Temp	72.7	RH% 47.9	CO2 435	Occupants: <input type="text"/>		
	ANIMALS IN THE CLASSROOM						
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?				Excessive dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Room is free of pests?				Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations 2
	THERMAL COMFORT						
	Room is usually comfortable? (If no, please explain in the notes below.)		My room adjoins another and one side is usually very cold and the other side is warm.		Environmental parameters were within acceptable range at the time of assessment..	None	
	Temperature in my classroom is generally comfortable (72F-76F)?		My room adjoins another and one side is usually very cold and the other side is warm.		Temperature was acceptable at the time of assessment.	None	
	Walkthrough						
					Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
151	Temp	72.3	RH% 65	CO2 408	Occupants:		
GENERAL CLEANLINESS							
	Room is free of pests?				Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations 2
Walkthrough							
					Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
					Excessive dust accumulation was observed on environmental surfaces at the time of assessment. Room is cluttered.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	Site Based 2
					No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based 2
					Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
152	Temp	72.4	RH% 53	CO2 423	Occupants:		
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?		No Bathroom or exhaust fans.		No bathroom. Identified in error.	None	
	Other exhaust fans that may exist in the classroom are functioning properly?		No Bathroom or exhaust fans.		No exhaust fans in room. Identified in error.	None	
THERMAL COMFORT							
	Room is usually comfortable? (If no, please explain in the notes below.)		Too cold		Environmental parameters were within acceptable range at the time of assessment..	None	
	Temperature in my classroom is generally comfortable (72F-76F)?		Too cold		Temperature was acceptable at the time of assessment.	None	
Walkthrough							
					Live plants in room.	facilities serviceperson should remove live plants.	Site Based 1

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
160	Temp	71.5	RH% 47.5	CO2 633	Occupants:		
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Room is free of pests?				Unsealed food items were observed at the time of assessment. Unsealed food items may attract pests.	Site based administration should encourage all staff to maintain food items within sealable plastic storage containers.	Site Based 1
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?		Air temperature changes from freezing to warm.		Environmental parameters were within acceptable range at the time of assessment..	None	
	Room is usually comfortable? (If no, please explain in the notes below.)		Air temperature changes from freezing to warm.		Environmental parameters were within acceptable range at the time of assessment..	None	
	Temperature in my classroom is generally comfortable (72F-76F)?		Air temperature changes from freezing to warm.		Temperature was a little lower than parameters at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based 2
161	Temp	71	RH% 48.3	CO2 613	Occupants:		
EXCESS MOISTURE IN CLASSROOMS							
	Area around and under classroom sinks free of leaks?				No leaks or signs of water intrusion identified.	None	
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	
	Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was acceptable.	None	
	Room is free of pests?				No pests observed at the time of assessment.	None	
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?				Exhaust fan is functioning properly.	None	
THERMAL COMFORT							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
161	Temp <input type="text" value="71"/>	RH% <input type="text" value="48.3"/>	CO2 <input type="text" value="613"/>	Occupants: <input type="text"/>			
	Classroom is free of significant temperature shifts?	Many times the room is too hot.		Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Room is usually comfortable? (If no, please explain in the notes below.)	Many times the room is too hot.		Temperature was low at the time of assessment.			
	Temperature in my classroom is generally comfortable (72F-76F)?	Many times the room is too hot.		Temperature was low at the time of assessment.			
	Walkthrough						
				Unsealed food items were observed at the time of assessment. Unsealed food items may attract pests.	Site based administration should encourage all staff to maintain food items within sealable plastic storage containers.	Site Based	1
162	Temp <input type="text" value="71.1"/>	RH% <input type="text" value="51.6"/>	CO2 <input type="text" value="522"/>	Occupants: <input type="text"/>			
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Room is free of pests?			Unsealed food items were observed at the time of assessment. Unsealed food items may attract pests.	Site based administration should encourage all staff to maintain food items within sealable plastic storage containers.	Site Based	1
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?	It is very very cold during many times.		Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Room is usually comfortable? (If no, please explain in the notes below.)	It is very very cold during many times.		Temperature was low at the time of assessment.			
	Temperature in my classroom is generally comfortable (72F-76F)?	It is very very cold during many times.		Temperature was low at the time of assessment.			

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
165	Temp	72.1	RH% 49.9	CO2 672	Occupants:		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
THERMAL COMFORT							
Room is usually comfortable? (If no, please explain in the notes below.)			Room is constantly cold	Environmental parameters were within acceptable range at the time of assessment..	None		
Temperature in my classroom is generally comfortable (72F-76F)?			Room is constantly cold	Temperature was acceptable at the time of assessment.	None		
Walkthrough							
				Stained ceiling tiles with visible microbial growth.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
171	Temp	73.2	RH% 52.3	CO2 769	Occupants:		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
172	Temp	69.8	RH% 50.8	CO2 699	Occupants:		
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
THERMAL COMFORT							
Classroom is free of significant temperature shifts?			Always extremely cold, winter and summer	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
172	Temp	69.8	RH% 50.8	CO2 699	Occupants: <input type="text"/>			
	Room is usually comfortable? (If no, please explain in the notes below.)	Always extremely cold, winter and summer			Temperature was low at the time of assessment.			
	Temperature in my classroom is generally comfortable (72F-76F)?	Always extremely cold, winter and summer			Temperature was low at the time of assessment.			
	Walkthrough			Water damage at exterior door along wall.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1	
174	Temp	70.4	RH% 48.6	CO2 734	Occupants: <input type="text"/>			
	GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Room is free of pests?				Unsealed food items were observed at the time of assessment. Unsealed food items may attract pests.	Site based administration should encourage all staff to maintain food items within sealable plastic storage containers.	Site Based	1
	Walkthrough			No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2	
180	Temp	72.8	RH% 49.7	CO2 705	Occupants: <input type="text"/>			
	EXCESS MOISTURE IN CLASSROOMS							
	Classroom lavatories/water fountains free of leaks?	Q e- The faucet on the sink is difficult to shut off for the children and water runs from the faucet unless I shut it off.			Occupant advised that the faucet is hard to shut off. Not an IAQ issue.	Facilities serviceperson should call in a work order to have Physical Plant Operations repair faucet.	Site Based	2
	Windows, windowsills and window frames free of continuous condensation?	Q e- The faucet on the sink is difficult to shut off for the children and water runs from the faucet unless I shut it off.			No visible condensation at the time of assessment. Signs of previous water intrusion as evidenced by stains on walls.	None		
	GENERAL CLEANLINESS							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
180	Temp	72.8	RH% 49.7	CO2 705	Occupants:			
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Q-e- define regularly? I would like for our rooms to be fully mopped everyother day. We have rugs in our rooms that are vacuumed everyother day, it would be nice if they were vacuumed daily as we have small children in our class.			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?	Q-e- define regularly? I would like for our rooms to be fully mopped everyother day. We have rugs in our rooms that are vacuumed everyother day, it would be nice if they were vacuumed daily as we have small children in our class.			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?	Q-e- define regularly? I would like for our rooms to be fully mopped everyother day. We have rugs in our rooms that are vacuumed everyother day, it would be nice if they were vacuumed daily as we have small children in our class.			Floor was clean at the time of assessment.	None		
LOCAL EXHAUST FANS								
	Bathroom exhaust fan is functioning properly?				Exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	1
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?				No issues identified at the time of assessment.	None		
THERMAL COMFORT								
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	The rooms in the kindergarten wing are sometimes too cold. You can feel the temperture change as you are walking to our part of the school. There is a gap under the door to the outside playground. Water, dirt and other critters could fit under the door			No issues identified at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)	The rooms in the kindergarten wing are sometimes too cold. You can feel the temperture change as you are walking to our part of the school. There is a gap under the door to the outside playground. Water, dirt and other critters could fit under the door			Environmental parameters were within acceptable range at the time of assessment..	None		
	Temperature in my classroom is generally comfortable (72F-76F)?	The rooms in the kindergarten wing are sometimes too cold. You can feel the temperture change as you are walking to our part of the school. There is a gap under the door to the outside playground. Water, dirt and other critters could fit under the door			Temperature was acceptable at the time of assessment.	None		

Walkthrough

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
180	Temp	72.8	RH% 49.7	CO2 705	Occupants: <input type="text"/>		
				Exterior door has gap at threshold.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
181	Temp	72.7	RH% 48.5	CO2 634	Occupants: <input type="text"/>		
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?		Backsplash needs to be cleaned of droppings from insects (lizards, cockroaches) on a semiregular basis.		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
EXCESS MOISTURE IN CLASSROOMS							
	Cold water pipes free of continuous condensation?			Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?		Due to the age appropriate curriculum/activities, the rugs should be vacuumed more often and some restrooms need to be mopped with cleaned water as little ones oftentimes make messes. As children are on the floors daily, spot cleaning is not sufficient.	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classrooms general appearance is clean and acceptable?		Due to the age appropriate curriculum/activities, the rugs should be vacuumed more often and some restrooms need to be mopped with cleaned water as little ones oftentimes make messes. As children are on the floors daily, spot cleaning is not sufficient.	General cleanliness of the room at the time of assessment was acceptable.	None		
	Room is free of pests?		Due to the age appropriate curriculum/activities, the rugs should be vacuumed more often and some restrooms need to be mopped with cleaned water as little ones oftentimes make messes. As children are on the floors daily, spot cleaning is not sufficient.	Unsealed food items were observed at the time of assessment. Unsealed food items may attract pests.	Site based administration should encourage all staff to maintain food items within sealable plastic storage containers.	Site Based	1
182	Temp	71.6	RH% 51.9	CO2 712	Occupants: <input type="text"/>		
LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?			No issues identified at the time of assessment.	None		
Walkthrough							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
182	Temp	71.6	RH% 51.9	CO2 712	Occupants: <input type="text"/>		
				Exterior door needs weather stripping.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
183	Temp	71.6	RH% 50.3	CO2 707	Occupants: <input type="text"/>		
AIR CONDITIONING							
	Air flowing from air supply?		Closet has an unusual smell	Air flowing without obstruction at the time of assessments.	None		
	Air is flowing without obstruction?		Closet has an unusual smell	Air flowing without obstruction at the time of assessments.	None		
	Room is free of smell of mold or mildew?		Closet has an unusual smell	No odor detected from mold and mildew at the time of assessment. Odor of crayons was present.	None		
EXCESS MOISTURE IN CLASSROOMS							
	Windows, windowsills and window frames free of continuous condensation?			No visible condensation at the time of assessment.	None		
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		Classroom is not dusted thoroughly or regularly. I suffer from asthma/allergies and it really concerns me. I feel that carpets should be vacuumed at least 3x a week and the floor should be swept thoroughly.	Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?		Classroom is not dusted thoroughly or regularly. I suffer from asthma/allergies and it really concerns me. I feel that carpets should be vacuumed at least 3x a week and the floor should be swept thoroughly.	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?		Classroom is not dusted thoroughly or regularly. I suffer from asthma/allergies and it really concerns me. I feel that carpets should be vacuumed at least 3x a week and the floor should be swept thoroughly.	Floor was clean at the time of assessment.	None		
THERMAL COMFORT							
	Room is usually comfortable? (If no, please explain in the notes below.)		Classroom is always very cold.	Environmental parameters were within acceptable range at the time of assessment..	None		
	Temperature in my classroom is generally comfortable (72F-76F)?		Classroom is always very cold.	Temperature was acceptable at the time of assessment.	None		
Walkthrough							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
183	Temp	71.6	RH% 50.3	CO2 707	Occupants: <input type="text"/>		
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1
429C	Temp	76.3	RH% 52.8	CO2 1185	Occupants: <input type="text"/>		
AIR CONDITIONING							
				Room is free of smell of mold or mildew?	No odor detected at the time of assessment.	None	
ANIMALS IN THE CLASSROOM							
				Activities and/or room conditions are modified to address student allergies?	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
				You are informed about the potential allergies of your students?	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
EXCESS MOISTURE IN CLASSROOMS							
				Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based 2
				Indoor surfaces of exterior walls free of continuous condensation?	No visible condensation at the time of assessment.	None	
				Windows, windowsills and window frames free of continuous condensation?	No visible condensation at the time of assessment.	None	
GENERAL CLEANLINESS							
				Classroom is dusted/vacuumed thoroughly and regularly?	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
Walkthrough							
					Carpet was stained and rippled.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
847VE	Temp	69.9	RH% 48.5	CO2 406	Occupants:		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS							
Room is free of pests?					No pests observed at the time of assessment.	None	
Walkthrough							
					No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations 1
					Temperature was low at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations 2
855	Temp	75.3	RH% 51.3	CO2 776	Occupants:		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?					Excessive dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2